



2499

EMISSIONS MONITORING SURVEY

Prepared for:

Western Bio-Energy Ltd
Longlands Lane
Margam
Port Talbot
SA13 2NR

Permit Number	: EPR/ZP3939GL
Variation Number	: V005
Installation	: Biomass Plant
Visit Details	: Compliance – January 2023
Job Number	: P5200
Report Number	: R003
Report Issue Date	: 16th February 2023
Survey Dates	: 5th – 9th January 2023

Prepared by:

Environmental Compliance Limited
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5BF.

Tel: 01443 841760

Report Issue:		FINAL	
Report Prepared by:		Report Reviewed & Approved by MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
Name:	Scott Hackett	Name:	Andy Barnes
		MCERTS No:	MM 03 235
		Signature:	
Date:	8 th February 2023	Date:	16 th February 2023

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECLs duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Any operating information and CEMS data used in this report has been supplied by the client.

This report should not be reproduced, (except in full) without the written approval of the laboratory.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Clients' release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

TABLE OF CONTENTS

Section	Description	Page Number
PART 1	EXECUTIVE SUMMARY	4
1	MONITORING OBJECTIVES	4
1.1	Monitoring Results	5
1.2	Operating Information	7
2	MONITORING DEVIATIONS	8
PART 2	SUPPORTING INFORMATION	9
3	SAMPLING STAFF DETAILS	9
4	SAMPLING PROTOCOLS / METHODOLOGIES	10
5	SAMPLE POINT DESCRIPTIONS	11
	EQUIPMENT IDs	12
	FIGURES	14
	TABLES	17
	VELOCITY TRAVERSE PROFILES	28
	FIELD CALIBRATION AND SAMPLING DATA	30
	LABORATORY ANALYSIS RESULTS	39
	UNCERTAINTY CALCULATIONS	50
	RESULTS OF FTIR DAILY SPECTRAL RESIDUALS CHECKS	71
	FTIR SUMMARY OF ANALYTICAL BANDS	73

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Western Bio-Energy Ltd** to undertake an emission monitoring survey at their **Margam, Port Talbot** facility. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **DHFB/P5200/Q001**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification
	Biomass Plant (Main Stack)
Particulates	• U
Velocity / Flowrate	• U
Oxides of Nitrogen (as NO ₂)	• U
Sulphur Dioxide	• U
Carbon Monoxide	• U
Oxygen	• U
Total Organic Carbon (TVOC)	• U
Hydrogen Chloride	• U
Hydrogen Fluoride	• U
Dioxins / Furans	• U
Heavy Metals (Cd, Tl, Sb, As, Pb, Cr, Co, Cu, Mn, Ni & V)	• U
Mercury	• U
Nitrous Oxide (N ₂ O)	• U
Ammonia	• U

- Denotes the substances to be monitored.
- U Denotes **UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.**

Special Requirements: *During Normal Operation.*”

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed For Test Result	Tick if non-conforming test (see Section 2)	Operating Status
Biomass Plant (Main Stack)	Volumetric Flowrate	...	48.84675	m ³ /sec	4	Stack Conditions	05/01/2023	09:32 – 10:09	BS EN 16911-1:2013 & MID	UKAS / MCERTS		Normal
	Volumetric Flowrate	...	23.61437	m ³ /sec	7	Dry & 6% O ₂	05/01/2023	09:32 – 10:09	BS EN 16911-1:2013 & MID	UKAS / MCERTS		Normal
	Particulates	15	1.14	mg/m ³	46	Dry & 6% O ₂	05/01/2023	11:50 – 12:52	BS EN 13284-1:2017 & MID	UKAS / MCERTS		Normal
	Hydrogen Chloride	...	24.02	mg/m ³	14	Dry & 6% O ₂	05/01/2023	11:50 – 12:52	BS EN 1911:2010	UKAS / MCERTS		Normal
	Hydrogen Fluoride	...	0.05	mg/m ³	14	Dry & 6% O ₂	05/01/2023	11:50 – 12:52	PD CEN/TS 17340:2020	UKAS / MCERTS		Normal
	Ammonia	10	8.06	mg/m ³	14	Dry & 6% O ₂	05/01/2023	13:30 – 14:30	BS EN ISO 21877:2019	UKAS / MCERTS		Normal
	Sulphur Dioxide	...	20.06	mg/m ³	14	Dry & 6% O ₂	06/01/2023	08:30 – 12:30	BS EN 14791:2017	UKAS / MCERTS		Normal
	PCDDs & PCDFs	...	0.0025	ng/m ³	13	Dry & 6% O ₂	09/01/2023	10:35 – 16:40	BS EN 1948-1:2006 & MID	UKAS / MCERTS		Normal
	Heavy Metals*	...	0.099	mg/m ³	3	Dry & 6% O ₂	05/01/2023	15:00 – 16:02	BS EN 14385:2004 & MID	UKAS / MCERTS		Normal
	Cadmium / Thallium	...	0.0013	mg/m ³	5	Dry & 6% O ₂	05/01/2023	15:00 – 16:02	BS EN 14385:2004 & MID	UKAS / MCERTS		Normal
	Mercury	...	0.00044	mg/m ³	10	Dry & 6% O ₂	06/01/2023	13:10 – 14:12	BS EN 13211:2001	UKAS / MCERTS		Normal
	TVOC as Carbon	...	2.72	mgC/m ³	3	Dry & 6% O ₂	05/01/2023	13:00 – 14:00	BS EN 12619:2013	UKAS / MCERTS		Normal
	Oxides of Nitrogen (as NO ₂)	300	178.73	mg/m ³	2	Dry & 6% O ₂	05/01/2023	14:00 – 15:00	BS EN 14792: 2017	UKAS / MCERTS		Normal
	Carbon Monoxide	250	119.10	mg/m ³	2	Dry & 6% O ₂	05/01/2023	14:00 – 15:00	BS EN 15058: 2017	UKAS / MCERTS		Normal
	Oxygen (Paramagnetic)	...	6.81	%	2	& Dry Gas	05/01/2023	14:00 – 15:00	BS EN 14789: 2017	UKAS / MCERTS		Normal
	Nitrous Oxide (N ₂ O)	...	0.53	mg/m ³	9	Dry & 6% O ₂	09/01/2023	14:00 – 15:00	PD CEN/TS 17337:2019	UKAS / MCERTS		Normal
	Oxygen (Zirconia Cell)	...	8.16	%	2	& Dry Gas	09/01/2023	14:00 – 15:00	BS EN 14789: 2017	UKAS / MCERTS		Normal

The volumetric flowrate shown above is that from the initial pitot traverse.

Any other flow measurements made during isokinetic sampling and/ or repeat traverses are shown later in the tables section.

(* Sum of Sb, As, Pb, Cr, Co, Cu, Mn, Ni & V)

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

Notes

The uncertainty figures presented in Table 1.1 for NO_x, CO, O₂, N₂O & TVOC are “measurement uncertainty” figures, which do not take into account the variability of the measured sample values. The “uncertainty of measurement results” figures, which do include this contribution, are presented in the appendices of the report for these determinands.

Emission Limit Value	The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
Periodic Monitoring Result	The result given is expressed in the same terms and units as the emission limit value.
Uncertainty	The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results DO NOT take into account the effect of the sample location limitations.
Reference Conditions	All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
Monitoring Method Reference	The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
Accreditation for use of Method	The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTs, UKAS. If use of the method is not accredited " NA" is stated.
Operating Status	The details indicate the feedstock and the loading rate of the plant during monitoring.
§	Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
NU	UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
NA	Method is NOT UKAS Accredited.

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

1.2 Operating Information

Any operating information and CEMS data below has been supplied by the client.

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
Biomass Plant	Continuous	Continuous	Wood Chip & Natural Gas	...	Bag Filters	Normal	NP

Notes:

- Process Type State whether the process is a continuous or batch process.
- Process Duration If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
- Fuel If applicable, state the fuel type If not applicable state "NA"
- Feedstock State the feedstock type
- Abatement State the type and whether operational during monitoring. If not applicable state "NA"
- Load State the normal load, throughput or rating of the plant
- CEMS Data Enter this data for each CEM installed if it is has been provided by operator otherwise state "NP" (NOT PROVIDED)

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

2 Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: EPR/ZP3939GL** where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

There were modifications to the sampling procedures (TPDs) listed in section 4, these are as follows:

The concentration of the span check gas used for FTIR sampling of N₂O has not been verified by analysis accredited to ISO 17025 with uncertainty <2%. Such analysis is not currently available. A gravimetrically prepared mixture was used instead. This deviation from the procedure has been sanctioned by the Environment Agency, until 17025 accredited gas does become available.

Due to high duct gas velocity, in order to maintain isokinetic sampling, it was necessary to use a nozzle with diameter smaller than the recommended minimum of 8mm minimum stated in BS EN 13284-1:2017. Note that there is no absolute minimum nozzle size stated in the standard, as long as the uncertainty of the nozzle area is <5%. **So this does not need to be described as a non-conforming test.**

There were substance deviations from the original and agreed emissions monitoring schedule. These are as follows:

At the request of the client, Hydrogen Fluoride was added to the scope of the sampling requirements for the visit.

There were non-conforming tests, as follows.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

The following tests appeared to fail efficiency checks (>5% in final impinger): **Hydrogen Fluoride & Thallium**. For **Hydrogen Fluoride & Thallium**, the concentration in the final impinger was very low (at or below the analytical LOD / blank value, so the efficiency check is not required).

Homogeneity tests have not been completed for pollutants at the following locations: **Biomass Plant (Main Stack)**: Such tests were not requested by the client.

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

PART 2 – SUPPORTING INFORMATION

3 SAMPLING STAFF DETAILS

Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
David Boles	5 th & 9 th January 2023	MM 03 215	2	TE1, TE2, TE4
Peter Brockway	5 th & 6 th January 2023	MM 17 1459	2	TE1, TE2, TE3, TE4
Llion Preskett Hughes	5 th , 6 th & 9 th January 2023	MM 22 1689	Trainee	...

Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	MM 03 235	2	TE1, TE2, TE3, TE4

Technical Endorsement Key:-

- TE1 – Isokinetic** Particulates, Temperature & Velocity Profiles, Oxygen.
- TE2 – Isokinetic** Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.
- TE3 – Non-Isokinetic** Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.
- TE4 – Continuous Analysers** (Combustion Gases):- TVOC, CO, NOx, SO2.

4 SAMPLING PROTOCOLS / METHODOLOGIES

Details of the substances monitored, the standard methods used and the Environmental Compliance Limited Technical Procedures used during this survey are shown in the table below. Detailed sampling protocols are included in a separate document which will be sent with the report.

In all cases, where analysis of collected samples was required, the analysis was by a subcontract laboratory. Details of the sub-contract laboratory are shown on the analysis certificates in this report. The UKAS/MCERTs accreditation status of the analysis is also indicated on the certificates.

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

Determinand	External Reference Method	ECL Technical Procedure Number
Velocity and Flowrate	BS EN 16911-1:2013 & MID	ECL / TPD / 022A
Particulates (MST)	BS EN 13284-1:2017 & MID	ECL / TPD / 027
Metals (without mercury)	BS EN 14385:2004 & MID	ECL / TPD / 028
Mercury (without other metals)	BS EN 13211:2001	ECL / TPD / 030
PCDDs & PCDFs	BS EN 1948-1 to 3:2006 & MID	ECL / TPD / 031
TVOC (Signal 3030PM)	BS EN 12619: 2013	ECL / TPD / 032A
Oxygen (PG350 E)	BS EN 14789: 2017	ECL / TPD / 033D
Carbon Monoxide (PG350 E)	BS EN 15058: 2017	ECL / TPD / 033D
Oxides of Nitrogen (PG350 E)	BS EN 14792: 2017	ECL / TPD / 033D
Ammonia	BS EN ISO 21877:2019	ECL / TPD / 034
Sulphur Dioxide	BS EN 14791:2017	ECL / TPD / 039
Hydrogen Chloride.	BS EN 1911:2010	ECL / TPD / 081
Hydrogen Fluoride	PD CEN/TS 17340:2020	ECL / TPD / 081
Moisture	BS EN 14790: 2017	ECL / TPD / 082
Nitrous Oxide (N ₂ O) (FTIR 204M)	PD CEN/TS 17337:2019	ECL / TPD / 097
Oxygen (Protea 204M)	BS EN 14789: 2017	ECL / TPD / 097

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

5 SAMPLE POINT DESCRIPTIONS

The homogeneity test is applicable to combustion processes, but may also be requested by the regulator for non-combustion processes.

Homogeneity testing has not been completed at this location.

The test is not usually required for stacks with sampling plane areas of $<1\text{m}^2$ (below 1.13m in diameter for circular ducts).

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

The sample location that was monitored is detailed below:

Biomass Plant – Main Stack

The stack diameter is 1.60m and the sample platform width back from the sample ports is 3.0m.

Two sample ports are located on the stack at 90 degrees to each other and are located on the same plane.

These sample ports are located at a height of approximately 0.7m from the working sample platform.

Sampling for Particulates was carried out using an out-of-stack filter system.

Access to the sample platform was attained by means of hooped ladder accessed on the outside of the chimney.

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

**EQUIPMENT IDs
(Pre site checklist from SSP)**

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

PRE SITE EQUIPMENT CHECKLIST/ EQUIPMENT USED

(Completed before departure to site and when on site in full)

Equipment	Equip. Type	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:	ID No:
MST console/pump	E001	U010							
MST Nozzle set		335							
MST “S” Type Pitot		668							
MST Probe		149							
MST Hot Box		192							
MST Impinger Arm		337							
Barometer		352							
Site Balance		1222							
Site Check weights		1223							
		1224							
Horiba	E002	969							
Heated Probe / Filter		1191							
Chiller		1192							
MFC									
Heated Line		1186	1187						
FID	E003	211							
Heated Line		1090	1091						
Heated Probe / Filter		922							
Testo	E004								
FTIR	E005	566							
Heated Probe / Filter		1191							
Heated Line		1186	1187						
Stackmite	E006								
“L” Type Pitot									
Digital Manometer									
Stack Thermocouple		461							
Thermocouple Reader									
Nozzle Set									
Workhorse Pumps	E007								
Stack Thermocouple									
Tube Thermocouple									
Meter Thermocouple									
High Vac Gauge									
Dioxin Thermocouple		789							

Quantity of Ice Required / Used for Survey	18	Bags (2kg bags)
--	----	-----------------

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

FIGURES

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Figure 1 – TVOC






Figure 2 – NO_x & CO



Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

Figure 3 – N2O



Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

TABLES

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 1 – TVOC

Data Recorded from Biomass Plant (Main Stack)

Sample Period: 13:00 – 14:00 on the 5th January 2023

Volumetric Flowrate (Reference Conditions) = 23.61437 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
TVOC (as carbon)*	2.72	0.2312

* Reference Conditions (273K, 101.3 kPa, 6% Oxygen & Dry Gas)

Table 2 – Nitrous Oxide

Data Recorded from Biomass Plant (Main Stack)

Sample Period: 14:00 – 15:00 on the 9th January 2023

Volumetric Flowrate (Reference Conditions) = 23.61437 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
Nitrous Oxide (N ₂ O)	0.53	0.0451

* Reference Conditions (273K, 101.3 kPa, 6% Oxygen & Dry Gas)

Table 3– Combustion Gases

Data Recorded from Biomass Plant (Main Stack)

Sample Period: 14:00 – 15:00 on the 5th January 2023

Volumetric Flowrate (Reference Conditions) = 23.61437 m³/sec *

	Average	Emission Rate
	mg/m ³	Kg/hr
Oxides of Nitrogen (as NO ₂) *	178.73	15.1941
Carbon Monoxide *	119.10	10.1249
Oxygen (%)	6.81	...

* Reference Conditions (273K, 101.3 kPa, 6% Oxygen & Dry Gas)

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 4 – Particulates & Hydrogen Chloride & Fluoride

Data Recorded from Main Stack - Biomass Plant

Emission Parameter	Units	TPM, HCl & HF	Blank
Stack Diameter	metres	1.60	...
Area of Sample Plane	m ²	2.011	...
Moisture Content	%	23.01	...
Oxygen Content	%	6.78	...
Stack Temperature	°C	141	...
Gas Velocity (as Measured. Adjusted for Smooth Walls)	m/sec	23.9286	...
Gas Velocity (Reference Conditions)	m/sec*	11.5894	...
Volumetric Flowrate (as Measured)	m ³ /sec	48.1114	...
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	23.3018	...
Dry Gas Molecular Weight	g/gmole	30.4393	
Sample Date	...	05/01/2023	...
Sample Period	...	11:50 - 12:52	...
Sample Volume (reference Conditions)	m ³ *	0.980	0.980
Isokinetic Sampling Rate	%	114.77	...
Sample Reference (ECL ID)	ECL/23/	0052 & 0053	0054 & 0055
Mass of Particulate Matter Collected	mg	1.12	0.60
Concentration of Particulate Matter	mg/m ³ *	1.14	0.61
Emission Rate of Particulate Matter	g/hr	95.91	...
Expanded Uncertainty (% Relative)	%	46	...
Emission Limit Value (ELV)	mg/m ³ *	15	...
Blank Concentration as Percentage of ELV	%	...	4.08
Sample Reference (ECL ID)	ECL/23/	0058 & 0059	0060
Mass of Hydrogen Chloride Collected	mg	23.53	0.02
Concentration of Hydrogen Chloride	mg/m ³ *	24.02	0.02
Emission Rate of Hydrogen Chloride	g/hr	2014.68	...
Expanded Uncertainty (% Relative)	%	14	...
Impinger Collection Efficiency	%	100	...
Sample Reference	ECL/23/	0058 & 0059	0060
Mass of Hydrogen Fluoride Collected	mg	0.05	0.02
Concentration of Hydrogen Fluoride	mg/m ³ *	0.05	0.02
Emission Rate of Hydrogen Fluoride	g/hr	4.43	...
Expanded Uncertainty (% Relative)	%	14	...
Impinger Collection Efficiency	%	68	...

*Reference Conditions (273K, 101.3kPa, 6% Oxygen, Dry Gas)

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 5 – Ammonia

Data Recorded from Main Stack - Biomass Plant

Emission Parameter	Units	Ammonia	Blank
Stack Diameter	metres	1.60	
Area of Sample Plane	m ²	2.011	
Moisture Content	%	24.35	
Oxygen Content	%	7.01	
Stack Temperature	°C	140	
Gas Velocity (as Measured)	m/sec	24.29	
Gas Velocity (Reference Conditions)	m/sec*	11.38	
Volumetric Flowrate (as Measured)	m ³ /sec	48.85	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	22.87	
Dry Gas Molecular Weight	g/gmole	30.44840953	
Sample Date	...	05/01/2023	
Sample Period	...	13:30 - 14:30	
Sample Volume (reference Conditions)	m ³ *	0.770	0.770
Sample Reference (ECL ID)	ECL/23/	0062 & 0063	0064
Mass of Ammonia Collected	mg	6.21	0.05
Concentration of Ammonia	mg/m ³ *	8.06	0.06
Emission Rate of Ammonia	kg/hr	0.66	...
Expanded Uncertainty (% Relative)	%	14	...
Emission Limit Value (ELV)	mg/m ³ *	10	...
Impinger Collection Efficiency	%	99	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

*Reference Conditions (273K, 101.3kPa, 6% Oxygen, Dry Gas)

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 6 – Sulphur Dioxide

Data Recorded from Main Stack - Biomass Plant

Emission Parameter	Units	Sulphur Dioxide	Blank
Stack Diameter	metres	1.60	
Area of Sample Plane	m ²	2.011	
Moisture Content	%	21.84	
Oxygen Content	%	6.55	
Stack Temperature	°C	140	
Gas Velocity (as Measured)	m/sec	24.29	
Gas Velocity (Reference Conditions)	m/sec*	12.10	
Volumetric Flowrate (as Measured)	m ³ /sec	48.85	
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	24.33	
Dry Gas Molecular Weight	g/gmole	30.42995243	
Sample Date	...	06/01/2023	
Sample Period	...	08:30 - 12:30	
Sample Volume (reference Conditions)	m ³ *	3.333	3.333
Sample Reference	ECL/23/	0066 & 0067	0068
Mass of Sulphur Dioxide Collected	mg	66.87	0.07
Concentration of Sulphur Dioxide	mg/m ³ *	20.06	0.02
Emission Rate of Sulphur Dioxide	kg/hr	1.76	...
Expanded Uncertainty (% Relative)	%	14	...
Impinger Collection Efficiency	%	100	...

*Reference Conditions (273K, 101.3kPa, 6% Oxygen, Dry Gas)

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 7 – Dioxins & Furans

Data Recorded from Biomass Plant - Stack Main Stack

Emission Parameter	Units	Chlorinated D & F		
Stack Diameter	metres	1.6		
-	-	-		
Area of sample plane	m ²	2.011		
Moisture Content	%	22.60		
Moisture Expanded Uncertainty	%(Relative)	5.23		
Stack Temperature	°C	132		
Oxygen Concentration	%	8.17		
Gas velocity (as Measured)	m/sec	21.7532		
Gas velocity (Reference Conditions)	m/sec*	9.6454		
Volumetric Flowrate (as Measured)	m ³ /sec	43.7375		
Volumetric Flowrate (Reference)	m ³ /sec*	19.3933		
Sample Date				
09/01/2023				
Sample Period				
10:35 - 16:40				
Sample Reference				
ECL/23/0046 - 0048				
Sample Volume (Reference Conditions)	m ³ *	4.59		
Isokinetic Sampling Rate	%	107.73		
Species	Sample Reference: ECL/23/0046 - 0048		Blank Reference: ECL/23/0049 - 0051	
	Conc. ng/m ³ *	TEQ ng/m ³ *	Conc. ng/m ³ *	TEQ ng/m ³ *
Chlorinated Dioxins 2,3,7,8 Isomers	0.032	0.0012	0.0053	0.00014
Total Chlorinated Dioxins Non – Targeted Isomers	0.00	...	0.00	...
Chlorinated Furans 2,3,7,8 Isomers	0.013	0.0013	0.0040	0.00033
Total Chlorinated Furans Non – Targeted Isomers	0.00	...	0.00	...
TOTAL	...	0.0025	...	0.00046
Range	...	0.0023 - 0.0025	Blank <10% of ELV?	YES
% Uncertainty	...	13		

*Reference Conditions 273K, 101.3kPa, 6% Oxygen, Dry Gas. NB: For each congener, where the blank concentration exceeds or equals the measured concentration, the blank value has been substituted. Refer to the table of individual congeners for more detailed information.

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 7b – Dioxins & Furans

Data Recorded from Biomass Plant - Stack Main Stack on the 09/01/23, 10:35 - 16:40

Species	Blank Reference: ECL/23/0049 - 0051 TEQ ng/m ³ *	EEC Toxic Equivalent Factor (TEF)	Sample Ref.: ECL/23/0046 - 0048		WHO Humans & Mammals (TEF)	Humans & Mammals TEQ ng/m ³ *	WHO Fish (TEF)	Fish TEQ ng/m ³ *	WHO Birds (TEF)	Birds TEQ ng/m ³ *
			Concentration ng/m ³ *	TEQ ng/m ³ *						
Chlorinated Dioxins - 2,3,7,8 Isomers										
2,3,7,8 - TCDD	0.000031	1	<i>0.00011</i>	<i>0.00011</i>	1	<i>0.00011</i>	1	<i>0.00011</i>	1	<i>0.00011</i>
1,2,3,7,8 - PCDD	0.000048	0.5	0.00084	0.00042	1	0.00084	1	0.00084	1	0.00084
1,2,3,4,7,8 - HxCDD	0.000006	0.1	0.0012	0.00012	0.1	0.00012	0.5	0.00061	0.05	0.000061
1,2,3,6,7,8 - HxCDD	0.000020	0.1	0.0026	0.00026	0.1	0.00026	0.01	0.000026	0.01	0.000026
1,2,3,7,8,9 - HxCDD	0.000016	0.1	0.0015	0.00015	0.1	0.00015	0.01	0.000015	0.1	0.00015
1,2,3,4,6,7,8 - HpCDD	0.000014	0.01	0.012	0.00012	0.01	0.00012	0.001	0.000012	0.001	0.000012
OCDD	0.000003	0.001	0.013	0.000013	0.0001	0.000001	0	...	0	...
Total Chlorinated Dioxins - Non - Targeted Isomers										
TCDD	...	0	0.000000	...	0	...	0	...	0	...
PCDD	...	0	0.000000	...	0	...	0	...	0	...
HxCDD	...	0	0.000000	...	0	...	0	...	0	...
HpCDD	...	0	0.000000	...	0	...	0	...	0	...
Chlorinated Furans - 2,3,7,8 Isomers										
2,3,7,8 - TCDF	0.000019	0.1	0.0022	0.00022	0.1	0.00022	0.05	0.00011	1	0.0022
1,2,3,7,8 - PCDF	0.000015	0.05	0.00090	0.000045	0.05	0.000045	0.05	0.000045	0.1	0.000090
2,3,4,7,8 - PCDF	0.00017	0.5	0.0012	0.00061	0.5	0.00061	0.5	0.00061	1	0.0012
1,2,3,4,7,8 - HxCDF	0.000005	0.1	0.0010	0.00010	0.1	0.00010	0.1	0.00010	0.1	0.00010
1,2,3,6,7,8 - HxCDF	0.000046	0.1	0.0012	0.00012	0.1	0.00012	0.1	0.00012	0.1	0.00012
2,3,4,6,7,8 - HxCDF	0.000055	0.1	0.0011	0.00011	0.1	0.00011	0.1	0.00011	0.1	0.00011
1,2,3,7,8,9 - HxCDF	0.000004	0.1	<i>0.000078</i>	<i>0.000008</i>	0.1	<i>0.000008</i>	0.1	<i>0.000008</i>	0.1	<i>0.000008</i>
1,2,3,4,6,7,8 - HpCDF	0.000015	0.01	0.0038	0.000038	0.01	0.000038	0.01	0.000038	0.01	0.000038
1,2,3,4,7,8,9 - HpCDF	0.000002	0.01	0.00047	0.000005	0.01	0.000005	0.01	0.000005	0.01	0.000005
OCDF	0.000000	0.001	0.0010	0.000001	0.0001	0.000000	0.0001	0.000000	0.0001	0.000000
Total Chlorinated Furans - Non - Targeted Isomers										
TCDF	...	0	0.000000	...	0	...	0	...	0	...
PCDF	...	0	0.000000	...	0	...	0	...	0	...
HxCDF	...	0	0.000000	...	0	...	0	...	0	...
HpCDF	...	0	0.000000	...	0	...	0	...	0	...
TOTAL	0.00046	0.0025	...	0.0029	...	0.0028	...	0.0051
Range	0.0023 - 0.0025	...	0.0027 - 0.0029	...	0.0026 - 0.0028	...	0.005 - 0.0051
% Uncertainty	13	...	17	...	18	...	18

*Reference Conditions 273K, 101.3kPa, 6% Oxygen, Dry Gas. NB: For each congener, where the blank concentration exceeds or equals the measured concentration, the blank value has been substituted. This is presented as shaded cells. Where the Limit of Detection applies, concentrations are presented in italics.

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 8 – Heavy Metals

Sampling Location: Biomass Plant Main Stack

Test Heavy Metals												
Stack Profile:	Circular	Units	Gas velocity (as Measured. Adjusted for Smooth Walls):					24.0213	m/sec			
Diameter:	1.60	m	Gas velocity (Reference Conditions):					11.8048	m/sec *			
			Volumetric Flowrate (as Measured):					48.2977	m ³ /sec			
Area of sample plane:	2.011	m ²	Volumetric Flowrate (Reference Conditions):					23.7350	m ³ /sec *			
Moisture Content:	22.58	%	Sample Date:					05/01/2023				
Stack Temperature:	141	°C	Sample Period:					15:00 - 16:02				
Barometric Pressure:	1018	mbar	Sample Volume:					0.953	m ³			
Measured Oxygen:	6.66	%	Isokinetic Rate (95% < ISOKx > 115%):					109.64	%			
*Reference Conditions: (273K, 101.3kPa, 6% Oxygen, Dry Gas)												
Trace Element	Symbol	Mass (mg)			ECL/23/0 - 0			Emission Rate (g/hr)*	Uncertainty (%)	ECL/23/0 - 0		
		Particulate Phase	Vapour Phase	Total Element Phase	Concentration (mg/m ³)*					Total Element Phase	Blank	
					Particulate Phase	Vapour Phase	Total Element Phase				Mass (mg)	Conc. (mg/m ³)
Antimony	Sb	0.013	0.0013	0.014	0.013	0.0014	0.015	1.25	14	0.00069	0.00072	
Arsenic	As	0.0021	0.0047	0.0068	0.0022	0.0050	0.0072	0.61	10	0.00063	0.00066	
Cadmium	Cd	0.00050	0.00019	0.00069	0.00052	0.00020	0.00072	0.062	10	0.00059	0.00062	
Chromium	Cr	0.012	0.011	0.023	0.012	0.012	0.024	2.08	9	0.0046	0.0048	
Cobalt	Co	0.00050	0.00019	0.00069	0.00052	0.00020	0.00072	0.062	10	0.00059	0.00062	
Copper	Cu	0.0022	0.011	0.014	0.0023	0.012	0.014	1.23	10	0.00077	0.00081	
Lead	Pb	0.0033	0.0062	0.0095	0.0035	0.0065	0.010	0.86	12	0.00069	0.00072	
Manganese	Mn	0.0058	0.0010	0.0068	0.0061	0.0011	0.0072	0.61	14	0.0015	0.0016	
Nickel	Ni	0.017	0.0013	0.018	0.018	0.0013	0.019	1.63	12	0.0056	0.0059	
Thallium	Tl	0.00040	0.00019	0.00059	0.00042	0.00020	0.00062	0.053	12	0.00049	0.00051	
Vanadium	V	0.0014	0.000094	0.0015	0.0015	0.000099	0.0016	0.13	12	0.00044	0.00047	
Cadmium & Thallium		0.00090	0.00038	0.0013	0.00094	0.00040	0.0013	0.11	5	0.0011	0.0011	
Antimony, Arsenic, Chromium, Cobalt, Copper, Lead, Manganese, Nickel & Vanadium		0.057	0.038	0.094	0.060	0.040	0.099	8.46	3	0.016	0.016	

Efficiency Failure

No ELV Entered!

No ELV Entered!

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties (in mg/m³) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 8b – Heavy Metals Efficiencies

Metals groups have been selected. Efficiencies will only be displayed for individual elements if the group total concentration is greater than 30% of the associated ELV.				
Recovery in the final impinger must be <10% of the total combined element mass (i.e. filter, probe rinse & impingers) to pass - ONLY if the element makes up >1% of the total mass of all metals collected				
Trace Element	Symbol	Final Impinger (%)	<10%?	<1% of Total?
Antimony	Sb	0.48	PASS	NO
Arsenic	As	1.45	PASS	NO
Cadmium	Cd	9.59	PASS	NO
Chromium	Cr	0.28	PASS	NO
Cobalt	Co	9.59	N/A	YES
Copper	Cu	0.96	PASS	NO
Lead	Pb	0.69	PASS	NO
Manganese	Mn	0.96	PASS	NO
Nickel	Ni	0.55	PASS	NO
Thallium	Tl	11.22	FAIL	NO
Vanadium	V	2.21	PASS	NO

Combined Groups	ELV mg/m ³	Result <30% ELV?
Cadmium & Thallium	0	NO
Antimony, Arsenic, Chromium, Cobalt, Copper, Lead, Manganese, Nickel & Vanadium	0	NO

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 9 – Mercury

Sampling Location: Biomass Plant Main Stack

Test Mercury											
Stack Profile:	Circular	Units	Gas velocity (as Measured. Adjusted for Smooth Walls):					24.1513	m/sec		
Diameter:	1.60	m	Gas velocity (Reference Conditions):					11.7466	m/sec *		
			Volumetric Flowrate (as Measured):					48.5590	m ³ /sec		
Area of sample plane:	2.011	m ²	Volumetric Flowrate (Reference Conditions):					23.6180	m ³ /sec *		
Moisture Content:	23.65	%	Sample Date:					06/01/2023			
Stack Temperature:	140	°C	Sample Period:					13:10 - 14:12			
Barometric Pressure:	1014	mbar	Sample Volume:					0.903	m ³		
Measured Oxygen:	6.60	%	Isokinetic Rate (95% < ISOKx > 115%):					104.40	%		
*Reference Conditions: (273K, 101.3kPa, 6% Oxygen, Dry Gas)											
Trace Element	Symbol	Mass (mg)			ECL/23/0 - 0			Emission Rate (g/hr)*	Uncertainty (%)	ECL/23/0 - 0	
					Concentration (mg/m ³)*					Blank	
		Particulate Phase	Vapour Phase	Total Element Phase	Particulate Phase	Vapour Phase	Total Element Phase			Total Element Phase	Mass (mg)
Mercury	Hg	0.00011	0.00029	0.00040	0.00012	0.00032	0.00044	0.037	10	0.00029	0.00032

No ELV Entered!

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Table 9b – Mercury Efficiencies

Groups have been selected. Efficiencies will only be displayed for mercury if the concentration is greater than 30% of the associated ELV.				
Recovery in the final impinger must be <5% of the total combined element mass in both impingers to pass - ONLY if the final impinger has a concentration greater than 2µg/m ³				
Trace Element	Symbol	Final Impinger (%)	<5%?	Final Impinger <2 µg/m ³ ?
Mercury	Hg	N/A	N/A	YES

Combined Groups	ELV mg/m ³	Result <30% ELV?
Mercury	0	NO

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

VELOCITY TRAVERSE PROFILES

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP399GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Environmental Compliance Limited	Traverse Data Profoma	Date of Measurement	05/01/2023
----------------------------------	-----------------------	---------------------	------------

Company	Western Bio-Energy Limited	Stack Diameter Port A (mm)	1600	Average Stack Diameter (mm)	1600	Pitot tube coefficient	0.84
Site	Margam	Stack Diameter Port B (mm)	1600	Port Length (mm)	210	Pitot Id	668
Location	Biomass Plant	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	461
Stack	Main Stack	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	987
Job No	P5200	Duct Length Port C (mm)		Barometric Pressure. (mb)	1018	Manometer ID	989
Operators	PB, DB & LPH	Duct Length Port D (mm)		Ave Static Press. (mm H ₂ O)	16.90	Barometer ID	352

Pre - Traverse Checks Carried Out	Time	Pass/ Fail
Pre - Traverse PITOT Visual Inspection	09:32:00	Pass
Pre - Traverse PITOT Leak Check	09:34:00	Pass

Smooth Walls

Static Pressure Readings (mm H ₂ O)			
Port A	Port B	Port C	Port D
16.80	17.00		

Port/ Point	Distance to Point (mm)	Time	Temperature Readings (°C)			(ΔP) Pitot Readings (mm H ₂ O)			Average Temp. (°C)	Average (ΔP) (mm H ₂ O)	Swirl Test ° From Reference
			1	2	3	1	2	3			
A1	70	09:37:00	142.0	142.0	142.0	40.00	40.00	38.00	142.0	39.33	10
A2	234	09:39:00	142.0	142.0	141.0	38.00	38.00	38.00	141.7	38.00	10
A3	473	09:41:00	141.0	141.0	141.0	36.00	38.00	36.00	141.0	36.67	10
A4	1127	09:43:00	141.0	140.0	141.0	36.00	36.00	36.00	140.7	36.00	10
A5	1366	09:45:00	141.0	141.0	142.0	34.00	34.00	32.00	141.3	33.33	10
A6	1530	09:47:00	142.0	142.0	142.0	32.00	32.00	32.00	142.0	32.00	10
B1	70	09:50:00	140.0	140.0	140.0	38.00	38.00	38.00	140.0	38.00	10
B2	234	09:52:00	141.0	141.0	141.0	38.00	38.00	38.00	141.0	38.00	10
B3	473	09:54:00	141.0	141.0	141.0	36.00	36.00	34.00	141.0	35.33	10
B4	1127	09:56:00	140.0	139.0	139.0	34.00	36.00	34.00	139.3	34.67	10
B5	1366	09:58:00	139.0	139.0	140.0	32.00	32.00	32.00	139.3	32.00	10
B6	1530	10:00:00	140.0	141.0	141.0	30.00	30.00	30.00	140.7	30.00	10
Blockage Check @ A1 (L-Type Pitot Only)									1690.0	423.3	Total
Mean									142.0	39.3	Max
Difference <5% from Initial ?									139.3	30.0	Min
									140.8	35.3	Average

Stagnation Check (S-type Pitot Only)	Time	Reading
Static Pressure Via Positive Leg (mm H ₂ O)	10:03:00	17.00
Static Pressure Via Negative Leg (mm H ₂ O)	10:05:00	16.80
Difference (Pa) < 1 mm H ₂ O ?		-0.20


Average temp (K)	413.833
--------------------	---------

Suitability of Sampling Position	Actual Stack Conditions
Highest:lowest flow pressure ratio < 9:1?	1.33:1
Maximum deviation of flow from axis <15°?	10
X-sectional area for stacks= πr ²	2.01 m ²
X-sectional area for ducts = L x B	m ²
Suitability of Position for Sampling	OK

Post - Traverse Checks Carried Out	Time	Pass/ Fail
Post - Traverse PITOT Visual Inspection	10:07:00	Pass
Post - Traverse PITOT Leak Check	10:09:00	Pass

Stack Moisture	23.01	%	Gas Velocity (as Measured) Adjusted for Smooth Walls	24.29438	m/sec
Measured Oxygen	6.81	%	Gas Velocity (Reference Conditions) Adjusted for Smooth Walls	11.74482	m/sec*
Measured Carbon Dioxide	13.55	%	Volumetric Flowrate (as Measured) Adjusted for Smooth Walls	48.84675	m ³ /sec
Dry Gas Molecular Weight	30.44040	g/g mole	Volumetric Flowrate (Ref Cond) Adjusted for Smooth Walls	23.61437	m ³ /sec*

Diagram/ Description of Cross Section of Stack/Duct



Notes
 Including expected or actual deviations from procedures / non-conformities

Compliance With Positional Requirements?	
Height of sample ports from Platform	0.70m
Number of sample ports	2
Width of platform (port back to handrail)	3.0m

Nearest downstream disturbance	Exit	15m
Nearest upstream disturbance	Bend	>5m
Disturbances are classed as bends, fans or diameter variations		

*Reference Conditions: 273K, 101.3kPa, 6% Oxygen, Dry Gas NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl >15°

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

FIELD CALIBRATION AND SAMPLING DATA

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

TVOC Calibration Site Log

TVOC - FIELD DATA SHEET

Client	Western Bio-Energy Ltd			Barometric Pressure mb	1018	
Site	Margam			Barometer ID	ECL/ID/ 352	
Date	05/01/2023			Analyser ID	ECL/ID/ 211	
Location	Biomass Plant			Sonimix/ MFC ID	ECL/ID/ N/A	
Stack ID	Main Stack			Heated Line/ Controller ID	ECL/ID/1090 1091	
Stack Temp °C	140			Heated Line Set Temp °C	180	YES
Ambient Temp (sampling)	1= 11	2= 12	3= 12	Heated Line Length	20	m
Ambient Temp (sampling)	4=	5=	6=	Heated Probe Filter ID	ECL/ID/ 1190	
Job No	P5200			Heated Filter Set Temp °C	180	YES
Operators	DB/ PB / LPH			Logger ID	922	

Calibration Gas Details

Calibration Gas	Gas Bottle ID	Gas Value	Uncertainty of Gas (k=2)	Analysers Range	Span Gas value used
Zero Gas (Synthetic Air)	Gas/ 2806	Propane	40ppm 30.11 ppm
Hydrogen / Helium	Gas/ 2761		
Propane (In Air)	Gas/ 2687	30.11ppm	0.3ppm		

Analysers Range should be not less than the expected peak emissions.

Span Gas Values should be either *approximately the half-hourly ELV* **OR** *50% to 90% of the Selected Analyser Range.*

	Direct Calibration (Rear of Analyser)					
	Zero Cal		Span Gas Cal		Zero Check	
	Start Time	End Time	Start Time	End Time	Start Time	End Time
ZERO /SPAN/ ZERO	12:09	12:12	12:14	12:17	12:19	12:22

NOTE: RESPONSE TIME

Response Time to be carried out at the same time as "Span Check" on system verification (via the sample probe)
 Start Time = when gas turned on. 90% Time = when analyser displays 90% of span gas value used. Response must be within 200 seconds.

Pre-Cal Ambient Temp °C		PRE <u>System</u> Verification Check (Down Line)				Response Time		
Max	Min	Zero Check		Span Check		SYSTEM Span Gas Cal		
		Start Time	End Time	Start Time	End Time	Start Time	90% Time	less than 200s (Y/N)
11	11	12:28	12:31	12:33	12:36	12:32:15	12:32:30	Y

	Start Time	End Time	Location	Production Details
Sample Period	12:45	14:15	Main Stack	Normal
Sample Period				
Sample Period				
Sample Period				
Sample Period				

Post-Cal Ambient Temp °C		POST <u>System</u> Verification Check (Down Line)			
Max	Min	Zero Check		Span Check	
		Start Time	End Time	Start Time	End Time
12	12	14:19	14:22	14:24	14:26

Process Details / Comments

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

TVOC Calibration Summary – 05/01/2023

		TVOC ppm
Analyser Range		40
Repeatability at Zero		0.8
Span Gas Concentration Applied		30.11
Zero Gas Concentration Applied		0
Direct Cal	Zero	0.00
	Span	30.1
	Zero	-0.01
Difference (Zero)		0.0051
<2×Repeatability @ Zero?		YES
Pre Test (System)	Zero	0.03
	Span	30.1
Difference (Zero)		0.0339
<2% Relative to Direct Span		YES
Difference (Span)		0.0166
<2% Relative to Direct Span		YES
Post Test (System)	Zero	0.15
	Span	30.4
Difference (Zero)		0.1190
Zero Drift <2% of Applied Span?		YES
Difference (Span)		0.3169
Span Drift <2% of Applied Span?		YES
Zero and Span Drift <5% of Applied Span?		YES

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Horiba Calibration Summary – 05/01/2023 (NO_x, CO & O₂)

Units

Mean Initial Direct Zero
 Mean Confirmation Direct Zero
 Difference in Direct Zero
 Repeatability at Zero
 <2 x Repeatability at Zero?

Mean Pre Test Zero
 % of Measurement Range?
 Detection Limit (LOD)

Actual Applied Span Concentration

Mean Pre Test System Zero
 Difference $\leq \pm 2\%$ of Span Value?

Mean Post Test Direct Zero
 % of Certified Range?
 Zero Drift $\leq \pm 5\%$ of Applied Span?

Mean Pre Test System Span
 Difference $\leq \pm 2\%$ of Span Value ?

Mean Post Test Direct Span
 Span Drift $\leq \pm 5\%$ Span Value?

Horiba PG 350 E Ranges:		
NO as NO ₂	CO	O ₂
512.5	625	25
mg/m ³	mg/m ³	%Vol
Zero Values (Direct)		
0.17	-0.01	-0.02
0.22	0.33	-0.03
0.05	0.34	0.01
4.10	2.50	0.20
YES	YES	YES
Pre Zero Values (System)		
0.47	0.23	0.03
0.09%	0.04%	0.12%
0.38	0.12	0.20
Applied Span:		
NO	CO	O ₂
317.96	382.63	14.99
Pre Test System Zero Values		
0.47	0.23	0.03
0.15%	0.06%	0.20%
Post Test Direct Zero Values		
0.17	0.42	-0.03
0.03%	0.07%	-0.12%
0.00%	0.11%	0.05%
Pre Test System Span Values		
315.10	381.57	15.00
0.90%	0.28%	0.07%
Post Test Direct Span Values		
316.79	383.20	15.04
0.37%	0.15%	0.34%

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

FTIR Calibration Summary – 09/01/2023 (N₂O & O₂)

4M FTIR Certified		
	N₂O	O₂
Upper Limit of Certified Range	39	20.9
Units	mg/m ³	% Vol
Pre System Zero Value		
Mean Pre Test System Zero	0.04	0.02
% of Certified Range? (Maximum Allowed 2%)	0.10%	0.11%
Pre Direct Zero Value		
Mean Pre Test Direct Zero	-0.05	0.00
% of Certified Range? (Maximum Allowed 2%)	-0.12%	0.00%
Detection Limit (LOD)	0.10	0.20
LOD as % of Range (Maximum Allowed 2%)	0.25	0.96
Post System Zero Value		
Mean Post Test System Zero	-0.05	0.00
% of Certified Range?	-0.14%	-0.01%
Zero Drift ≤ ± 5% of Applied Span?	0.01%	0.01%
Applied Span:		
	N₂O	O₂
Actual Applied Span Concentration	36.65	14.99
Direct Span Values		
Mean Span Direct to Analyser	36.48	14.99
Deviation ≤ ± 5% Applied Concentration?	0.47%	0.00%
Pre System Span Value		
Mean Pre Test System Span	36.46	15.08
Losses Due to Sampling System ≤ 2% ?	0.04%	0.61%
Post System Span Value		
Mean Post Test System Span	36.37	15.04
Span Drift ≤ ± 5% Pre Span?	0.24%	0.35%

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Oxygen Calibration Summary

06/01/2023

Units

Mean Initial Direct Zero
 Mean Confirmation Direct Zero
 Difference in Direct Zero
 Repeatability at Zero
 <2 x Repeatability at Zero?

Mean Pre Test Zero
 % of Measurement Range?
 Detection Limit (LOD)

Actual Applied Span Concentration

Mean Pre Test System Zero
 Difference $\leq \pm 2\%$ of Span Value?

Mean Post Test Direct Zero
 % of Certified Range?
 Zero Drift $\leq \pm 5\%$ of Applied Span?

Mean Pre Test System Span
 Difference $\leq \pm 2\%$ of Span Value ?

Mean Post Test Direct Span
 Span Drift $\leq \pm 5\%$ Span Value?

Horiba PG 350 E Ranges:	
O₂	
25	
%Vol	
Zero Values (Direct)	
	-0.02
	-0.03
	0.01
	0.20
	YES
Pre Zero Values (System)	
	0.03
	0.12%
	0.20
Applied Span:	
O₂	
14.99	
Pre Test System Zero Values	
	0.03
	0.20%
Post Test Direct Zero Values	
	-0.12
	-0.48%
	0.65%
Pre Test System Span Values	
	15.00
	0.07%
Post Test Direct Span Values	
	14.98
	0.05%

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Particulates & Hydrogen Chloride & Fluoride

Environmental Compliance Limited		PARTICULATE DATA SAMPLING PROFORMA				Date of Measurement		05/01/2023		Rinse Solutions used											
ECL/TPD/ 027 & 081		Time taken to change Ports? 2				Start Time		11:50		End Time		12:52									
Client		Western Bio-Energy Limited		Stack Profile		Circular		Console id		U010		Barometer id		352							
Site		Margam		Stack Area (m ²)		2.01		Pump id		U010		Nozzle id		335							
Location		Biomass Plant		Barometric Pressure (mb)		1018		Probe id		149		Nozzle size		5.09							
Stack ID		Main Stack		Static Pres. (mm H ₂ O)		16.9		DGM Yd		0.9979		Filter Id		249657 4043							
Test No.		TPW, HCl & HF		Pilot coefficient		0.84		AHE		47.22		Pilot ID		668							
Job No.		P5200		Probe Heater Setting (°C)		150		Impinger Id		192		Hot Box ID		182							
ECL Site Staff		PB, DB & LPH		Hot Box Setting (°C)		160		Balance Id		1222											
IF SAMPLING FOR PARTICULATES NO LEAK CHECKS ARE ALLOWED AFTER SAMPLING HAS STARTED (NOT EVEN IF TRAIN IS BROKEN DOWN) OR OTHER SAMPLING (WITHOUT PARTICULATES) LEAK CHECKS ARE ALLOWED AFTER SAMPLING HAS STARTED (BUT ARE NOT MANDATORY)												Silica <50% Spent at End of Test?		YES							
Start Volume		2712243.0		Leak 1		Leak 2		Leak 3		Leak 4		Leak 5		Total							
Final Volume		2713346.8		0.0		0.0		0.0		0.0		0.0		1103.8							
Total Volume		1103.8																			
Leak Check		First		Second		Third		Fourth		Fifth											
Leak rate U/min		0.2																			
Vacuum *Hg		11																			
Time of Check		11:48																			
Set Rate U/min		20																			
Leak <2%?		YES																			
Smooth Walls														Dry O ₂ ([Atmospheric)		6.78		K factor		0.9	
														Dry Carbon Dioxide %		13.55		Reference Oxygen Percentage		6	
Traverse Point		A1		A2		A3		A4		A5		A6		B1		B2		Total			
Time/Point (mins)		0 - 5		5 - 10		10 - 15		15 - 20		20 - 25		25 - 30		30 - 35		35 - 40					
AP (mm H2O)		36.00		34.00		34.00		32.00		32.00		30.00		38.00		38.00		34.25			
K factor		0.90		0.90		0.90		0.90		0.90		0.90		0.90		0.90					
ΔH (Orifice)		32.40		30.60		30.60		28.80		27.00		34.20		34.20		30.60		30.83			
Meter (Tm in)		18.00		19.00		19.00		19.00		20.00		20.00		21.00		21.00		19.50			
Meter (Tm out)		18.00		19.00		19.00		19.00		20.00		20.00		20.00		21.00		19.50			
Stack Temp (Ts)		142.00		143.00		141.00		140.00		141.00		142.00		142.00		140.00		141.38			
Impinger T Outlet		7.00		7.00		7.00		8.00		8.00		8.00		9.00		9.00		7.89			
Vacuum (* Hg)		10.00		10.00		10.00		10.00		10.00		10.00		10.00		10.00		10.00			
Traverse Point		B3		B4		B5		B6										Total			
Time/Point(mins)		40 - 45		45 - 50		50 - 55		55 - 60										34.00			
AP (mm H2O)		36.00		34.00		34.00		32.00										34.00			
K factor		0.90		0.90		0.90		0.90													
ΔH (Orifice)		32.40		30.60		30.60		28.80										30.60			
Meter (Tm in)		21.00		21.00		22.00		22.00										21.50			
Meter (Tm out)		21.00		21.00		22.00		22.00										21.50			
Stack Temp (Ts)		140.00		139.00		139.00		140.00										139.50			
Impinger T Outlet		10.00		10.00		11.00		11.00										10.50			
Vacuum (* Hg)		10.00		10.00		10.00		10.00										10.00			
Traverse Point																		Total			
Time/Point(mins)																					
AP (mm H2O)																					
K factor																					
ΔH (Orifice)																					
Meter (Tm in)																					
Meter (Tm out)																					
Stack Temp (Ts)																					
Impinger T Outlet																					
Vacuum (* Hg)																					
Traverse Point																		Total			
Time/Point(mins)																					
AP (mm H2O)																					
K factor																					
ΔH (Orifice)																					
Meter (Tm in)																					
Meter (Tm out)																					
Stack Temp (Ts)																					
Impinger T Outlet																					
Vacuum (* Hg)																					
Traverse Point																		Total			
Time/Point(mins)																					
AP (mm H2O)																					
K factor																					
ΔH (Orifice)																					
Meter (Tm in)																					
Meter (Tm out)																					
Stack Temp (Ts)																					
Impinger T Outlet																					
Vacuum (* Hg)																					
Traverse Point																		Total			
Time/Point(mins)																					
AP (mm H2O)																					
K factor																					
ΔH (Orifice)																					
Meter (Tm in)																					
Meter (Tm out)																					
Stack Temp (Ts)																					
Impinger T Outlet																					
Vacuum (* Hg)																					
Traverse Point																		Total			
Time/Point(mins)																					
AP (mm H2O)																					
K factor																					
ΔH (Orifice)																					
Meter (Tm in)																					
Meter (Tm out)																					
Stack Temp (Ts)																					
Impinger T Outlet																					
Vacuum (* Hg)																					
Traverse Point																		Total			
Time/Point(mins)																					
AP (mm H2O)																					
K factor																					
ΔH (Orifice)																					
Meter (Tm in)																					
Meter (Tm out)																					
Stack Temp (Ts)																					
Impinger T Outlet																					
Vacuum (* Hg)																					
Traverse Point																		Total			
Time/Point(mins)																					
AP (mm H2O)																					
K factor																					
ΔH (Orifice)																					
Meter (Tm in)																					
Meter (Tm out)																					
Stack Temp (Ts)																					
Impinger T Outlet																					
Vacuum (* Hg)																					

Ammonia

Environmental Compliance Limited		NON ISOKINETIC SAMPLING PROFORMA				Date of Measurement		05/01/2023		Rinse Solutions used					
ECL/TPD/ 034		Time taken to change Ports? 0				Start Time		13:30		End Time		14:30			
Client		Western Bio-Energy Limited		Stack Profile		Circular		Console id		U010		Barometer id		352	
Site		Margam		Stack Area (m ²)		2.01		Pump id		U010		Nozzle id		n/a	
Location		Biomass Plant		Barometric Pressure (mb)		1017		Probe id		149		Nozzle size		n/a	
Stack ID		Main Stack		Static Pres. (mm H ₂ O)		16.9		DGM Yd		0.9979		Filter Id		LW QMA	
Test No.		Ammonia		Pilot coefficient		n/a		AHE		47.22		Pilot ID		n/a	
Job No.		P5200		Probe Heater Setting (°C)		150		Impinger Id		337		Hot Box ID		192	
ECL Site Staff		PB, DB & LPH		Hot Box Setting (°											

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : Ro03

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Heavy Metals

METALS DATA SAMPLING PROFORMA										Date of Measurement		05/01/2023		Pilot Quality Control Checks											
ECL/TPD/		028		Time taken to change Ports?		2		Start Time		15:00		End Time		16:02		PRE-Sample PITOT Visual Inspection									
Client		Western Bio-Energy Limited		Stack Profile		Circular		Console id		U010		Barometer id		352		Time		14:54							
Site		Margam		Stack Area (m ²)		2.01		Pump id		U010		Nozzle id		335		Time		14:56							
Location		Biomass Plant		Barometric Pressure (mb)		1018		Probe id		149		Nozzle size		5.09		Time		14:58							
Stack ID		Main Stack		Static Pres. (mm H ² O)		19.9		DOM Yd		0.9979		Filter id		UW QIMA		Time		14:59							
Test No.		Heavy Metals		Pilot coefficient		0.84		A/H		47.22		Pilot ID		668		Time		15:00							
Job No		P5200		Probe Heater Setting (°C)		180		Impinger id		337		Hot Box ID		192		Time		15:01							
ECL Site Staff		PB, DB & LPH		Hot Box Setting (°C)		180		Balance id		1222						Time		15:02							
NB: Leak Check - Record Actual leak rate or 'U' but not less than values										Test Duration		60 mins		Rinse Solutions used		5% HNO3		4800		Pass 7 (Y/N)		Y			
Sample		Leak 1		Leak 2		Leak 3		Leak 4		Leak 5		Total		Impinger 1		HNO ₃ / H ₂ O		Time		15:04					
Start Volume		2717228.0												SOL		4799		Time		15:05					
Final Volume		2718300.2												Start Weight (g)		671.2		Time		15:06					
Total Volume		1072.2		0.0		0.0		0.0		0.0		1072.2		End Weight (g)		841.5		Time		16:06					
Leak Check		First		Second		Third		Fourth		Fifth				Total weight (g)		170.3		Time		16:08					
Leak rate l/min		0.2												Impinger 2		HNO ₃ / H ₂ O		Time		16:09					
Vacuum "Hg		12												SOL		4799		Time		16:10					
Time of Check		14:58												Start Weight (g)		862.9		Time		16:11					
Set Rate l/min		20												End Weight (g)		739		Time		16:12					
Leak <2%?		YES												Total weight (g)		46.1		Time		16:13					
Dry O ₂ <input type="checkbox"/> Atmospheric) 6.66 K factor 0.9										Reference Oxygen Percentage		6		Additional Moisture Weighings		Item Name									
Dry Carbon Dioxide % 13.85										Silica (PPH-Spacer at End of Test?)		YES		Item Name		Start Weight (g)		End Weight (g)		Total weight (g)					
Blank checks DO NOT NEED to be performed (BUT ARE ALLOWED at the end of the test or when moving between sample ports, EVEN when disconnections are made).										Total (g)		233.7		Item Name		Start Weight (g)		End Weight (g)		Total weight (g)					
Traverse Point		A1		A2		A3		A4		A5		A6		B1		B2		Total							
Time/Point (mins)		0 - 5		5 - 10		10 - 15		15 - 20		20 - 25		25 - 30		30 - 35		35 - 40		Total							
AP (mm H2O)		36.00		36.00		34.00		34.00		32.00		32.00		38.00		36.00		34.8							
K factor		0.90		0.90		0.90		0.90		0.90		0.90		0.90		0.90		34.8							
AR (Orifice)		32.40		32.40		30.60		30.60		28.80		28.80		34.20		32.40		31.3							
Meter (Tm in)		22.00		22.00		22.00		22.00		22.00		22.00		22.00		22.00		22.0							
Meter (Tm out)		22.00		22.00		22.00		22.00		22.00		22.00		22.00		22.00		22.0							
Stack Temp (Ts)		140.00		141.00		142.00		142.00		142.00		141.00		141.00		141.00		141.3							
Impinger T Outlet		7.00		7.00		7.00		7.00		8.00		8.00		8.00		8.00		7.5							
Vacuum (" Hg)		10.00		10.00		10.00		10.00		10.00		10.00		10.00		10.00		10							
Traverse Point		B3		B4		B5		B6										Total							
Time/Point (mins)		40 - 45		45 - 50		50 - 55		55 - 60										34.0							
AP (mm H2O)		36.00		34.00		34.00		32.00										34.0							
K factor		0.90		0.90		0.90		0.90										34.0							
AR (Orifice)		32.40		30.60		30.60		28.80										30.6							
Meter (Tm in)		22.00		23.00		23.00		23.00										22.8							
Meter (Tm out)		22.00		23.00		23.00		23.00										22.8							
Stack Temp (Ts)		140.00		140.00		139.00		139.00										139.5							
Impinger T Outlet		9.00		9.00		9.00		9.00										9.0							
Vacuum (" Hg)		10.00		10.00		10.00		10.00										10							
Traverse Point																		Total							
Time/Point (mins)																									
AP (mm H2O)																									
K factor																									
AR (Orifice)																									
Meter (Tm in)																									
Meter (Tm out)																									
Stack Temp (Ts)																									
Impinger T Outlet																									
Vacuum (" Hg)																									

Mercury

METALS DATA SAMPLING PROFORMA										Date of Measurement		06/01/2023		Pilot Quality Control Checks									
ECL/TPD/		030		Time taken to change Ports?		2		Start Time		13:10		End Time		14:12		PRE-Sample PITOT Visual Inspection							
Client		Western Bio-Energy Limited		Stack Profile		Circular		Console id		U010		Barometer id		352		Time		13:04					
Site		Margam		Stack Area (m ²)		2.01		Pump id		U010		Nozzle id		335		Time		13:06					
Location		Biomass Plant		Barometric Pressure (mb)		1014		Probe id		149		Nozzle size		5.09		Time		13:08					
Stack ID		Main Stack		Static Pres. (mm H ² O)		19.9		DOM Yd		0.9979		Filter id		UW QIMA		Time		13:09					
Test No.		Mercury		Pilot coefficient		0.84		A/H		47.22		Pilot ID		668		Time		13:10					
Job No		P5200		Probe Heater Setting (°C)		180		Impinger id		337		Hot Box ID		192		Time		13:11					
ECL Site Staff		PB & LPH		Hot Box Setting (°C)		180		Balance id		1222						Time		13:12					
NB: Leak Check - Record Actual leak rate or 'U' but not less than values										Test Duration		60 mins		Rinse Solutions used		5% HNO3		4800		Pass 7 (Y/N)		Y	
Sample		Leak 1		Leak 2		Leak 3		Leak 4		Leak 5		Total		Impinger 1		K ₂ Cr ₂ O ₇ / 20% HNO ₃		Time		14:15			
Start Volume		2725842.4												SOL		4802		Time		14:16			
Final Volume		2726956.8												Start Weight (g)		677.7		Time		14:17			
Total Volume		1014.4		0.0		0.0		0.0		0.0		1014.4		End Weight (g)		846.1		Time		14:21			
Leak Check		First		Second		Third		Fourth		Fifth				Total weight (g)		169.4		Time		14:22			
Leak rate l/min		0.2												Impinger 2		K ₂ Cr ₂ O ₇ / 20% HNO ₃		Time		14:23			
Vacuum "Hg		12												SOL		4802		Time		14:24			
Time of Check		13:08												Start Weight (g)		595.6		Time		14:25			
Set Rate l/min		20												End Weight (g)		628.5		Time		14:26			
Leak <2%?		YES												Total weight (g)		42.9		Time		14:27			
Dry O ₂ <input type="checkbox"/> Atmospheric) 6.60 K factor 0.9										Reference Oxygen Percentage		6		Additional Moisture Weighings		Item Name		Start Weight (g)		End Weight (g)		Total weight (g)	
Dry Carbon Dioxide % 13.85										Silica (PPH-Spacer at End of Test?)		YES		Item Name		Start Weight (g)		End Weight (g)		Total weight (g)			
Blank checks DO NOT NEED to be performed (BUT ARE ALLOWED at the end of the test or when moving between sample ports, EVEN when disconnections are made).										Total (g)		234.0		Item Name		Start Weight (g)		End Weight (g)		Total weight (g)			
Traverse Point		A1		A2		A3		A4		A5		A6		B1		B2		Total					
Time/Point (mins)		0 - 5		5 - 10		10 - 15		15 - 20		20 - 25		25 - 30		30 - 35		35 - 40		Total					
AP (mm H2O)		36.00		34.00		34.00		32.00		32.00		38.00		36.00		36.00		34.8					
K factor		0.90		0.90		0.90		0.90		0.90		0.90		0.90		0.90		34.8					
AR (Orifice)		32.40		30.60		30.60		28.80		28.80		34.20		34.20		31.3		31.3					
Meter (Tm in)		22.00		22.00		22.00		22.00		22.00		22.00		22.00		22.00		22.0					
Meter (Tm out)		22.00		22.00		22.00		22.00		22.00		22.00		22.00		22.00		22.0					
Stack Temp (Ts)		138.00		138.00		139.00		140.00		140.00		141.00		140.00		139.5		139.5					
Impinger T Outlet		7.00		7.00		7.00		7.00		8.00		8.00		8.00		7.5		7.5					
Vacuum (" Hg)		10.00		10.00		10.00		10.00		10.00		10.00		10.00		10		10					
Traverse Point		B3		B4		B5		B6										Total					
Time/Point (mins)		40 - 45		45 - 50		50 - 55		55 - 60										34.5					
AP (mm H2O)		36.00		34.00		34.00		32.00										34.5					
K factor		0.90		0.90		0.90		0.90										34.5					
AR (Orifice)		32.40		32.40		30.60		28.80										31.1					
Meter (Tm in)		22.00		22.00		22.00		22.00										22.0					
Meter (Tm out)		22.00		22.00		22.00		22.00															

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

LABORATORY ANALYSIS RESULTS

Laboratory analysis for Particulates, Hydrogen Chloride, Hydrogen Fluoride, ammonia, Sulphur Dioxide & Heavy Metals, Mercury was subcontracted to RPS laboratories, a UKAS Accredited Testing Laboratory, Number 0605.

RPS DO/ DO NOT hold UKAS & MCERTS accreditation for this analysis.

As required by the MCERTS Performance Standard for Organisations, the analysis results are shown below.

Laboratory analysis for Dioxins& Furans was subcontracted to Marchwood, a UKAS Accredited Testing Laboratory, Number 1668.

Marchwood DO hold UKAS & MCERTS accreditation for this analysis.

As required by the MCERTS Performance Standard for Organisations, the analysis results are shown below.

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Results Summary

Report No.: 23-00403-1

Customer Reference: 2023 Stack Preferential Rates

Customer Order No: E0232 P5200

Customer Sample No	ECL/23/0052	ECL/23/0053	ECL/23/0054	ECL/23/0055	ECL/23/0056	ECL/23/0057
RPS Sample No	155254	155255	155256	155257	155258	155259
Sample Matrix	FILTER	SOLUTION	FILTER	SOLUTION	FILTER	SOLUTION
Sampling Date	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023

Determinand	CAS No	Codes	SOP	RL	Units					
particulates		UM	D9	0.04	mg	0.52		S/C		S/C
particulates		UM	D9	0.5	mg		0.6		< 0.5	< 0.5

Comments

Report No.: 23-00403-1

Customer Reference: 2023 Stack Preferential Rates

Customer Order No: E0232 P5200

RPS Sample Number	Customer Number	Sample Comments
155256	ECL/23/0054	<0.1 mg
155258	ECL/23/0056	<0.1 mg

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Results Summary

Report No.: 23-00404-1

Customer Reference: 2023 Stack Preferential Rates

Customer Order No: E0232 P5200

Customer Sample No	ECL/23/0058	ECL/23/0059	ECL/23/0060	ECL/23/0061	ECL/23/0062	ECL/23/0063	ECL/23/0064	ECL/23/0065	ECL/23/0066	ECL/23/0067	ECL/23/0068
RPS Sample No	155260	155261	155262	155263	155264	155265	155266	155267	155268	155269	155270
Sample Matrix	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION	SOLUTION
Sampling Date	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	06/01/2023	06/01/2023	06/01/2023

Determinand	CAS No	Codes	SOP	RL	Units											
volume of sample supplied		U	N/A	n/a	ml	706	328	390	426	812	346	478	506	1050	491	365
ammonia	7664-41-7	UM	A6	0.1	ug/mL					7.6	< 0.1	< 0.1	< 0.1			
hydrogen chloride	7647-01-0	UM	C27	0.05	ug/mL	33.3	< 0.05	< 0.05	< 0.05							
sulphur dioxide	7446-09-5	UM	C27	0.05	ug/mL								63.6	0.19	0.19	
hydrogen fluoride	7664-39-3	UM	C27	0.05	ug/mL	< 0.05	< 0.05	< 0.05	< 0.05							

Results Summary

Report No.: 23-00404-1

Customer Reference: 2023 Stack Preferential Rates

Customer Order No: E0232 P5200

Customer Sample No	ECL/23/0069
RPS Sample No	155271
Sample Matrix	SOLUTION
Sampling Date	06/01/2023

Determinand	CAS No	Codes	SOP	RL	Units	
volume of sample supplied		U	N/A	n/a	ml	376
ammonia	7664-41-7	UM	A6	0.1	ug/mL	
hydrogen chloride	7647-01-0	UM	C27	0.05	ug/mL	
sulphur dioxide	7446-09-5	UM	C27	0.05	ug/mL	0.18
hydrogen fluoride	7664-39-3	UM	C27	0.05	ug/mL	

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Results Summary

Report No.: 23-00405-1

Customer Reference: 2023 Stack Preferential Rates

Customer Order No: E0232 P5200

Customer Sample No	ECL/23/0070	ECL/23/0071	ECL/23/0072	ECL/23/0073	ECL/23/0074	ECL/23/0075	ECL/23/0076	ECL/23/0077	ECL/23/0078	ECL/23/0079	ECL/23/0080
RPS Sample No	155272	155273	155274	155275	155276	155277	155278	155279	155280	155281	155282
Sample Matrix	FILTER	SOLUTION	SOLUTION	SOLUTION	FILTER	SOLUTION	SOLUTION	SOLUTION	FILTER	SOLUTION	SOLUTION
Sampling Date	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	06/01/2023	06/01/2023	06/01/2023

Determinand	CAS No	Codes	SOP	RL	Units										
volume of sample supplied		U	N/A	n/a	ml		136	611	330		179	280	155	157	361
arsenic	7440-38-2	UM	M31	0.2	ug	1.8				< 0.2					
cadmium	7440-43-9	UM	M31	0.2	ug	< 0.2				< 0.2					
cobalt	7440-48-4	UM	M31	0.2	ug	< 0.2				< 0.2					
chromium	7440-47-3	UM	M31	0.3	ug	2.2				2.0					
copper	7440-50-8	UM	M31	0.2	ug	0.3				< 0.2					
manganese	7439-96-5	UM	M31	0.2	ug	1.5				1.2					
nickel	7440-02-0	UM	M31	0.5	ug	5.5				5.4					
lead	7439-92-1	UM	M31	0.3	ug	1.1				0.4					
antimony	7440-36-0	UM	M31	0.4	ug	12.4				< 0.4					
thallium	7440-28-0	UM	M31	0.2	ug	< 0.2				< 0.2					
vanadium	7440-62-2	UM	M31	0.2	ug	< 0.2				< 0.2					
arsenic	7440-38-2	UM	M31	0.3	ug		< 0.3			< 0.3					
cadmium	7440-43-9	UM	M31	0.3	ug		< 0.3			< 0.3					
cobalt	7440-48-4	UM	M31	0.3	ug		< 0.3			< 0.3					
chromium	7440-47-3	UM	M31	0.3	ug		9.7			2.5					
copper	7440-50-8	UM	M31	0.4	ug		1.9			< 0.4					
manganese	7439-96-5	UM	M31	0.2	ug		4.3			< 0.2					
nickel	7440-02-0	UM	M31	0.1	ug		11.4			< 0.1					
lead	7439-92-1	UM	M31	0.2	ug		2.2			< 0.2					
antimony	7440-36-0	UM	M31	0.2	ug		< 0.2			< 0.2					
thallium	7440-28-0	UM	M31	0.2	ug		< 0.2			< 0.2					
vanadium	7440-62-2	UM	M31	0.2	ug		1.2			< 0.2					
arsenic	7440-38-2	UM	M31	0.3	ug/L			7.6	< 0.3		< 0.3	< 0.3			
cadmium	7440-43-9	UM	M31	0.2	ug/L			< 0.2	< 0.2		< 0.2	< 0.2			
cobalt	7440-48-4	UM	M31	0.2	ug/L			< 0.2	< 0.2		< 0.2	< 0.2			
chromium	7440-47-3	UM	M31	0.2	ug/L			18.4	< 0.2		< 0.2	0.2			
copper	7440-50-8	UM	M31	0.4	ug/L			18.6	< 0.4		< 0.4	< 0.4			
manganese	7439-96-5	UM	M31	0.2	ug/L			1.6	< 0.2		< 0.2	< 0.2			
nickel	7440-02-0	UM	M31	0.3	ug/L			1.9	< 0.3		< 0.3	< 0.3			
lead	7439-92-1	UM	M31	0.2	ug/L			10.1	< 0.2		< 0.2	< 0.2			
antimony	7440-36-0	UM	M31	0.2	ug/L			2.0	< 0.2		< 0.2	< 0.2			
thallium	7440-28-0	UM	M31	0.2	ug/L			< 0.2	< 0.2		< 0.2	< 0.2			

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Results Summary

Report No.: 23-00405-1

Customer Reference: 2023 Stack Preferential Rates

Customer Order No: E0232 P5200

Customer Sample No	ECL/23/0070	ECL/23/0071	ECL/23/0072	ECL/23/0073	ECL/23/0074	ECL/23/0075	ECL/23/0076	ECL/23/0077	ECL/23/0078	ECL/23/0079	ECL/23/0080
RPS Sample No	155272	155273	155274	155275	155276	155277	155278	155279	155280	155281	155282
Sample Matrix	FILTER	SOLUTION	SOLUTION	SOLUTION	FILTER	SOLUTION	SOLUTION	SOLUTION	FILTER	SOLUTION	SOLUTION
Sampling Date	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	05/01/2023	06/01/2023	06/01/2023	06/01/2023

Determinand	CAS No	Codes	SOP	RL	Units							
vanadium	7440-62-2	UM	M31	0.1	ug/L			< 0.1	< 0.1			
mercury	7439-97-6	UM	M112	0.03	ug						< 0.03	
mercury	7439-97-6	UM	M112	0.5	ug/l							< 0.5
mercury	7439-97-6	UM	M112	0.5	ug/l							< 0.50

Results Summary

Report No.: 23-00405-1

Customer Reference: 2023 Stack Preferential Rates

Customer Order No: E0232 P5200

Customer Sample No	ECL/23/0081	ECL/23/0082	ECL/23/0083	ECL/23/0084	ECL/23/0085
RPS Sample No	155283	155284	155285	155286	155287
Sample Matrix	SOLUTION	FILTER	SOLUTION	SOLUTION	SOLUTION
Sampling Date	06/01/2023	06/01/2023	06/01/2023	06/01/2023	06/01/2023

Determinand	CAS No	Codes	SOP	RL	Units					
vanadium	7440-62-2	UM	M31	0.1	ug/L					
mercury	7439-97-6	UM	M112	0.03	ug			< 0.03		
mercury	7439-97-6	UM	M112	0.5	ug/l			< 0.5		< 0.5
mercury	7439-97-6	UM	M112	0.5	ug/l				< 0.50	

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : Ro03

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Results Summary

Report No.: 23-00405-1

Customer Reference: 2023 Stack Preferential Rates

Customer Order No: E0232 P5200

Customer Sample No	ECL/23/0081	ECL/23/0082	ECL/23/0083	ECL/23/0084	ECL/23/0085
RPS Sample No	155283	155284	155285	155286	155287
Sample Matrix	SOLUTION	FILTER	SOLUTION	SOLUTION	SOLUTION
Sampling Date	06/01/2023	06/01/2023	06/01/2023	06/01/2023	06/01/2023

Determinand	CAS No	Codes	SOP	RL	Units					
volume of sample supplied		U	N/A	n/a	ml	212		152	250	114
arsenic	7440-38-2	UM	M31	0.2	ug					
cadmium	7440-43-9	UM	M31	0.2	ug					
cobalt	7440-48-4	UM	M31	0.2	ug					
chromium	7440-47-3	UM	M31	0.3	ug					
copper	7440-50-8	UM	M31	0.2	ug					
manganese	7439-96-5	UM	M31	0.2	ug					
nickel	7440-02-0	UM	M31	0.5	ug					
lead	7439-92-1	UM	M31	0.3	ug					
antimony	7440-36-0	UM	M31	0.4	ug					
thallium	7440-28-0	UM	M31	0.2	ug					
vanadium	7440-62-2	UM	M31	0.2	ug					
arsenic	7440-38-2	UM	M31	0.3	ug					
cadmium	7440-43-9	UM	M31	0.3	ug					
cobalt	7440-48-4	UM	M31	0.3	ug					
chromium	7440-47-3	UM	M31	0.3	ug					
copper	7440-50-8	UM	M31	0.4	ug					
manganese	7439-96-5	UM	M31	0.2	ug					
nickel	7440-02-0	UM	M31	0.1	ug					
lead	7439-92-1	UM	M31	0.2	ug					
antimony	7440-36-0	UM	M31	0.2	ug					
thallium	7440-28-0	UM	M31	0.2	ug					
vanadium	7440-62-2	UM	M31	0.2	ug					
arsenic	7440-38-2	UM	M31	0.3	ug/L					
cadmium	7440-43-9	UM	M31	0.2	ug/L					
cobalt	7440-48-4	UM	M31	0.2	ug/L					
chromium	7440-47-3	UM	M31	0.2	ug/L					
copper	7440-50-8	UM	M31	0.4	ug/L					
manganese	7439-96-5	UM	M31	0.2	ug/L					
nickel	7440-02-0	UM	M31	0.3	ug/L					
lead	7439-92-1	UM	M31	0.2	ug/L					
antimony	7440-36-0	UM	M31	0.2	ug/L					
thallium	7440-28-0	UM	M31	0.2	ug/L					

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023



CERTIFICATE OF ANALYSIS

MSSL reference: 23-48763

Report date: 26-01-2023

Customer: Environmental Compliance Ltd
Unit 1G,
Main Avenue,
Treforest Industrial Estate,
Pontypridd,
CF37 5BF

Customer contact(s): -

Customer reference: P5200
Customer PO: E0233
Customer sampling date: 09-01-2023
Date received: 13-01-2023

Analysis started: 19-01-2023
Analysis complete: 23-01-2023
Conforming: YES

This report shall not be reproduced except when in full without approval of the laboratory.
Results only relate to the items tested. Results apply to the samples as received.
Conformance is contingent upon accurate information being provided by the customer and customer compliance with relevant sample handling and storage conditions prior to receipt at the laboratory.
All opinions and interpretations expressed within this report are outside Marchwood's scope of accreditation.

Accreditation Key:

Y : ISO/IEC 17025 M : MCERTS
N : Non Accredited (S) : Subcontracted

Notes:

Reported by: Lesley Jeffery
Position: Scientist

Approved by: Giuseppe Reitano
Position: Technical Laboratory Manager
For/on behalf of Marchwood Scientific Services Ltd



t: 02380 786979 w: www.cawood.co.uk/marchwood
Marchwood, 371 Millbrook Road West, Southampton SO15 0HW



Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

270166 Dioxin Results Summary

Sample Type : Stack
MSS Sample Ref : 270166
Customer Sample Ref : ECL/23/0046 -ECL/23/0048
Sample Condition : Conforming
Test Method : 2002b

Dioxins/ Furans

Analysis	Accreditation	Lower Bound	Upper Bound
I-TEQ	M	0.0107	0.0113

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

270166 Dioxin Results

Sample Type : Stack
 MSS Sample Ref : 270166
 Customer Sample Ref : ECL/23/0046 -ECL/23/0048
 Sample Condition : Conforming
 Test Method : 2002b

Congener	LOD	Detected	Lower Bound	Upper Bound	Recovery	Sampling Recovery	UKAS
Dioxins/Furans	ng/Sample	ng/Sample	ng/Sample	ng/Sample	%	%	
2378-TCDD	0.00051	< 0.00051	0.0000	0.00051	103		M
12378-PeCDD	0.00120	0.00384	0.00192	0.00192	84		M
123478-HxCDD	0.00096	0.00564	0.00056	0.00056	81		M
123678-HxCDD	0.00096	0.0121	0.00121	0.00121	89		M
123789-HxCDD	0.00091	0.00671	0.00067	0.00067			M
1234678-HpCDD	0.00049	0.0557	0.00056	0.00056	84		M
OCDD	0.00053	0.0615	0.00006	0.00006	78		M
Dioxins Total			0.00498	0.00549			M
2378-TCDF	0.00116	0.0103	0.00103	0.00103	89		M
12378-PeCDF	0.00087	0.00412	0.00021	0.00021		105	M
23478-PeCDF	0.00085	0.00556	0.00278	0.00278	86		M
123478-HxCDF	0.00042	0.00466	0.00047	0.00047	85		M
123678-HxCDF	0.00043	0.00546	0.00055	0.00055	89		M
234678-HxCDF	0.00037	0.00523	0.00052	0.00052	91		M
123789-HxCDF	0.00036	< 0.00036	0.0000	0.00004		90	M
1234678-HpCDF	0.00025	0.0174	0.00017	0.00017	85		M
1234789-HpCDF	0.00029	0.00216	0.00002	0.00002		102	M
OCDF	0.00025	0.00469	0.00000	0.00000	72		M
Furans Total			0.00575	0.00579			M
Dioxin/Furan Total			0.0107	0.0113			M

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

270167 Dioxin Results Summary

Sample Type : Stack
MSS Sample Ref : 270167
Customer Sample Ref : ECL/23/0049 -ECL/23/0051
Sample Condition : Conforming
Test Method : 2002b

Dioxins/ Furans

Analysis	Accreditation	Lower Bound	Upper Bound
I-TEQ	M	0.00170	0.00213

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

270167 Dioxin Results

Sample Type : Stack
 MSS Sample Ref : 270167
 Customer Sample Ref : ECL/23/0049 -ECL/23/0051
 Sample Condition : Conforming
 Test Method : 2002b

Congener	LOD	Detected	Lower Bound	Upper Bound	Recovery	Sampling Recovery	UKAS
Dioxins/Furans	ng/Sample	ng/Sample	ng/Sample	ng/Sample	%	%	
2378-TCDD	0.00014	< 0.00014	0.0000	0.00014	100		M
12378-PeCDD	0.00044	< 0.00044	0.0000	0.00022	87		M
123478-HxCDD	0.00026	< 0.00026	0.0000	0.00003	82		M
123678-HxCDD	0.00027	0.00090	0.00009	0.00009	79		M
123789-HxCDD	0.00026	0.00073	0.00007	0.00007			M
1234678-HpCDD	0.00028	0.00644	0.00006	0.00006	77		M
OCDD	0.00041	0.0155	0.00002	0.00002	75		M
Dioxins Total			0.00024	0.00063			M
2378-TCDF	0.00036	0.00085	0.00008	0.00008	88		M
12378-PeCDF	0.00029	0.00141	0.00007	0.00007		108	M
23478-PeCDF	0.00028	0.00152	0.00076	0.00076	84		M
123478-HxCDF	0.00022	< 0.00022	0.0000	0.00002	79		M
123678-HxCDF	0.00021	0.00210	0.00021	0.00021	80		M
234678-HxCDF	0.00020	0.00252	0.00025	0.00025	82		M
123789-HxCDF	0.00019	< 0.00019	0.0000	0.00002		91	M
1234678-HpCDF	0.00019	0.00695	0.00007	0.00007	77		M
1234789-HpCDF	0.00022	0.00084	0.00001	0.00001		103	M
OCDF	0.00020	0.00197	0.00000	0.00000	68		M
Furans Total			0.00146	0.00150			M
Dioxin/Furan Total			0.00170	0.00213			M

Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

UNCERTAINTY CALCULATIONS

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

TVOC Measurement Uncertainty

Main Stack - TVOC - Measurement Uncertainty - Uncertainty Calculations Table 1

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Min Certified Ranges
			TVOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.73
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.35
Repeatability Standard Deviation (span) ⁽³⁾	u_r	Normal (Divisor = 1)	1.61
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	0.11
Temperature dependant span drift ⁽⁵⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.30
Interferents ⁽¹⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	4.39
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	0.84

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- 1 Expressed as a percentage of the certified range
- 2 Expressed as maximum drift per 24hr period as percentage of the certified range
- 3 Expressed as a percentage of the certified range
- 4 Expressed as a percentage of the certified range
- 5 Expressed as a percentage of the certified range per one degree centigrade
- 6 Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol taking account of an additional uncertainty of 2% for gas blending
- 7 Expressed as a percentage of the certified range

Main Stack - TVOC - Measurement Uncertainty - Uncertainty Calculations Table 2

Performance Characteristics	Uncertainty	Value of Standard Uncertainty	*TVOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.064
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.031
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	0.24
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	0.0096
Temperature dependant span drift	u_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{adj})^2 + (x_{i,min} - x_{adj})(x_{i,max} - x_{adj}) + (x_{i,min} - x_{adj})^2}{3}}$	0.013
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.38
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	0.48
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	0.79
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	1.58
Applied Span Concentration			48.39
Measured Span Concentration, STP Dry Gas			48.53
Expanded measurement uncertainty as % of Applied Span			3 %

* Signal 3030 FID

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

TVOC Uncertainty of Measurement Results

Main Stack - TVOC - Uncertainty of Measurement Results - Calculations Part 1

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Min Certified Range	
				O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.13	0.73
Span drift ⁽²⁾	$u_{d,s}$			0.029	0.35
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			1.00	0.055
Temperature dependant span drift ⁽⁴⁾	u_t			0.070	0.30
Interferents ⁽¹⁾	u_i			0.56	4.39
Effect of Voltage Fluctuation ⁽⁷⁾	u_v			...	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}			...	

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})(x_{i,max} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.019	0.064
Span drift	$u_{d,s}$			0.0041	0.031
Temperature dependant span drift	u_t			0.0051	0.013
Interferents	u_i			0.081	0.38
Effect of Voltage Fluctuation (See Note)	u_v			...	0.16

Main Stack - TVOC - Uncertainty of Measurement Results - Calculations Part 2

Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	O ₂ 0 - 25 %Vol	TVOC 0 - 15 mgC/m ³
Losses / leakage in the sample system	u_{loss}	05/01/23 13:00 - 14:00	0.069	0.0015
Standard Error of Measured Value	u_{SE}	05/01/23 13:00 - 14:00	0.032	0.019
Uncertainty due to Moisture Correction ⁽⁶⁾	u_{H2O}	05/01/23 13:00 - 14:00	0.27	0.081

Effect on Uncertainty Caused by Oxygen

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured})(20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Meas} = 0.03$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.0609$$

$$u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 2.56\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Main Stack - TVOC - Uncertainty of Measurement Results - Calculations Part 3

Uncertainty	Date & Time	O ₂ 0 - 25 %Vol	*TVOC 0 - 15 mgC/m ³
Measured Concentration	05/01/23 13:00 - 14:00	6.85	2.72
Expanded Uncertainty as Percentage of Measured Concentration		8 %	29 %

Combined Standard Uncertainty $u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2 + u_v^2 + u_{syn}^2}$

Expanded uncertainty (at 95% confidence) $U_{Exp} = 2 \times u_c$

- 1 Expressed as a percentage of the certified range
- 2 Expressed as a percentage of the certified range as maximum drift per 24hr period
- 3 Expressed as a percentage of the certified range
- 4 Expressed as a percentage of the applied span concentration
- 5 Expressed as a percentage of the certified range per one degree centigrade
- 6 Where the uncertainty of moisture is taken from the manual extract test calculations.
- 7 Expressed as a percentage of the certified range
- 8 Where no uncertainty is presented above, the uncertainty is >100%

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Combustion Gases (NO_x, CO & O₂) Measurement Uncertainty

Measurement Uncertainty Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distributiou	Minimum Certified Range (R _i)		
			NO 0 - 134 mg/m ³	CO 0 - 75 mg/m ³	O ₂ 0 - 25 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.75	0.61	0.10
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.094	0.056	0.0057
Repeatability Standard Deviation (span) ⁽³⁾	u_r	Normal (Divisor = 1)	0.76	1.18	0.094
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	2.13	1.41	0.041
Temperature dependant span drift ⁽⁵⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.051	0.057	0.014
Interferents ⁽¹⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	0.52	0.87	0.010
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	5.51	6.63	0.15
Effect of Voltage Fluctuation ⁽⁷⁾	u_v	Rectangular (Divisor = $\sqrt{3}$)	0.40	0.50	0.020
Effect of Sample Gas Flow/ Pressure ⁽⁷⁾	u_{sg}	Rectangular (Divisor = $\sqrt{3}$)	0.10	0.10	0.10

Note:

when $(x_{i,max} - x_{i,adj}) = (x_{i,min} - x_{i,adj})$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

- 1 Expressed as a percentage of the certified range
- 2 Expressed as a percentage of the certified range as maximum drift per 24hr period
- 3 Expressed as a percentage of the certified range
- 4 Expressed as a percentage of the certified range
- 5 Expressed as a percentage of the certified range per one degree centigrade
- 6 Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol inc additional uncertainty of 2% for gas blending
- 7 Expressed as a percentage of the certified range

Measurement Uncertainty Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty	Value of Standard Uncertainty	NO 0 - 134 mg/m ³	CO 0 - 75 mg/m ³	O ₂ 0 - 25 %Vol
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.58	0.26	0.014
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.073	0.024	0.00082
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	0.76	1.18	0.094
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	1.65	0.61	0.0059
Temperature dependant span drift	u_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})^2 + (x_{i,max} - x_{i,adj})(x_{i,min} - x_{i,adj})}{3}} =$	0.020	0.012	0.0010
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.40	0.38	0.0014
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	3.18	3.83	0.087
Effect of Voltage Fluctuation ⁽⁷⁾	u_v	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.23	0.29	0.012
Effect of Sample Gas Flow / Pressure ⁽⁷⁾	u_{sg}	$u(x_i) = \frac{u_{sg} \times R_i}{\sqrt{3}} =$	0.058	0.058	0.058
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2 + u_v^2 + u_{sg}^2} =$	3.74	4.09	0.14
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	7.47	8.17	0.28
Applied Span Concentration			317.96	382.63	14.99
Measured Span Concentration, STP Dry Gas			315.67	382.31	15.02
Expanded measurement uncertainty as % of Applied Span			2%	2%	2%

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Combustion Gases (NO_x, CO & O₂) Uncertainty of Measurement Results

Uncertainty of Measurement Results - Calculations Part 1

Horiba PG 350 E Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R _i)		
				NO 0 - 134 mg/m ³	CO 0 - 75 mg/m ³	O ₂ 0 - 25 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.75	0.61	0.10
Span drift ⁽²⁾	$u_{d,s}$			0.094	0.056	0.0057
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			2.13	1.41	0.04
Temperature dependant span drift ⁽³⁾	u_t			0.051	0.057	0.014
Interferents ⁽¹⁾	u_i			0.52	0.87	0.010
Effect of Voltage Fluctuation ⁽⁷⁾	u_v			0.40	0.50	0.020
Sample Gas Pressure/ Flow ⁽⁷⁾	u_{sg}			0.10	0.10	0.10

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})(x_{i,max} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$, when $(x_{i,max} - x_{i,adj}) = (x_{i,min} - x_{i,adj})$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	NO 0 - 134 mg/m ³	CO 0 - 75 mg/m ³	O ₂ 0 - 25 %Vol
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.58	0.26	0.014
Span drift	$u_{d,s}$			0.073	0.024	0.00082
Temperature dependant span drift	u_t			0.020	0.012	0.0010
Interferents	u_i			0.40	0.38	0.0014
Effect of Voltage Fluctuation ⁽⁷⁾	u_v			0.31	0.22	0.0029
Sample Gas Pressure/ Flow ⁽⁷⁾	u_{sg}			0.077	0.043	0.014

Uncertainty of Measurement Results - Calculations Part 2

Horiba PG 350 E Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	NO 0 - 134 mg/m ³	CO 0 - 75 mg/m ³	O ₂ 0 - 25 %Vol
Losses / leakage in the sample system	u_{loss}	05/01/23 14:00 - 15:00	3.80	1.67	0.003
Standard Error of Measured Value	u_{SE}	05/01/23 14:00 - 15:00	2.04	3.14	0.081

Effect on Uncertainty Caused by Oxygen $u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured})(20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.027$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 2.1871 \quad u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 1.24\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$\therefore u(x_i) = C_i u_i$ where $C_i = \frac{\partial f}{\partial x_i}$

Uncertainty of Measurement Results - Calculations Part 3

Horiba PG 350 E Uncertainty	Date & Time	NOx (as NO ₂) 0 - 134 mg/m ³	CO 0 - 75 mg/m ³	O ₂ 0 - 25 %Vol
Measured Concentration	05/01/23 14:00 - 15:00	178.73	119.10	6.81
Expanded Uncertainty as Percentage of Measured Concentration		5%	6%	3%

Combined Standard Uncertainty $u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_t^2 + u_{loss}^2 + u_i^2 + u_v^2 + u_{sg}^2 + u_{Corr_{O_2}}^2}$

Expanded uncertainty (at 95% confidence) $U_{Exp} = 2 \times u_c$

- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range as maximum drift per 24hr period
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range
- Expressed as a percentage of the certified range per one degree centigrade
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- If no value for uncertainty is presented above, the uncertainty is considered to be >100%

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Combustion Gases (N₂O & O₂) Measurement Uncertainty

Hide Empty Rows Show All Hidden Rows Main Navigation Page

Measurement Uncertainty Calculations Part 1

Protir 204M FTIR Performance Characteristics	Standard Uncertainty	Distributioun	imum Certified Range	
			N ₂ O 0 - 39 mg/m ³	O ₂ 0 - 21 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.67	0.19
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.57	0.029
Repeatability Standard Deviation (span) ⁽³⁾	u_r	Normal (Divisor = 1)	0.87	0.13
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	0.48	0.44
Temperature dependant span drift ⁽⁵⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.30	0.13
Interferents ⁽¹⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	5.16	0.10
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	1.04	0.15

Note:

when $(x_{i,max} - x_{i,adj}) = (x_{i,min} - x_{i,adj})$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

- 1 Expressed as a percentage of the certified range
- 2 Expressed as a percentage of the certified range as maximum drift per 24hr period
- 3 Expressed as a percentage of the certified range
- 4 Expressed as a percentage of the certified range
- 5 Expressed as a percentage of the certified range per one degree centigrade
- 6 Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol inc additional uncertainty of 2% for gas blending
- 7 Not Available

Measurement Uncertainty Calculations Part 2

Protir 204M FTIR Performance Characteristics	Uncertainty	Value of Standard Uncertainty	N ₂ O 0 - 39 mg/m ³	O ₂ 0 - 21 %Vol
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.15	0.023
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.13	0.0034
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	0.87	0.13
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	0.089	0.036
Temperature dependant span drift	u_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{adj})^2 + (x_{i,min} - x_{adj})(x_{i,max} - x_{adj}) + (x_{i,min} - x_{adj})^2}{3}}$	0.10	0.024
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	1.16	0.012
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	0.60	0.087
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	1.59	0.16
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	3.18	0.32
Applied Span Concentration			36.65	14.99
Measured Span Concentration, STP Dry Gas			36.42	15.06
Expanded measurement uncertainty as % of Applied Span			9%	2%

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance - January 2023
 Survey Dates : 5th - 9th January 2023
 Report Issue Date : 16th February 2023

Combustion Gases (N₂O & O₂) Uncertainty of Measurement Results

Uncertainty of Measurement Results - Calculations Part 1

Protir 204M FTIR Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Minimum Certified Range (R _i)	
				N ₂ O 0 - 39 mg/m ³	O ₂ 0 - 21 %Vol
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	0.67	0.19
Span drift ⁽²⁾	u_{ds}			0.57	0.029
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			0.48	0.44
Temperature dependant span drift ⁽⁵⁾	u_t			0.30	0.13

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,adj})^2 + (x_{i,min} - x_{i,adj})(x_{i,max} - x_{i,adj}) + (x_{i,min} - x_{i,adj})^2}{3}}$, when $|x_{i,max} - x_{i,adj}| = |x_{i,min} - x_{i,adj}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Protir 204M FTIR Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	N ₂ O 0 - 39 mg/m ³	O ₂ 0 - 21 %Vol
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	0.15	0.023
Span drift	u_{ds}			0.13	0.0034
Temperature dependant span drift	u_t			0.089	0.021
Interferents	u_i			1.16	0.012

Uncertainty of Measurement Results - Calculations Part 2

Protir 204M FTIR Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	N ₂ O 0 - 39 mg/m ³	O ₂ 0 - 21 %Vol
Losses / leakage in the sample system	u_{loss}	09/01/23 14:00 - 15:00	0.0025	0.036
Standard Error of Measured Value	u_{SE}	09/01/23 14:00 - 15:00	0.018	0.021
Uncertainty due to Moisture Correction ⁽⁶⁾	u_{H2O}	09/01/23 14:00 - 15:00	0.015	0.24

Effect on Uncertainty Caused by Oxygen

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured})(20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.025$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 2.3570 \quad u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 1.07\%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty of Measurement Results - Calculations Part 3

Protir 204M FTIR Uncertainty	Date & Time	N ₂ O 0 - 39 mg/m ³	O ₂ 0 - 21 %Vol
Measured Concentration	09/01/23 14:00 - 15:00	0.53	8.16
Expanded Uncertainty as Percentage of Measured Concentration		>100%	6%

$$u_c = \sqrt{u_{lof}^2 + u_{ds}^2 + u_{loss}^2 + u_t^2 + u_{H2O}^2 + u_{SE}^2 + u_{O_2}^2 + u_{O_2}^2}$$

Combined Standard Uncertainty

$$U_{Exp} = 2 \times u_c$$

Expanded uncertainty (at 95% confidence)

- 1 Expressed as a percentage of the certified range
- 2 Expressed as percentage of the certified range as maximum drift per 24hr period
- 3 Expressed as a percentage of the certified range
- 4 Expressed as a percentage of the certified range
- 5 Expressed as a percentage of the certified range per one degree centigrade
- 6 Where the uncertainty of moisture is taken from the manual extract test calculations.
- 7 Not available
- 8 If no value for uncertainty is presented above, the uncertainty is considered to be >100%

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Particulates & Hydrogen Chloride & Fluoride Uncertainty

Site: Margam
 Location: Main Stack

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Filter mg	Uncert (%) K=2 Solution mg	Standard Uncertainty Filter mg	Standard Uncertainty Solution mg	Combined Uncertainty mg
TPM, HCl & HF								
Particulates	0.52	0.60	1.12	0.10	0.50	0.0500	0.25	0.25
Hydrogen Chloride	...	23.53	23.53	...	3.06	...	1.53	1.53
Hydrogen Fluoride	...	0.0517	0.0517	...	0.00672	...	0.00336	0.00336
...

TPM, HCl & HF			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	1.10	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	1.00
Meter Temperature (T _m)	293.17	k	uT _m	1.5	k
Average Differential Pressure (ΔH)	30.75	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (p _b)	763.56	mmHg	up _b	3.8	mmHg
ΔH + ps (p _m)	102.10	kPa
Oxygen content (O _{2,m})	6.78	% by volume	uO _{2,m} = σ/√n	0.0792	% by volume
Moisture Content (H ₂ O)	23.01	% by volume	uH ₂ O	0.61	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

TPM, HCl & HF:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (up_b) & measured temperature of dry gas uncertainty component (uT_{m Dry})

TPM, HCl & HF:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.936$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.94	0.94	0.0000899	0.0000225
up _b	0.94	0.93	0.00122	0.00459
uT _m	0.94	0.93	0.00319	0.00479
H ₂ O

$$u_{f_s} = \sqrt{\left(\frac{u\Delta H}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.00597$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

TPM, HCl & HF:

$$V_{std} = V_{measured} \times f_s = 1.034$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{std}	1.04	1.03	1.10	0.00659
Effect of uV _m	1.03	1.03	0.94	0.000936

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00732$$

Uncertainty of Oxygen Correction Factor (%):-

TPM, HCl & HF:

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.06$$

$$u_{Corr_{o_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times \text{Uncertainty of } O_2 \text{ Measurement}} = 0.0269$$

$$uf_{o_2} = \frac{u_{Corr_{o_2}}}{f_{o_2}} \times 100 = 2.55\%$$

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	TPM, HCl & HF:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
Particulates	1.40	0.88	1.02	0.26
Hydrogen Chloride	25.59	22.46	1.02	1.56
Hydrogen Fluoride	0.0562	0.0494	1.02	0.00343
Ammonia

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	TPM, HCl & HF:
	uL mg/Nm ³
Particulates	0.0132
Hydrogen Chloride	0.28
Hydrogen Fluoride	0.000610
Ammonia	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	TPM, HCl & HF:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
Particulates	1.15	1.14	1.11	0.00811
Hydrogen Chloride	24.20	23.86	23.25	0.17
Hydrogen Fluoride	0.0532	0.0524	0.0511	0.000374
Ammonia

Measurement Uncertainty of Determinand (excluding correction for oxygen)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	TPM, HCl & HF:				Uncertainty as Percentage of ELV
	Measurement Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration	
Particulates	0.26	0.52	1.14	45.61	3.48
Hydrogen Chloride	1.60	3.19	24.03	13.28	
Hydrogen Fluoride	0.00351	0.00701	0.0528	13.28	
Ammonia	

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	TPM, HCl & HF:		
	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr ⁿ Factor	Overall Measurement Uncertainty inc O ₂ Corr ⁿ factor (U _{combined})
Particulates	45.61	2.55	45.68
Hydrogen Chloride	13.28	2.55	13.52
Hydrogen Fluoride	13.28	2.55	13.52
Ammonia

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Ammonia Uncertainty

Site: Margam
 Location: Main Stack

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2 Filter mg	Solution mg	Standard Uncertainty Filter mg	Solution mg	Combined Uncertainty mg
Ammonia								
...
...
...
Ammonia	...	6.21	6.21	...	0.81	...	0.40	0.40
...
...
...
...

Ammonia		Standard Uncertainty @ 95%	
Sampled Volume (V _m)	0.89 m ³	uV _m	0.001 m ³
Meter Correction Factor (Y _d)	1.00
Meter Temperature (T _m)	294.67 k	uT _m	1.5 k
Average Differential Pressure (ΔH)	25.00 mmH ₂ O	uΔH	0.25 mmH ₂ O
Barometric Pressure (p _b)	762.81 mmHg	u p _b	3.8 mmHg
ΔH + ps (p _m)	101.94 kPa
Oxygen content (O _{2,m})	7.01 % by volume	uO _{2,m} = σ/√n	0.0772 % by volume
Moisture Content (H ₂ O)	24.35 % by volume	uH ₂ O	0.65 % by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

Ammonia:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (u p_b) & measured temperature of dry gas uncertainty component (uT_{m Dry})

Ammonia:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.930$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.93	0.93	0.0000894	0.0000224
u p _b	0.93	0.93	0.00122	0.00456
uT _m	0.93	0.93	0.00316	0.00474
H ₂ O

$$\frac{u f_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.00587$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

Ammonia:

$$V_{std} = V_{measured} \times f_s = 0.826$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{std}	0.83	0.82	0.89	0.00521
Effect of uV _m	0.83	0.83	0.93	0.000930

Combined Standard Uncertainty

$$\frac{u V_{std}}{V_{std}} = \sqrt{\left(\frac{u V_{std}}{f_s}\right)^2 + \left(\frac{u V_m}{V_m}\right)^2} = 0.00471$$

Uncertainty of Oxygen Correction Factor (%):-

Ammonia:

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.07$$

$$uCorr_{o_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.0278$$

$$u f_{o_2} = \frac{uCorr_{o_2}}{f_{o_2}} \times 100 = 2.59\%$$

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	Ammonia:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
...
...
...
Ammonia	8.58	7.54	1.30	0.52

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	Ammonia:
	uL mg/Nm ³
...	...
...	...
...	...
Ammonia	0.0931

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	Ammonia:			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
...
...
...
Ammonia	8.11	8.01	9.76	0.0459

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	Ammonia:			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
...
...
...
Ammonia	0.53	1.07	8.06	13.25

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (uf_{O_2})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O ₂ Corr ⁿ factor (Ucombined)
...
...
...
Ammonia	13.25	2.59	13.50

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Sulphur Dioxide Uncertainty

Site: Margam
 Location: Main Stack

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
Sulphur Dioxide								
...
Sulphur Dioxide	...	66.87	66.87	...	8.69	...	4.35	4.35
...

Sulphur Dioxide			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	3.71	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	1.00
Meter Temperature (T _m)	292.96	k	uT _m	1.5	k
Average Differential Pressure (ΔH)	15.00	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (p _b)	760.56	mmHg	uρ _b	3.8	mmHg
ΔH + ps (ρ _m)	101.55	kPa
Oxygen content (O _{2,m})	6.55	% by volume	uO _{2,m} = σ/√n	0.0293	% by volume
Moisture Content (H ₂ O)	21.84	% by volume	uH ₂ O	0.57	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

Sulphur Dioxide :

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uρ_b) & measured temperature of dry gas uncertainty component (uT_{m Dry})

Sulphur Dioxide :

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.932$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.93	0.93	0.0000900	0.0000225
uρ _b	0.94	0.93	0.00122	0.00459
uT _m	0.94	0.93	0.00318	0.00477
H ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.00595$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

Sulphur Dioxide :

$$V_{std} = V_{measured} \times f_s = 3.460$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty (m ³)
Effect of uV _{std}	3.48	3.44	3.71	0.0221
Effect of uV _m	3.46	3.46	0.93	0.000932

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0820$$

Uncertainty of Oxygen Correction Factor (%):-

Sulphur Dioxide :

$$f_{o_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.04$$

$$uCorr_{o_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.0260$$

$$uf_{o_2} = \frac{uCorr_{o_2}}{f_{o_2}} \times 100 = 2.51\%$$

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Determinand	Sulphur Dioxide :			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
...
Sulphur Dioxide	21.37	18.76	0.30	1.30
...

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

Determinand	Sulphur Dioxide :
	uL mg/Nm ³
...	...
Sulphur Dioxide	0.23
...	...

Uncertainty in final measurement @ Reference Conditions due to uVstp

Determinand	Sulphur Dioxide :			
	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
...
Sulphur Dioxide	20.56	19.60	5.80	0.48
...

Combined Uncertainty excluding oxygen contribution

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Determinand	Sulphur Dioxide :			
	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
...
Sulphur Dioxide	1.41	2.82	20.07	14.03
...

Combined Uncertainty including oxygen contribution

$$u_{combined} = \sqrt{\sum (uf_{O_2})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O ₂ Corr ⁿ factor (Ucombined)
...
Sulphur Dioxide	14.03	2.51	14.25
...

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Dioxins & Furans & PCBs Uncertainty

Site: Margam
 Location: Main Stack

Dioxin	Recovered Mass ng	LOD ng	LAB Method Uncert (%) %age	K=2 as Mass (ng)	Standard Uncertainty Symbol	ng
2,3,7,8 - TCDD	0.000510	0.000140	50	0.000255	u2,3,7,8 - TCDD	0.000128
1,2,3,7,8 - PCDD	0.00384	0.000440	50	0.00192	u1,2,3,7,8 - PCDD	0.000960
1,2,3,4,7,8 - HxCDD	0.00564	0.000260	30	0.00169	u1,2,3,4,7,8 - HxCDD	0.000846
1,2,3,6,7,8 - HxCDD	0.0121	0.000270	30	0.00363	u1,2,3,6,7,8 - HxCDD	0.00182
1,2,3,7,8,9 - HxCDD	0.00671	0.000260	30	0.00201	u1,2,3,7,8,9 - HxCDD	0.00101
1,2,3,4,6,7,8 - HpCDD	0.0557	0.000280	30	0.0167	u1,2,3,4,6,7,8 - HpCDD	0.00836
OCDD	0.0615	0.000410	30	0.0185	uOCDD	0.00923
2,3,7,8 - TCDF	0.0103	0.000360	30	0.00309	u2,3,7,8 - TCDF	0.00155
1,2,3,7,8 - PCDF	0.00412	0.000290	30	0.00124	u1,2,3,7,8 - PCDF	0.000618
2,3,4,7,8 - PCDF	0.00556	0.000280	30	0.00167	u2,3,4,7,8 - PCDF	0.000834
1,2,3,4,7,8 - HxCDF	0.00466	0.000220	30	0.00140	u1,2,3,4,7,8 - HxCDF	0.000699
1,2,3,6,7,8 - HxCDF	0.00546	0.000210	30	0.00164	u1,2,3,6,7,8 - HxCDF	0.000819
2,3,4,6,7,8 - HxCDF	0.00523	0.000200	30	0.00157	u2,3,4,6,7,8 - HxCDF	0.000785
1,2,3,7,8,9 - HxCDF	0.000360	0.000190	50	0.000180	u1,2,3,7,8,9 - HxCDF	0.0000900
1,2,3,4,6,7,8 - HpCDF	0.0174	0.000190	30	0.00522	u1,2,3,4,6,7,8 - HpCDF	0.00261
1,2,3,4,7,8,9 - HpCDF	0.00216	0.000220	50	0.00108	u1,2,3,4,7,8,9 - HpCDF	0.000540
OCDF	0.00469	0.000200	30	0.00141	uOCDF	0.000704

Measured Values			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	5.719	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	0.998
Meter Temperature (T _m)	288.444	K	uT _m	1.5	K
Average Differential Pressure (ΔH)	25.718	mmH ₂ O	uΔH	0.25	mmH ₂ O
Barometric Pressure (p _b)	753.059	mmHg	uP _b	3.8	mmHg
ΔH + p _s (p _m)	100.652	kPa	
Oxygen content (O _{2,m})	8.168	% by volume	uO _{2,m} = σ/√n	0.04	% by volume
Moisture Content (H ₂ O)	22.602	% by volume	uH ₂ O	0.59	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP_s) & measured temperature of dry gas

$$f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.938$$

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.938	0.938	0.0000914	0.0000228
uP _b	0.943	0.934	0.00124	0.00466
uT _m	0.943	0.933	0.00325	0.00488
H ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00618$$

Uncertainty in volume @ reference conditions due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 5.366$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
	m ³	m ³		m ³
Effect of uV _{std}	5.401	5.330	5.719	0.0353
Effect of uV _m	5.366	5.365	0.938	0.000938

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.2020$$

Uncertainty of oxygen correction factor (uO₂)

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.169 \quad uCorr^{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} =$$

$$\therefore uf_{O_2} = \frac{uCorr^{O_2}}{f_{O_2}} \times 100 = 2.83 \%$$

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Uncertainty in final dioxin measurement @ reference conditions due to mass uncertainty component (uM)

Dioxin	Maximum ng/Nm ³	Minimum ng/Nm ³	Sensitivity	uM ng/Nm ³
2,3,7,8 - TCDD	0.000139	0.0000833	0.218	0.0000278
1,2,3,7,8 - PCDD	0.00105	0.000627	0.218	0.000209
1,2,3,4,7,8 - HxCDD	0.00141	0.00104	0.218	0.000184
1,2,3,6,7,8 - HxCDD	0.00303	0.00224	0.218	0.000395
1,2,3,7,8,9 - HxCDD	0.00168	0.00124	0.218	0.000219
1,2,3,4,6,7,8 - HpCDD	0.0140	0.0103	0.218	0.00182
OCDD	0.0154	0.0114	0.218	0.00201
2,3,7,8 - TCDF	0.00258	0.00191	0.218	0.000337
1,2,3,7,8 - PCDF	0.00103	0.000763	0.218	0.000135
2,3,4,7,8 - PCDF	0.00139	0.00103	0.218	0.000182
1,2,3,4,7,8 - HxCDF	0.00117	0.000863	0.218	0.000152
1,2,3,6,7,8 - HxCDF	0.00137	0.00101	0.218	0.000178
2,3,4,6,7,8 - HxCDF	0.00131	0.000969	0.218	0.000171
1,2,3,7,8,9 - HxCDF	0.000980	0.000588	0.218	0.0000196
1,2,3,4,6,7,8 - HpCDF	0.00436	0.00322	0.218	0.000569
1,2,3,4,7,8,9 - HpCDF	0.00588	0.00353	0.218	0.000118
OCDF	0.00118	0.000869	0.218	0.000153

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss in the sample system (uL)

Dioxin	uL ng/Nm ³
2,3,7,8 - TCDD	1.283E-06
1,2,3,7,8 - PCDD	9.660E-06
1,2,3,4,7,8 - HxCDD	0.0000142
1,2,3,6,7,8 - HxCDD	0.0000304
1,2,3,7,8,9 - HxCDD	0.0000169
1,2,3,4,6,7,8 - HpCDD	0.000140
OCDD	0.000155
2,3,7,8 - TCDF	0.0000259
1,2,3,7,8 - PCDF	0.0000104
2,3,4,7,8 - PCDF	0.0000140
1,2,3,4,7,8 - HxCDF	0.0000117
1,2,3,6,7,8 - HxCDF	0.0000137
2,3,4,6,7,8 - HxCDF	0.0000132
1,2,3,7,8,9 - HxCDF	9.056E-07
1,2,3,4,6,7,8 - HpCDF	0.0000438
1,2,3,4,7,8,9 - HpCDF	5.434E-06
OCDF	0.0000118

Uncertainty in final measurement @ Reference Conditions due to uVstp

Dioxin	Maximum ng/Nm ³	Minimum ng/Nm ³	Sensitivity	uVstp mg/Nm ³
2,3,7,8 - TCDD	0.000115	0.000107	0.0000207	4.190E-06
1,2,3,7,8 - PCDD	0.000869	0.000806	0.000156	0.0000315
1,2,3,4,7,8 - HxCDD	0.00128	0.00118	0.000229	0.0000463
1,2,3,6,7,8 - HxCDD	0.00274	0.00254	0.000492	0.0000994
1,2,3,7,8,9 - HxCDD	0.00152	0.00141	0.000273	0.0000551
1,2,3,4,6,7,8 - HpCDD	0.0126	0.0117	0.00226	0.000458
OCDD	0.0139	0.0129	0.00250	0.000505
2,3,7,8 - TCDF	0.00233	0.00216	0.000419	0.0000846
1,2,3,7,8 - PCDF	0.000933	0.000865	0.000168	0.0000338
2,3,4,7,8 - PCDF	0.00126	0.00117	0.000226	0.0000457
1,2,3,4,7,8 - HxCDF	0.00105	0.000978	0.000189	0.0000383
1,2,3,6,7,8 - HxCDF	0.00124	0.00115	0.000222	0.0000449
2,3,4,6,7,8 - HxCDF	0.00118	0.00110	0.000213	0.0000430
1,2,3,7,8,9 - HxCDF	0.0000815	0.0000756	0.0000146	2.957E-06
1,2,3,4,6,7,8 - HpCDF	0.00394	0.00365	0.000708	0.000143
1,2,3,4,7,8,9 - HpCDF	0.00489	0.00454	0.000878	0.000177
OCDF	0.00106	0.000985	0.000191	0.0000385

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Dioxin	Combined Uncertainty ng/Nm ³	Expanded Uncertainty ng/Nm ³	Measured Concentration ng/Nm ³	% of Measured Concentration
2,3,7,8 - TCDD	0.0000281	0.0000562	0.000111	50.618
1,2,3,7,8 - PCDD	0.000212	0.000423	0.000837	50.618
1,2,3,4,7,8 - HxCDD	0.000191	0.000381	0.00123	31.019
1,2,3,6,7,8 - HxCDD	0.000409	0.000818	0.00264	31.019
1,2,3,7,8,9 - HxCDD	0.000227	0.000453	0.00146	31.019
1,2,3,4,6,7,8 - HpCDD	0.00188	0.00376	0.0121	31.019
OCDD	0.00208	0.00416	0.0134	31.019
2,3,7,8 - TCDF	0.000348	0.000696	0.00224	31.019
1,2,3,7,8 - PCDF	0.000139	0.000278	0.000898	31.019
2,3,4,7,8 - PCDF	0.000188	0.000376	0.00121	31.019
1,2,3,4,7,8 - HxCDF	0.000157	0.000315	0.00102	31.019
1,2,3,6,7,8 - HxCDF	0.000184	0.000369	0.00119	31.019
2,3,4,6,7,8 - HxCDF	0.000177	0.000353	0.00114	31.019
1,2,3,7,8,9 - HxCDF	0.0000199	0.0000397	0.0000784	50.618
1,2,3,4,6,7,8 - HpCDF	0.000588	0.00118	0.00379	31.019
1,2,3,4,7,8,9 - HpCDF	0.000119	0.000238	0.000471	50.618
OCDF	0.000158	0.000317	0.00102	31.019

Total (ng/Nm³) 0.045 13.2

$$u_{combined} = \sqrt{\sum (u_{f_{i,j}})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Dioxin	% of Measured Concentration	Measurement Uncertainty of Oxygen Corr Factor	Overall Measurement Uncertainty inc O ₂ Corr Factor (uCombined)	New Combined Uncertainty ng/Nm ³
2,3,7,8 - TCDD	50.618	2.830	50.697	0.0000281
1,2,3,7,8 - PCDD	50.618	2.830	50.697	0.000212
1,2,3,4,7,8 - HxCDD	31.019	2.830	31.148	0.000191
1,2,3,6,7,8 - HxCDD	31.019	2.830	31.148	0.000409
1,2,3,7,8,9 - HxCDD	31.019	2.830	31.148	0.000227
1,2,3,4,6,7,8 - HpCDD	31.019	2.830	31.148	0.00188
OCDD	31.019	2.830	31.148	0.00208
2,3,7,8 - TCDF	31.019	2.830	31.148	0.000348
1,2,3,7,8 - PCDF	31.019	2.830	31.148	0.000139
2,3,4,7,8 - PCDF	31.019	2.830	31.148	0.000188
1,2,3,4,7,8 - HxCDF	31.019	2.830	31.148	0.000157
1,2,3,6,7,8 - HxCDF	31.019	2.830	31.148	0.000184
2,3,4,6,7,8 - HxCDF	31.019	2.830	31.148	0.000177
1,2,3,7,8,9 - HxCDF	50.618	2.830	50.697	0.0000199
1,2,3,4,6,7,8 - HpCDF	31.019	2.830	31.148	0.000588
1,2,3,4,7,8,9 - HpCDF	50.618	2.830	50.697	0.000119
OCDF	31.019	2.830	31.148	0.000158

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Uncertainty - Adjusted for TEQ / TEF

Dioxin	TEQ ng/m ³	Uncertainty		WHO Humans & Mammals (TEF)	Conc		WHO Fish (TEF)	Uncertainty		Conc		WHO Birds (TEF)	Uncertainty		Conc	
		ng/Nm ³	ng/Nm ³		ng/Nm ³	ng/Nm ³		ng/Nm ³	ng/Nm ³	ng/Nm ³	ng/Nm ³		ng/Nm ³	ng/Nm ³		
2,3,7,8 - TCDD	1	0.000563	0.000111	1	0.000563	0.000111	1	0.000563	0.000111	1	0.000563	0.000111	1	0.000563	0.000111	
1,2,3,7,8 - PCDD	0.5	0.000212	0.000418	1	0.000424	0.000837	1	0.000424	0.000837	1	0.000424	0.000837	1	0.000424	0.000837	
1,2,3,4,7,8 - HxCDD	0.1	0.000382	0.000123	0.1	0.000382	0.000123	0.5	0.000191	0.000614	0.05	0.000191	0.000614	0.01	0.000191	0.000614	
1,2,3,6,7,8 - HxCDD	0.1	0.000619	0.000264	0.1	0.000619	0.000264	0.01	8.188E-06	0.000264	0.01	8.188E-06	0.000264	0.01	8.188E-06	0.000264	
1,2,3,7,8,9 - HxCDD	0.1	0.000454	0.000146	0.1	0.000454	0.000146	0.01	4.540E-06	0.000146	0.01	4.540E-06	0.000146	0.01	4.540E-06	0.000146	
1,2,3,4,6,7,8 - HpCDD	0.01	0.000377	0.000121	0.01	0.000377	0.000121	0.001	3.769E-06	0.000121	0.001	3.769E-06	0.000121	0.001	3.769E-06	0.000121	
OCDD	0.001	4.161E-06	0.000134	0.0001	4.161E-07	1.340E-06										
2,3,7,8 - TCDF	0.1	0.000697	0.000224	0.1	0.000697	0.000224	0.05	0.000348	0.000112	1	0.000697	0.000224	1	0.000697	0.000224	
1,2,3,7,8 - PCDF	0.05	0.000139	0.000449	0.05	0.000139	0.000449	0.05	0.000139	0.000449	0.1	0.000279	0.000898	0.1	0.000279	0.000898	
2,3,4,7,8 - PCDF	0.5	0.000188	0.000606	0.5	0.000188	0.000606	0.5	0.000188	0.000606	1	0.000376	0.00121	1	0.000376	0.00121	
1,2,3,4,7,8 - HxCDF	0.1	0.000315	0.000102	0.1	0.000315	0.000102	0.1	0.000315	0.000102	0.1	0.000315	0.000102	0.1	0.000315	0.000102	
1,2,3,6,7,8 - HxCDF	0.1	0.000369	0.000119	0.1	0.000369	0.000119	0.1	0.000369	0.000119	0.1	0.000369	0.000119	0.1	0.000369	0.000119	
2,3,4,6,7,8 - HxCDF	0.1	0.000354	0.000114	0.1	0.000354	0.000114	0.1	0.000354	0.000114	0.1	0.000354	0.000114	0.1	0.000354	0.000114	
1,2,3,7,8,9 - HxCDF	0.1	3.973E-06	7.843E-06	0.1	3.973E-06	7.843E-06	0.1	3.973E-06	7.843E-06	0.1	3.973E-06	7.843E-06	0.1	3.973E-06	7.843E-06	
1,2,3,4,6,7,8 - HpCDF	0.01	0.000118	0.000379	0.01	0.000118	0.000379	0.01	0.000118	0.000379	0.01	0.000118	0.000379	0.01	0.000118	0.000379	
1,2,3,4,7,8,9 - HpCDF	0.01	2.384E-06	4.706E-06	0.01	2.384E-06	4.706E-06	0.01	2.384E-06	4.706E-06	0.01	2.384E-06	4.706E-06	0.01	2.384E-06	4.706E-06	
OCDF	0.001	3.174E-07	1.022E-06	0.0001	3.174E-08	1.022E-07	0.0001	3.174E-08	1.022E-07	0.0001	3.174E-08	1.022E-07	0.0001	3.174E-08	1.022E-07	
TOTAL	...	0.000	0.002	...	0.000	0.003	...	0.001	0.003	...	0.001	0.005	...	0.001	0.005	
% Uncertainty	13.118	17.063	18.450	17.6	17.6	

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Heavy Metals Uncertainty

Site: Margam
 Location: Main Stack

$$u_{\text{phase}(mg/m^3)} = \frac{u_{\text{method}} \times \text{Mass}_{\text{fg}}}{200000} \quad u_{\text{mass}} = \sqrt{\sum (u_{\text{particulate}})^2 + (u_{\text{vapour}})^2}$$

Metal	Particulate mg	Vapour mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Standard Uncertainty of Measured	
			Particulate Phase	Vapour Phase	Particulate Phase mg/m ³	Vapour Phase mg/m ³	Symbol	mg/m ³
Antimony	12.600	1.288	15	16	0.000945	0.000103	uMSb	0.000951
Arsenic	2.100	4.743	11	12	0.000116	0.000285	uMAs	0.000307
Cadmium	0.500	0.188	12	10	0.0000300	9.410E-06	uMCD	0.0000314
Chromium	11.900	11.308	12	10	0.000714	0.000565	uMCR	0.000911
Cobalt	0.500	0.188	12	10	0.0000300	9.410E-06	uMCo	0.0000314
Copper	2.200	11.497	12	10	0.000132	0.000575	uMCu	0.000590
Lead	3.300	6.237	13	16	0.000215	0.000499	uMPb	0.000543
Manganese	5.800	1.044	16	10	0.000464	0.0000522	uMMn	0.000467
Nickel	16.900	1.260	12	9	0.00101	0.0000567	uMNI	0.00102
Thallium	0.400	0.188	14	14	0.0000280	0.0000132	uMTI	0.0000309
Vanadium	1.400	0.0941	12	9	0.0000840	4.235E-06	uMV	0.0000841

Standard Uncertainty @ 95%			
Sampled Volume (V _m)	1.072	m ³	uV _m 0.001 m ³
Meter Correction Factor (Y _d)	0.998
Meter Temperature (T _m)	295.25	K	uT _m 1.5 K
Average Differential Pressure (ΔH)	31.05	mmH ₂ O	uDH 0.25 mmH ₂ O
Barometric Pressure (P _b)	763.56	mmHg	uP _s 3.8 mmHg
ΔH + ps (P _m)	102.10	KPa	...
Oxygen content (O _{2,m})	6.66	% by volume	uO _{2,m} = σ/√n 0.03 % by volume
Moisture Content (H ₂ O)	22.58	% by volume	uH ₂ O 0.60 % by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP_s) & measured

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.930$$

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.930	0.930	0.0000893	0.0000223
uP _s	0.934	0.925	0.00121	0.00455
uT _m	0.935	0.925	0.00315	0.00472
H ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00584$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.997$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty m ³
Effect of uV _{std}	1.003	0.991	1.072	0.00627
Effect of uV _m	0.998	0.996	0.930	0.000930

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00677$$

Uncertainty of oxygen correction factor (uf_{O2})

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 0.70$$

$$uCorr_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times \text{Uncertainty of } O_2 \text{ Measurement}} = 0.03$$

$$\therefore uf_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 3.81\%$$

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Metal	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
Antimony	0.0103	0.00902	0.697	0.000663
Arsenic	0.00499	0.00456	0.697	0.000214
Cadmium	0.000502	0.000458	0.697	0.0000219
Chromium	0.0168	0.0156	0.697	0.000635
Cobalt	0.000502	0.000458	0.697	0.0000219
Copper	0.00996	0.00914	0.697	0.000411
Lead	0.00703	0.00627	0.697	0.000379
Manganese	0.00510	0.00445	0.697	0.000326
Nickel	0.0134	0.0120	0.697	0.000708
Thallium	0.000432	0.000389	0.697	0.0000216
Vanadium	0.00110	0.000983	0.697	0.0000587

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system

Metal	uL mg/Nm ³
Antimony	0.000112
Arsenic	0.0000551
Cadmium	5.543E-06
Chromium	0.000187
Cobalt	5.543E-06
Copper	0.000110
Lead	0.0000768
Manganese	0.0000551
Nickel	0.000146
Thallium	4.737E-06
Vanadium	0.0000120

Uncertainty in final measurement @ Reference Conditions due to uVstp

Metal	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
Antimony	0.00975	0.00962	0.00972	0.0000658
Arsenic	0.00481	0.00474	0.00479	0.0000324
Cadmium	0.000483	0.000477	0.000482	3.262E-06
Chromium	0.0163	0.0161	0.0162	0.000110
Cobalt	0.000483	0.000477	0.000482	3.262E-06
Copper	0.00962	0.00949	0.00958	0.0000649
Lead	0.00670	0.00661	0.00667	0.0000452
Manganese	0.00481	0.00474	0.00479	0.0000324
Nickel	0.0128	0.0126	0.0127	0.0000861
Thallium	0.000413	0.000407	0.000412	2.788E-06
Vanadium	0.00105	0.00104	0.00105	7.081E-06

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{Vstp})^2}$$

Metal	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Antimony	0.000676	0.00135	0.00969	13.949
Arsenic	0.000224	0.000447	0.00477	9.368
Cadmium	0.0000229	0.0000457	0.000480	9.522
Chromium	0.000671	0.00134	0.0162	8.293
Cobalt	0.0000229	0.0000457	0.000480	9.522
Copper	0.000431	0.000862	0.00955	9.019
Lead	0.000389	0.000778	0.00665	11.701
Manganese	0.000332	0.000664	0.00477	13.906
Nickel	0.000728	0.00146	0.0127	11.501
Thallium	0.0000223	0.0000445	0.000410	10.858
Vanadium	0.0000603	0.000121	0.00104	11.573

$$u_{combined} = \sqrt{\sum (uf_{o_2})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Metal	% of Measured Concentration	Measurement Uncertainty of Oxygen Corr ^o Factor	Overall Measurement Uncertainty inc O ₂ Corr ^o factor (U _{combined})	New Combined Uncertainty mg/Nm ³
Antimony	13.949	3.810	14.460	0.000700
Arsenic	9.368	3.810	10.113	0.000241
Cadmium	9.522	3.810	10.256	0.000025
Chromium	8.293	3.810	9.127	0.000739
Cobalt	9.522	3.810	10.256	0.000025
Copper	9.019	3.810	9.791	0.000468
Lead	11.701	3.810	12.305	0.000409
Manganese	13.906	3.810	14.419	0.000344
Nickel	11.501	3.810	12.116	0.000767
Thallium	10.858	3.810	11.507	0.000024
Vanadium	11.573	3.810	12.184	0.000063

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties (in mg/m3) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.

Environmental Compliance Limited

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Mercury Uncertainty

Site: Margam
 Location: Main Stack

$$u_{\text{phase}(mg/m^3)} = \frac{u_{\text{method}} \times \text{Mass}_{\text{Hg}}}{200000} \quad u_{\text{mass}} = \sqrt{\sum (u_{\text{particulate}})^2 + (u_{\text{vapour}})^2}$$

Metal	Particulate mg	Vapour mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Standard Uncertainty of Measured	
			Particulate Phase	Vapour Phase	Particulate Phase mg/m ³	Vapour Phase mg/m ³	Symbol	mg/m ³
Mercury	0.109	0.287	10	12	5.425E-06	0.0000172	uMHg	0.0000180

			Standard Uncertainty @ 95%		
Sampled Volume (V _m)	1.014	m ³	uV _m	0.001	m ³
Meter Correction Factor (Y _d)	0.998
Meter Temperature (T _m)	295.00	k	uT _m	1.5	k
Average Differential Pressure (ΔH)	31.20	mmH ₂ O	uDH	0.25	mmH ₂ O
Barometric Pressure (p _b)	760.56	mmHg	uP _s	3.8	mmHg
ΔH + p _s (p _m)	101.71	kPa
Oxygen content (O _{2,m})	6.60	% by volume	uO _{2,m} = σ/√n	0.02	% by volume
Moisture Content (H ₂ O)	23.65	% by volume	uH ₂ O	0.63	% by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:

$$C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty in correction factor to STP due to measured ΔH uncertainty component (uΔH), measured stack pressure uncertainty component (uP_s) & measured

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.927$$

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1$$

	Maximum	Minimum	Sensitivity	ufstp
uΔH	0.927	0.927	0.0000893	0.0000223
uP _s	0.932	0.922	0.00122	0.00456
uT _m	0.932	0.922	0.00314	0.00471
H ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00584$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.940$$

	Maximum m ³	Minimum m ³	Sensitivity	Standard Uncertainty m ³
Effect of uV _{std}	0.946	0.934	1.014	0.00592
Effect of uV _m	0.941	0.939	0.927	0.000927

Combined Standard Uncertainty

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00607$$

Uncertainty of oxygen correction factor (uf_{O2})

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 0.69$$

$$uCorr_{O_2} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Measurement} = 0.03$$

$$\therefore uf_{O_2} = \frac{uCorr_{O_2}}{f_{O_2}} \times 100 = 3.79\%$$

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM)

Metal	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uM mg/Nm ³
Mercury	0.000304	0.000277	0.736	0.0000133

Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system

Metal	uL mg/Nm ³
Mercury	3.357E-06

Uncertainty in final measurement @ Reference Conditions due to uVstp

Metal	Maximum mg/Nm ³	Minimum mg/Nm ³	Sensitivity	uVstp mg/Nm ³
Mercury	0.000293	0.000289	0.000309	1.876E-06

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Metal	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Mercury	0.0000138	0.0000276	0.000291	9.503

$$u_{combined} = \sqrt{\sum (uf_{o_2})^2 + (Uncertainty\ of\ Measurement\ of\ Determinand)^2}$$

Metal	% of Measured Concentration	Measurement Uncertainty of Oxygen Corr ⁿ Factor	Overall Measurement Uncertainty inc O ₂ Corr ⁿ factor (U _{combined})	New Combined Uncertainty mg/Nm ³
Mercury	9.503	3.790	10.231	0.000015

Note: Uncertainty for each metals group is based on the summation in quadrature of the individual standard uncertainties (in mg/m3) of each contributing metal. Combined standard uncertainty of each group is converted to 95% confidence (multiplication by k = 2) before being expressed as a percentage of the combined group concentration.

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

Stack Reference Main Stack

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (mm H ₂ O)	
Pitot Calibration Uncertainty Contribution	0.176	A
Manometer Calibration Uncertainty Contribution	0.176	B
Variation in Actual Pitot reading at sample points	0.42	C
Combined u/c (mm H ₂ O) =	Combined u/c (mm H₂O)	
SQRT (A/√3) ² + (B/√3) ² + (C/√3) ²	0.28	
Expanded Uncertainty of Flow Measurements (mm H₂O)	0.56	
	Standard u/c (K)	
Temperature Calibration (K)	2.07	D
Variation in Actual Temp reading at sample points	0.25	E
Combined u/c of Temp (K)	Combined u/c (K)	
SQRT ((D/√3) ² + (E/√3) ²)	1.20	
Expanded Uncertainty of Temp Measurements (K)	2.41	
Measured Average Velocity (m/s) at Stack Conds	24.42	
Maximum Average Velocity (m/s) at Stack Conds	24.68	
Standard Uncertainty Velocity at Stack Conditions (%)	1.08	
Expanded Uncertainty Velocity (at Stack Conditions)	2.17 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ²)
Area (m ²)	0.02011
Measured Average Flowrate (m ³ /s) at Stack Conds	49.09
Maximum Average Flowrate (m ³ /s) at Stack Conds	50.12
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.10
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	4.19 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	32.55
Maximum Average Flowrate (m ³ /s) at STP Wet	33.34
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	2.43
Expanded Uncertainty Flowrate (m³/s) at STP Wet	4.86 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Dry Gas

Contribution From	Standard u/c (%)
Moisture Uncertainty (% v/v)	0.31
Measured Average Flowrate (m ³ /s) at STP Dry	25.06
Maximum Average Flowrate (m ³ /s) at STP Dry	25.77
Standard Uncertainty Flowrate (m ³ /s) at STP Dry	2.84
Expanded Uncertainty Flowrate (m³/s) at STP Dry	5.67 (%)

Measurement Uncertainty Calculations - Flowrate at STP, Dry Gas & Ref Oxygen

Contribution From	Standard u/c (%)
Oxygen Uncertainty (% v/v)	0.068
Measured Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	23.70
Maximum Average Flowrate (m ³ /s) at STP Dry & Ref Oxygen	24.49
Standard Uncertainty Flowrate (m ³ /s) at STP Dry & Ref Oxygen	3.33
Expanded Uncertainty Flowrate (m³/s) at STP Dry & Ref O₂	6.66 (%)

Environmental Compliance Limited

Western Bio-Energy Ltd

Permit No : EPR/ZP3939GL

Variation No : V005

Report Ref : P5200 : R003

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Biomass Plant

: Compliance – January 2023

: 5th – 9th January 2023


: 16th February 2023

RESULTS OF FTIR DAILY SPECTRAL RESIDUALS CHECKS

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

Photo of Residual Check Results – N₂O (Below 5% = PASS)



Environmental Compliance Limited

Western Bio-Energy Ltd
Permit No : EPR/ZP3939GL
Variation No : V005
Report Ref : P5200 : R003

Installation Name : Biomass Plant
Visit Details : Compliance – January 2023
Survey Dates : 5th – 9th January 2023
Report Issue Date : 16th February 2023

FTIR SUMMARY OF ANALYTICAL BANDS

Western Bio-Energy Ltd
 Permit No : EPR/ZP3939GL
 Variation No : V005
 Report Ref : P5200 : R003

Installation Name : Biomass Plant
 Visit Details : Compliance – January 2023
 Survey Dates : 5th – 9th January 2023
 Report Issue Date : 16th February 2023

SUMMARY OF ANALYTICAL BANDS – PROTEA FTIR 204M

Gas Species	Primary Method Band / cm^{-1}	Secondary Method Band / cm^{-1}	Tertiary Method Band / cm^{-1}
H₂O	3319.374 – 3404.709		
CO₂	2043.693 – 2091.905 902.523 – 997.018		
CO	2132.885 – 2201.345	2021.034 – 2201.345	2021.034 – 2201.345
NO	1872.060 – 1905.326	2012.838 – 1851.329 (sub-set of smaller bands in this region)	3388.317 – 3404.709 1905.326 - 1872.060
NO₂	1548.077 – 1677.284	1605.931 - 1583.754; 2810.741 – 3160.276	2810.259 – 2936.091
N₂O	2113.600 – 2223.041	2528.703 – 2651.160 2113.600 – 2223.041	
SO₂	1295.448 – 1414.531	3388.317 – 3404.709 1342.695 – 1360.052 1019.195 – 1233.737	2810.259 – 2936.091
NH₃	899.148 – 969.055		
HCl	2587.521 – 2884.023	2587.521 – 2884.023	