

Jan 2023

Day	Downtime	Availability	Rationale
1	0	100.00%	
2	0	100.00%	
3	0	100.00%	
4	0	100.00%	
5	0	100.00%	
6	0	100.00%	
7	0	100.00%	
8	0	100.00%	
9	0	100.00%	
10	0	100.00%	
11	0	100.00%	
12	0	100.00%	
13	0	100.00%	
14	0	100.00%	
15	0	100.00%	
16	0	100.00%	
17	0	100.00%	
18	0	100.00%	
19	0	100.00%	
20	4.5	81.25%	Wet Ash Conveyor overwhelmed due to under grate ash hopper bridging
21	16	33.33%	Unit start up following unblocking of wet ash system
22	0	100.00%	
23	0	100.00%	
24	0	100.00%	
25	0	100.00%	
26	2.5	89.58%	Plant trip due to Boiler PLC
27	0	100.00%	
28	0	100.00%	
29	0	100.00%	
30	0	100.00%	
31	0	100.00%	
Month	23	96.91%	