

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BB4018701

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at STORMY DOWN STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent: **Name:**
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):
Address:

Post Code:

Date of Transfer to new Holder(s);

Signed: **Dated:**

Name (block capitals): **Position:**



1740

Alan Jones

SW 73

WEPD/S2/23/D7

BB 4018701

WO REF WEP/WS 9112/88

WELSH OFFICE

CONTROL OF POLLUTION ACT 1974: SECTIONS 34 AND 55
THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES) REGULATIONS 1984
CONSENT FOR A DISCHARGE

1. The Welsh Water Authority (hereinafter referred to as 'the Water Authority') proposes to discharge sewage effluent from the Stormy Down Sewage Treatment Works to the ground at National Grid Reference SS 8467 7975 in accordance with the application dated 27 May 1988.
2. The proposal requires the consent of the Secretary of State for Wales in pursuance of sections 34 and 55 of the Control of Pollution Act 1974 and the Control of Pollution (Discharges by Authorities) Regulations 1984.
3. THE SECRETARY OF STATE FOR WALES hereby consents to the proposed discharge.

Dated this 27 day of June 1988

Signed [A. S. PEARCE]
on behalf of the Secretary
of State for Wales

BBU() 18 / 0

No. 4-187

(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)

CT, 1951
Water Res. Act 1973. 5/375
CAT. NO. R.B.12 SHAW & SONS LTD., FETTER LANE, E.C.4.

CAT. NO. R.B.12 SHAW & SONS LTD., FETTER LANE, E.C.4.

* IF DISCHARGE NOT CONTROLLED UNDER S.7 OF 1951 ACT

FRESH OFFICE REF:

PLAN 300A 3
(MINE 1983)

NWA HQ REF: 88 4019701

THE CONTROL OF POLLUTION ACT 1974: SECTION 34
 THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES)
 REGULATIONS 1984 (SI 1984 NO. 1300)

CERTIFICATE TO BE SUBMITTED WITH A REQUEST FOR A
 DESCRIPTIVE DISCHARGE CONSENT
 REID BED

As the Fresh Water Authority we certify that, in respect of the
 discharge from the Authority's sewage treatment works at Stirmy Down
 (National Grid Reference: 114000 220000)

1. The effluent derives from domestic sewage from a population of 250
 or less and contains no authorised trade waste.
2. There are no potable water supply intakes downstream which are likely to be
 adversely affected.
3. As far as is reasonably practicable, the works shall be operated so as to
 prevent:
 - a. any matter being present in the effluent which will cause the
 receiving water to be poisonous or injurious to fish or to their spawn
 or spawning grounds or food or otherwise cause damage to the quality
 of the receiving water; and
 - b. the overall effluent from having any adverse visual and
 environmental impact.
4. The Authority shall operate the works such as to:-
 - a. maintain and develop the reed growth until full cover of the bed is
 achieved
 - b. ensure that the sewage flow does not by-pass the reed bed
 - c. prevent the short circuit by overlaid sewage flow and ensure efficient
 distribution of sewage bed.

[Signature]
 Divisional Pollution Manager

[Signature]
 District Engineer

1756

88 40187 01

WELSH OFFICE REF:

FORM COPA 3
(JUNE 1988)

WWA HQ REF: 88 4018701

THE CONTROL OF POLLUTION ACT 1974: SECTION 34
THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES)
REGULATIONS 1984 (SI 1984 NO. 1200)

CERTIFICATE TO BE SUBMITTED WITH A REQUEST FOR A
DESCRIPTIVE DISCHARGE CONSENT
REED BED

On behalf of the Welsh Water Authority we certify that, in respect of the discharge from the Authority's sewage treatment works at Stormy Down
 (National Grid Reference ST 827725)

1. The effluent derives from domestic sewage from a population of 250 or less and contains no authorised trade waste.
2. There are no potable water supply intakes downstream which are likely to be adversely affected.
3. As far as is reasonably practicable, the works shall be operated so as to prevent:
 - a. any matter being present in the effluent which will cause the receiving water to be poisonous or injurious to fish or to their spawning or spawning grounds or food or otherwise cause damage to the ecology of the receiving waters; and
 - b. the treated effluent from having any adverse visual and environmental impact.
4. The Authority shall operate the works such as to:
 - a. maintain and develop the reed growth until full cover of the bed is achieved.
 - b. ensure that the sewage flow does not by-pass the reed.
 - c. prevent the short circuit by overlaid sewage flow and ensure effective distribution of sewage load.

[Signature]
 Divisional Operations Manager

[Signature]
 District Officer

Issued on 12/12/90 at Cardiff