

| SCHEDULE 5 Notification      |                   |
|------------------------------|-------------------|
| <b>Part A</b>                |                   |
| Permit Number:               | BL7108IM          |
| Name of Operator:            | Tata Steel UK Ltd |
| Location of Facility:        | Port Talbot Works |
| Time & Date of the Detection | 24/05/2023        |

| (b) Notification requirements for breach of a permit condition |                                                                                                                                |
|----------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|
| Emission point/reference source                                | A39 Number 1 New Mill Stack (GCI)                                                                                              |
| Parameter(s)                                                   | Particulate                                                                                                                    |
| Limit                                                          | Bi-annual spot monitoring of 20 mg/m <sup>3</sup>                                                                              |
| Measured value and uncertainty                                 | 336.6 mg/m <sup>3</sup><br>Uncertainty 12.2 mg/Nm <sup>3</sup><br><br>Measured value minus uncertainty 324.4 mg/m <sup>3</sup> |
| Date and time of monitoring                                    | 17/05/2023<br>11:41 – 14:24                                                                                                    |
| Measures taken, or intended to be taken, to stop the emission  | A Management Investigation will be instigated to determine reasons for consecutive breaches                                    |
| REF: S5N/23/27A                                                |                                                                                                                                |