

SCHEDULE 5 Notification	
Part A	
Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Time & Date of the Detection	10/07/2023 08:00am

(b) Notification requirements for breach of a permit condition	
Emission point/reference source	A52A Boiler 6 (Margam C) stack
Parameter(s)	NO _x
Limit	Daily fuel-weighted dynamic emission limits 01 st April: 285.7mg/m ³ 08 th April: 297.7 mg/m ³ 10 th April: 311.6 mg/m ³
Measured value and uncertainty	Daily average 1 st April: 334.7 mg/m ³ 8 th April: 466.2 mg/m ³ 10 th April: 342.5 mg/m ³ 95% confidence level has already been subtracted from measured results – permit condition 3.6.7 (a)
Date and time of monitoring	Daily means from continuous emission monitoring 01 st April 2023: 00:00 to 23:59 08 th April 2023: 00:00 to 23:59 10 th April 2023: 00:00 to 23:59
Measures taken, or intended to be taken, to stop the emission	No abatement of NO _x emissions from boiler stacks.
REF: S5N/23/38A	