

Permit Number: EPR/BV9683IH

Operator: Dunbia (UK)

Facility: Teify Park Abattoir and Meat Processing Plant

Form Number: Q2 Water

Reporting of emissions to water (other than to sewer) and land for the period from 01/04/2023 to 30/06/2023

Emission Point	Substance / Parameter	Emission		Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value						
W2	Total suspended solids	50 mg/l		24 hour flow	49.8 mg/l	HMSO ISBN 011751957X	11/04/2023	13.4%
W2	pH	6-9		24 hour flow	7.7 – Min 8.3 – Max	On-line pH electrode/ meter	11/04/2023 27/06/2023	9%
W2	BOD	30 mg/l		24 hour flow	5.74 mg/l	BS 6068-250:1995	11/04/2023	16%
W2	Ammonia	10mg/l		24 hour flow	0.49 mg/l	BSENISO 11732:1997	06/06/2023	6.6%
W2	Volume/flow rate	630m ³ /day		24 hour flow	364 m ³ /day - Max	On-line flow meter	10/05/2023	-

The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases, the principal technique is stated, for example gas chromatography.

For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

Signed
(Authorised to sign as representative of Operator)

Date... 10/07/2023