

May 2023

| Day | Downtime | Availability | Rationale |
|--------------|-------------|---------------|--|
| 1 | 0 | 100.00% | |
| 2 | 0 | 100.00% | |
| 3 | 1.5 | 93.75% | Boiler PLC stop, Turbine trip |
| 4 | 0 | 100.00% | |
| 5 | 0 | 100.00% | |
| 6 | 0 | 100.00% | |
| 7 | 0 | 100.00% | |
| 8 | 0 | 100.00% | |
| 9 | 0 | 100.00% | |
| 10 | 0 | 100.00% | |
| 11 | 1 | 95.83% | Turbine trip twice CBISS calibration trip, Gland steam condenser vent fan trip |
| 12 | 0 | 100.00% | |
| 13 | 0 | 100.00% | |
| 14 | 0 | 100.00% | |
| 15 | 0 | 100.00% | |
| 16 | 0.5 | 97.92% | Condensate high level trip, turbine trip, condensate low pressure |
| 17 | 6 | 75.00% | WPD outage turbine tripped, MSV auto drain failed to operate |
| 18 | 0 | 100.00% | |
| 19 | 0 | 100.00% | |
| 20 | 0 | 100.00% | |
| 21 | 0 | 100.00% | |
| 22 | 0 | 100.00% | |
| 23 | 0 | 100.00% | |
| 24 | 0 | 100.00% | |
| 25 | 0 | 100.00% | |
| 26 | 0 | 100.00% | |
| 27 | 1 | 95.83% | Turbine tripped twice, high high live steam temp |
| 28 | 11.5 | 52.08% | Turbine tripped twice, condensate high level due to HP turbine casing valve open |
| 29 | 0 | 100.00% | |
| 30 | 0 | 100.00% | |
| 31 | 0 | 100.00% | |
| Month | 21.5 | 97.11% | |