

June 2023

Day	Downtime	Availability	Rationale
1	0	100.00%	
2	0	100.00%	
3	0	100.00%	
4	0	100.00%	
5	0	100.00%	
6	0	100.00%	
7	7.5	68.75%	Turbine Trip, high live steam temp, Turbine restarted, 2nd trip due to tube leak
8	24	0.00%	Plant offline for Superheater 2 tube repairs
9	24	0.00%	
10	24	0.00%	
11	24	0.00%	
12	24	0.00%	
13	7	70.83%	Plant startup
14	0	100.00%	
15	0	100.00%	
16	0	100.00%	
17	0	100.00%	
18	0	100.00%	
19	0	100.00%	
20	4	83.33%	Turbine Tripped due to water hammering
21	0	100.00%	
22	0	100.00%	
23	0	100.00%	
24	0	100.00%	
25	0	100.00%	
26	7.5	68.75%	Large condensate swings, turbine trip due to tube leak
27	24	0.00%	Plant off line for Superheater 1 & 2 tube repairs
28	24	0.00%	
29	24	0.00%	
30	24	0.00%	
Month	242	66.39%	