

Permit Number: EPR/EP3935UC Operator: Real Alloy UK limited

Facility: Waunarlwydd Works Form Number: Air Q2 30/06/23

Reporting of emissions to air for the period from 1/04/2023 to 30/6/2023

Emission Point	Substance / Parameter	Emission		Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value						
A4	Particulate Matter	5 mg/m ³	Continuous	1.3	BS EN 13284-1 and MID	25 th April 2023 ; 13.00-16.00	0.13	
	Oxides of Nitrogen (as NO ₂)	60 mg/m ³	Average extractive sample		BS EN 14792 and MID			
	Hydrogen chloride	10 mg/m ³	Average extractive sample	0.03	BS EN 1911	25 th April 2023; 13.00-16.00	0.001	
	Volatile Organic Compounds	30 mg/m ³	Average extractive sample	10.4	BS EN 12619	25 th April 2023; 13.00-	0.48	
	Sulphur dioxide	50 mg/m ³	Average extractive sample	7.9	BS EN 14791	25 th April 2023; 13.00-16.00	0.43	
	Hydrogen fluoride	1 mg/m ³	Periodic over minimum 1 hr period		BS ISO 15713 and MID			
	Dioxins (ITEQ)	0.1 ng/m ³	Periodic minimum 6 hours, maximum 8 hour period		BS EN 1948 Parts 1, 2 and 3 and MID			
	Particulate Matter	4500 kg/year	Annual total					

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the ‘minimum – maximum’ measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed *Walter Ullrich*
(Authorised to sign as representative of Operator)

Date *29/6/2023*