Date	Suspended solids	Dissolved solids	Oil and grease	Copper	Pb	Sn	Zn	Al	Mercury	Arsenic	Ni	Nitrogen	pH max	pH min	Comments
30.4.2023	4	1350	1	0.0059	0.0003	0.0015	0.016	0.37	0.00001	0.00091	0.001	4.3	6.3	6.3	Schedule 5 submitted 19.5.2023 when results received from laboratory.
31.5.2023															Exceptionally dry weather; unable to obtain sufficient quantity for lab to sample.
30.6.2023															Prolonged hot and dry weather with no rain; unable to obtain sample.
Limit	50	1200	10	0.25	0.1	0.1	0.5	1.5	0.075	0.1	0.5	1.5	9	6	

Swan Alloy UK Ltd
Westfield Industrial Park
Waunarlwydd
SWANSEA
SA5 4SF

EP3935UC
Q2 2023