

Planned or unplanned outage of abatement equipment

Permit Number	EPR/BL7108IM
Name of operator	Tata Steel
Location of Facility	Port Talbot Steel Works
Date & time of when the planned or unplanned outage commence (Please state if planned or unplanned)	11/08/2023 Unplanned

(PART A)	
Reference or description of the location of the event	A63 CASOB/Desulph Fume Extraction Plant
Reason for the outage	Cracks on the impeller following non-destructive testing
Immediate action taken to mitigate environment incident (if applicable)	
Has the abatement equipment been reinstated? (If yes state date and time)	Yes 25/08/2023 @ 14:00
If no confirm planned date to reinstate abatement equipment	
Is further correspondence required to notify NRW that the abatement equipment has been reinstated?	No
Reference	A63 BOS 108_110823
(PART B) Any more accurate information on the matters notified under Part A (Specifically if the outage of the abatement equipment has increased)	N/A
Date abatement equipment returned to service	25/08/2023
Name	Nicola Parnell
Post	Environment Lead, UK ETS & Air Quality
Signature	
Date	29/08/2023
Reference	A63 BOS 108_110823