

SCHEDULE 5 Notification	
Part A	
Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Time & Date of the Detection	04/09/2023 11:00am

(b) Notification requirements for breach of a permit condition	
Emission point/reference source	A50 Service Boilers 4&5 stack
Parameter(s)	SO ₂
Limit	Daily fuel-weighted dynamic emission limits 11 th August: 290.9mg/m ³ 23 rd August: 309.4 mg/m ³ 30 th August: 304.8 mg/m ³
Measured value and uncertainty	Daily average 11 th August: 319.7mg/m ³ (only 2 hours of normal operating conditions) 23 rd August: 329.3 mg/m ³ (only 14 hours of normal operating conditions) 30 th August: 305.6 mg/m ³ (23 hours of normal operating conditions) 95% confidence level has already been subtracted from measured results – permit condition 3.6.7 (a)
Date and time of monitoring	Daily means from continuous emission monitoring 11 th August 2023: 00:00 to 23:59 23 rd August 2023: 00:00 to 23:59 30 th August 2023: 00:00 to 23:59
Measures taken, or intended to be taken, to stop the emission	No abatement of SO ₂ emissions from service boiler stacks.
REF: S5N/23/51A	