

Notice of variation with introductory note

The Environmental Permitting (England & Wales) Regulations 2010

Dŵr Cymru Cyfyngedig

Aberdyfi Wharf Sewage Pumping Station
Sea View Terrace
Aberdyfi
Gwynedd

Variation application number
CG0351301/V001

Permit number
CG0351301/V001

Aberdyfi Wharf Sewage Pumping Station

Permit number CG0351301

Introductory note

This introductory note does not form a part of the notice

The following notice gives notice of the variation of an environmental permit.

This notice represents an Environment Agency initiated variation to remove condition 9 relating to 3 spills.

The schedules specify the changes made to the original permit.

The status log of a permit sets out the permitting history, including any changes to the permit reference number. It is not backdated before 6 April 2010.

Status log of the permit

Description	Date	Comments
Permit varied CG0351301	31/03/2010	Modification issued to add AMP5 requirement, conditions 9 and 10
Regulator initiated variation CG0351301/V001	31/08/2012	EA initiated variation to remove condition 9

End of introductory note

Notice of variation

The Environmental Permitting (England and Wales) Regulations 2010

The Environment Agency in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2010 varies

permit number
CG0351301

issued to:
Dwr Cymru Cyfyngedig (“the operator”)

whose registered office is

Pentwyn Road
Nelson
Treharris
CF64 6LY

company registration number 02366777

to operate regulated facilities
at

Aberdyfi Wharf Sewage Pumping Station
Sea View Terrace
Aberdyfi
Gwynedd

to the extent set out in the schedules.

The notice shall take effect from 31/08/2012

Name

Date

Eleanor Smart

31/08/2012

Authorised on behalf of the Environment Agency

Schedule 1 – conditions to be deleted

The following conditions are deleted following an Environment Agency initiated variation:

9.

(a) The combined sewer overflow shall be designed to ensure that there shall be no more than 3 spills per bathing season (i.e May to September inclusive) on average over a ten year period.

A spill is defined as follows:

One or more overflow events of total volume greater than 50m³/d within a period of 12 hours or less will be considered to be one spill.

One or more of such overflow events (extending over a period of greater than 12 hours up to 36 hours will be considered to be 2 spills. Each subsequent 24 hour duration of such overflow events counts as 1 additional spill.

(b) The combined sewer overflow shall be constructed and operated in accordance with the design.

(c) At the request of the Agency, the consent holder shall provide calculations and evidence to confirm that the combined sewer overflow is designed and constructed in accordance with conditions (a) and (b) above

Schedule 2 – conditions to be amended

None.

Schedule 3 – conditions to be added

None.