

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/KP3195FW
Name of operator	Sims Group UK Limited
Location of Facility	Northside, South Dock, Alexandra Dock, Newport, NP20 2WE
Time and date of the detection	Date of sampling - 29/05/2019

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment

To be notified Immediately	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a permit condition

To be notified immediately	
Emission point reference/ source	Fridge Plant 1 emission to air (point 3, schedule 7)
Parameter(s)	CFC
Limit	5g/hr
Measured value and uncertainty	9.45g/hr
Date and time of monitoring	29/05/2019
Measures taken, or intended to be taken, to stop the emission	An investigation has been undertaken to determine the cause of the elevation. The online plant readings were within normal parameters, and again a full inspection of the plant did not identify any operational issues that could be attributed to the elevation. In light of the above, the online gas sampling unit has been exchanged for a new unit, with no discernible change to readings. We have instructed MTD to take additional samples next week, with results to be back Monday 8th July. We will keep you informed of the outcome of the above as soon as possible.

Time periods for notification following detection of a breach of a limit

Parameter	Notification period

--	--

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:

To be notified immediately	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Wayne Taylor
Post	Site Manager
Signature	W Taylor
Date	27/06/2019

* authorised to sign on behalf of the operator