

CONSENT NO.	CG0110901
--------------------	------------------



**ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales**

**WATER RESOURCES ACT 1991
SECTION 88 - SCHEDULE 10
(AS AMENDED BY THE ENVIRONMENT ACT 1995)
NOTICE OF MODIFICATION OF CONSENT TO DISCHARGE**

**TO: Dŵr Cymru Cyf
Pentwyn Road
Nelson
Treharris
Mid Glamorgan
CH46 6LY**

WHEREAS the **ENVIRONMENT AGENCY** in pursuance of its powers under Schedule 10 to the Water Resources Act 1991 granted on 17th day of July 1987 CG0110901 permitting the discharge of **TREATED SEWAGE EFFLUENT**

FROM: LLANFACHRETH STW

AT: SH 75370 22340

TO: Afon Y Llan

NOTICE IS HEREBY given by the **ENVIRONMENT AGENCY** that, following the publication of the PR04 agreed programme for sewerage undertakers in England and Wales, and in pursuance of its powers under the paragraph 7(2) of Schedule 10 to the Water Resources Act 1991, the said Consent is **MODIFIED** as follows:

A. Substitution of condition 7 attached to CG0110901 by the following new condition:

7. Treated Sewage Effluent:

The limits set out below may be exceeded where, in any series of samples taken in the period of 12 months ending on the date of the discharge, as listed in column 1 of Annex 1 attached to this consent no more than the relevant number of samples, as listed in Column 2 of the said Annex, exceeds the applicable limit for that determinant at the time when a sample is taken.

- (i) The biological oxygen demand (ATU) in 5 days at 20°C shall not exceed 40 milligrams per litre
- (ii) The suspended solids dried at 105°C shall not exceed 60 milligrams per litre.
- (iii) The ammonical nitrogen (expressed as N) shall not exceed 35 milligrams per litre.

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 to the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of modifications made by this notice, without the agreement in writing of the Consent Holder, during a period of 4 years from the date this notice is served.





This modification is served on 31st March 2005
This modification takes effect on 31st day of December 2005

Signed *Iwan Williams*
Iwan Williams
Regulatory Team Leader (Water Quality)

NOTE. All other conditions of this consent remain unaltered and in force. This notice of modification should be read in conjunction with, CG0110901

CONSENT AMENDMENTS

CONSENT NO	SCHEDULE NO	DATE MODIFICATION ISSUED
CG0110901		31 st March 2005
CONDITIONS : UNCHANGED		
1, 2, 3, 4, 5, 6, 8, 9,		
CONDITIONS: MODIFIED		DATE ON WHICH NEW OR REVISED CONDITIONS COME INTO FORCE
7		31 st day of December 2005

