
Summary of Odour Control Unit Monitoring Results

Site Name: Bryn Pica

Date: 30/08/2023

Unit:	Carbon Filter		
	Odour (ouE/m³)	Ammonia (mg/m³)	Hydrogen Sulphide (mg/m³)
Inlet Result	18830	0.76	1.87
Outlet Result	273	0.68	1.32
Efficiency (%)	99	11	29