

Planned or unplanned outage of abatement equipment

Permit Number	EPR/BL7108IM
Name of operator	Tata Steel
Location of Facility	Port Talbot Steel Works
Date & time of when the planned or unplanned outage commence (Please state if planned or unplanned)	27/09/2023 @ 03:10 Unplanned

(PART A)	
Reference or description of the location of the event	A56 Minister Stein Morfa Coke Ovens Hood
Reason for the outage	2 x ovens pushed off the hood due to guide door electrical faults and brake unit failure on No.3 guide
Immediate action taken to mitigate environment incident (if applicable)	
Has the abatement equipment been reinstated? (If yes state date and time)	Yes, 27/09/2023 @ 03:30
If no confirm planned date to reinstate abatement equipment	
Is further correspondence required to notify NRW that the abatement equipment has been reinstated?	No
Reference	A56 MCO 127_270923
(PART B) Any more accurate information on the matters notified under Part A (Specifically if the outage of the abatement equipment has increased)	
Date abatement equipment returned to service	27/09/2023
Name	Freya Ashton
Post	Environment Higher Apprentice, UK ETS
Signature	
Date	27/09/2023
Reference	A56 MCO 127_270923