



Cyfoeth Naturiol Cymru Natural Resources Wales

Energy Build Limited
Aberpergwm Colliery
Engine Cottage Site
Glynneath
Neath
SA11 5EW

Ein cyf / Our ref: BP0299101 181112 Sample
Exceedance

Eich cyf / Your ref:

Dyddiad/Date: 29th November 2018

Dear Sir / Madam,

**Environment Permitting (England and Wales) Regulations 2010
Failure to Comply with Consent Condition 8(i) of Discharge Consent BP0299101
Sample taken from New Aberpergwm Colliery Surface Water Discharge on the 12th
November 2018**

The attached analytical report indicates that samples taken on the 12th November 2018 from the New Aberpergwm Surface Water discharge for which you hold the consent, exceeded the permitted limits.

These results, together with all other results taken for the purpose of consent monitoring, will form part of the public register held by Natural Resources Wales and are available for inspection by any member of the public.

Please let me know within **fourteen** days the reason for these failures and the steps that you intend to take or have taken to prevent recurrence. I shall have regard to your response when determining what further action Natural Resources Wales may take to ensure compliance with the consent.

Please ensure that the person responding on behalf of Energy Build Limited is authorised or has been authorised to respond on behalf of the company and that this is also stated in the response.

Yours sincerely

Angharad Clark
Environment Officer

Deialu uniongyrchol/Direct dial 0300 065 3216

E-bost uniongyrchol/Direct e-mail

angharad.clark@cyfoethnaturiolcymru.gov.uk / angharad.clark@naturalresourceswales.gov.uk

Enc. Analytical Report for samples taken on 12th November 2018

NEW ABERPERGWM COLLIERY SUR' WATER DIS

Sample Point: 78396

Date: 12/11/2018 Time: 11:49

Reason: CF Sampler: P683 – KATE THOMAS

0135/Sld Sus@105C

Result: 121 mg/l

Permit Limit: 80 mg/l