

SCHEDULE 5 Notification	
Part A	
Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Time & Date of the Detection	02/10/2023 11:00am

(b) Notification requirements for breach of a permit condition	
Emission point/reference source	A52B Boiler 7 (Margam C) stack
Parameter(s)	SO ₂
Limit	Daily fuel-weighted dynamic emission limits 7 th September 2023: 104.6mg/m ³ 17 th September 2023: 69.4 mg/m ³
Measured value and uncertainty	Daily average 7 th September: 127.6mg/m ³ (only 10 hours of normal operating conditions) 17 th September: 136.7 mg/m ³ (only 1 hour of normal operating conditions) 95% confidence level has already been subtracted from measured results – permit condition 3.6.7 (a)
Date and time of monitoring	Daily means from continuous emission monitoring 7 th September 2023: 00:00 to 23:59 17 th September 2023: 00:00 to 23:59
Measures taken, or intended to be taken, to stop the emission	No abatement of SO ₂ emissions from service boiler stacks.
REF: S5N/23/57A	