



ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales

**ENVIRONMENT AGENCY WALES
NORTHERN AREA
CONSENT REVIEW 2004**

UWWTD

[URBAN WASTE WATER TREATMENT DIRECTIVE 1991]

FILE NOTE

A snapshot of WRA 91 Discharge Consents qualifying for review under UWWTD was extracted from WIMS (EA electronic Public Register) on the 21st April 2004. All details shown on this file note are based on the permission extant as of this date.

CONSENT REF :	CG0024101	VERSION :	2		
OPERATOR :	DWR CYMRU CYFYNGEDIG				
DISCHARGE SITE :	RHYD DDU STW				
EXTANT CONSENT ISSUE DATE :	03/09/1987	EFFECTIVE DATE :	03/09/1987		
DWF (m ³ /day) :	14.5	MAX DAILY VOL. (m ³ /day) :	UNSPECIFIED	RATE (l/s) :	

Records held on WIMS show RHYD DDU STW (CG0024101) to be extant under version 2 issued 03/09/1987 with descriptive consent conditions, effective 03/09/1987. The works is currently consented to discharge a max daily volume of UNSPECIFIEDm³/day effluent to the GWYRFAI at NGR SH5705053080.

UWWTD directive aims to deliver a standard level of sewage treatment throughout EC member states. This has been interpreted as prescribing a minimum of secondary biological treatment (package plant or equivalent) on all discharges made to a controlled surface water; or a minimum of primary (septic tank or equivalent) treatment on all discharges made to ground.

The discharge of UNSPECIFIEDm³/day effluent to 'GWYRFAI', for the purposes of this review, is described as 'secondary treated effluent to surface waters'. This treatment / receiving water combination has been assessed* as APPROPRIATE under the UWWTD review. This consent is reviewed as APPROPRIATE under UWWTD as of 01/09/2005.

* NB: the assessment of this Discharge Consent to meet UWWTD 'appropriate treatment' criteria is based solely on provision of the appropriate 'threshold' level of minimum treatment for the receiving medium. This review does not assess appropriateness in terms of the specific river needs of the receiving water stretch.

Iwan Williams
Regulatory Team Leader (Water Quality)