

**RELEASES TO AIR
QUARTERLY RETURN
MONTHLY MEAN, MAXIMUM DAILY MEAN AND ANNUAL PERCENTILE CONCENTRATIONS
OPERATING MODE:**

Operator: Dow Silicones UK Ltd
Location: Barry Cogeneration Plant
Permit/Variation Number: EPR/JP3632ZH/V002

Form: IED CON 2 (Gas Turbines)
Version/date: V.3.1 31 Dec 2015

Year: 2019	A1 / LCP 60					
	NOx (mg/m3)			CO (mg/m3)		
Month	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean
January	-	-		-	-	-
February	-	-		-	-	-
March	-	-		-	-	-
April	68.	69.67		4.7	4.8	10.7
May	60.11	77.84		10.4	17.2	52.2
June	61.97	74.63		7.7	12.6	34.4
July						
August						
September						
October						
November						
December						
Monthly ELV / Daily ELV (f)	125.	125.		80.	80.	80.
Annual 95th Percentile (h)	72.08(61)			19.7(61)		
Annual Percentile ELV (g)	125.			80.		

NOTES:

- (a) All data based on validated hourly average concentrations, excluding start-up and shut-down and periods of malfunction or breakdown of abatement equipment, at 15% O₂, dry, 273.15K, 101.325 kPa
- (b) Annual percentiles are submitted with the final return (Quarter 4)
- (c) Extend report to cover the required number of LCP on each site and repeat report for each separately regulated Operating Mode as required, e.g., Combined Cycle, Open Cycle, Supplementary firing, Auxiliary firing
- (d) Averages determined at loads in the range 70% < Load ≤ 100% ISO base load and above
- (e) Averages determined at loads in the range MSUL* < Load = 100% ISO base load and above (* For a 3 parameter approach, from the point of Start-Up to the point of Shut-down)
- (f) Leave the Daily ELV blank if this is applied as a 95th percentile ELV within the Permit
- (g) For each pollutant, report the Annual 95th percentile ELV for hourly averages in the first column and, if applicable, the Annual 95th percentile ELV for daily means in the second column
- (h) For each pollutant, report the Annual 95th percentile of hourly averages in the first column and, if applicable, the Annual 95th percentile of daily means in the second column

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

10th July 2019

No confidence adjustment

**RELEASES TO AIR
QUARTERLY RETURN
MONTHLY MEAN, MAXIMUM DAILY MEAN AND ANNUAL PERCENTILE CONCENTRATIONS
OPERATING MODE:**

Operator: Dow Silicones UK Ltd
Location: Barry Cogeneration Plant
Permit/Variation Number: EPR/JP3632ZH/V002

Form: IED CON 2 (Gas Turbines)
Version/date: V.3.1 31 Dec 2015

Year: 2019	A2 / LCP60					
	NOx (mg/m3)			CO (mg/m3)		
Month	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean
January	211.88	224.43		11.6	27.9	
February	209.22	219.43		11.3	17.6	
March	206.89	222.76		13.3	23.8	
April	207.44	215.86		10.5	12.6	
May	201.8	231.13		8.5	11.2	
June	197.68	213.81		8	9	
July						
August						
September						
October						
November						
December						
Monthly ELV / Daily ELV (f)	250.	250.		100.	110.	
Annual 95th Percentile (h)	223.36(112)			25.1(112)		
Annual Percentile ELV (g)	250.			200.		

NOTES:

- (a) All data based on validated hourly average concentrations, excluding start-up and shut-down and periods of malfunction or breakdown of abatement equipment, at 15% O₂, dry, 273.15K, 101.325 kPa
- (b) Annual percentiles are submitted with the final return (Quarter 4)
- (c) Extend report to cover the required number of LCP on each site and repeat report for each separately regulated Operating Mode as required, e.g., Combined Cycle, Open Cycle, Supplementary firing, Auxiliary firing
- (d) Averages determined at loads in the range 70% < Load ≤ 100% ISO base load and above
- (e) Averages determined at loads in the range MSUL* < Load = 100% ISO base load and above (* For a 3 parameter approach, from the point of Start-Up to the point of Shut-down)
- (f) Leave the Daily ELV blank if this is applied as a 95th percentile ELV within the Permit
- (g) For each pollutant, report the Annual 95th percentile ELV for hourly averages in the first column and, if applicable, the Annual 95th percentile ELV for daily means in the second column
- (h) For each pollutant, report the Annual 95th percentile of hourly averages in the first column and, if applicable, the Annual 95th percentile of daily means in the second column

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

10th July 2019

No confidence adjustment

**RELEASES TO AIR
QUARTERLY RETURN
MONTHLY MEAN, MAXIMUM DAILY MEAN AND ANNUAL PERCENTILE CONCENTRATIONS
OPERATING MODE:**

Operator: **Dow Silicones UK Ltd**
Location: **Barry Cogeneration Plant**
Permit/Variation Number: **EPR/JP3632ZH/V002**

Form: IED CON 2 (Gas Turbines)
Version/date: **V.3.1 31 Dec 2015**

Year: 2019	A3 / LCP60					
	NOx (mg/m3)			CO (mg/m3)		
Month	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean
January	75.73	80.86		0.6	4.1	4.1
February	74.79	78.71		0.3	4.1	9.4
March	74.67	80.75		0.3	3.7	3.7
April	75.31	78.58		0	0	1.3
May	49.15	69.96		5.6	20.1	23.1
June	54.32	73.61		2.6	11.3	35.5
July						
August						
September						
October						
November						
December						
Monthly ELV / Daily ELV (f)	125.	125.		80.	80.	80.
Annual 95th Percentile (h)	79.90(168)			10.6(168)		
Annual Percentile ELV (g)	125.			80.		

NOTES:

- (a) All data based on validated hourly average concentrations, excluding start-up and shut-down and periods of malfunction or breakdown of abatement equipment, at 15% O₂, dry, 273.15K, 101.325 kPa
- (b) Annual percentiles are submitted with the final return (Quarter 4)
- (c) Extend report to cover the required number of LCP on each site and repeat report for each separately regulated Operating Mode as required, e.g., Combined Cycle, Open Cycle, Supplementary firing, Auxiliary firing
- (d) Averages determined at loads in the range 70% < Load ≤ 100% ISO base load and above
- (e) Averages determined at loads in the range MSUL* < Load = 100% ISO base load and above (* For a 3 parameter approach, from the point of Start-Up to the point of Shut-down)
- (f) Leave the Daily ELV blank if this is applied as a 95th percentile ELV within the Permit
- (g) For each pollutant, report the Annual 95th percentile ELV for hourly averages in the first column and, if applicable, the Annual 95th percentile ELV for daily means in the second column
- (h) For each pollutant, report the Annual 95th percentile of hourly averages in the first column and, if applicable, the Annual 95th percentile of daily means in the second column

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

10th July 2019

No confidence adjustment