

Date	Suspended solids	Dissolved solids	Oil and grease	Copper	Pb	Sn	Zn	Al	Mercury	Arsenic	Ni	Nitrogen	pH max	pH min	Comments
31.7.2023	2	965	2	0.0058	0.0003	0.0015	0.012	0.32	0.00001	0.0026	0.001	0.41	7.9	7.9	
01 August 2023															Exceptionally dry weather, no water sufficient for sampling
27.9.2023	1	1150	1	0.0056	0.0005	0.0015	0.014	0.44	0.00001	0.0013	0.001	0.41	8.1	8.1	Updated-results received back from laboratory 16.10.2023
Limit	50	1200	10	0.25	0.1	0.1	0.5	1.5	0.075	0.1	0.5	1.5	9	6	

Swan Alloy UK Ltd
Westfield Industrial Park
Waunarlwydd
SWANSEA
SA5 4SF

EP3935UC
Q3 2023