

**Aug 2023**

Day	Downtime	Availability	Rationale
1	0	100.00%	
2	0	100.00%	
3	0	100.00%	
4	0	100.00%	
5	0	100.00%	
6	0	100.00%	
7	0	100.00%	
8	0	100.00%	
9	0	100.00%	
10	0	100.00%	
11	0	100.00%	
12	0	100.00%	
13	3	87.50%	Plant trip due to superheater 1 tube leak
14	24	0.00%	Plant offline for Superheater 1 tube repairs
15	24	0.00%	
16	24	0.00%	
17	24	0.00%	
18	24	0.00%	
19	9	62.50%	Plant start up
20	0	100.00%	
21	0	100.00%	
22	0	100.00%	
23	0	100.00%	
24	0	100.00%	
25	0	100.00%	
26	0	100.00%	
27	0	100.00%	
28	0	100.00%	
29	0	100.00%	
30	0	100.00%	
31	0	100.00%	
<b>Month</b>	<b>132</b>	<b>82.26%</b>	