

July 2023

Day	Downtime	Availability	Rationale
1	21	12.50%	Unit start up following superheater repairs
2	0	100.00%	
3	0	100.00%	
4	0	100.00%	
5	0	100.00%	
6	0	100.00%	
7	0	100.00%	
8	0	100.00%	
9	0	100.00%	
10	0	100.00%	
11	0	100.00%	
12	0	100.00%	
13	0	100.00%	
14	0	100.00%	
15	0	100.00%	
16	0.5	97.92%	Turbine Trip due to High condensate tank level
17	0	100.00%	
18	0	100.00%	
19	4.5	81.25%	Turbine Trip due to Feed Water Flow external fault
20	0	100.00%	
21	0	100.00%	
22	0	100.00%	
23	0	100.00%	
24	0	100.00%	
25	0	100.00%	
26	0	100.00%	
27	0	100.00%	
28	0	100.00%	
29	0	100.00%	
30	0	100.00%	
31	0	100.00%	
Month	26	96.51%	