

Planned or unplanned outage of abatement equipment

Permit Number	EPR/BL7108IM
Name of operator	Tata Steel
Location of Facility	Port Talbot Steel Works
Date & time of when the planned or unplanned outage commence (Please state if planned or unplanned)	29/10/2023 @ 11:53 Unplanned

(PART A)	
Reference or description of the location of the event	A56 Minister Stein Morfa Coke Ovens Hood
Reason for the outage	2 x ovens pushed off the hood due to an issue with Guide No.3. Testing was required before changing of the hood.
Immediate action taken to mitigate environment incident (if applicable)	
Has the abatement equipment been reinstated? (If yes state date and time)	Yes 29/10/2023 @ 12:16
If no confirm planned date to reinstate abatement equipment	
Is further correspondence required to notify NRW that the abatement equipment has been reinstated?	No
Reference	A56 MCO 137_291023
(PART B) Any more accurate information on the matters notified under Part A (Specifically if the outage of the abatement equipment has increased)	
Date abatement equipment returned to service	29/10/2023
Name	Nicola Parnell
Post	Environment Lead, Air Quality & UK ETS
Signature	
Date	30/10/2023
Reference	A56 MCO 137_291023