

Permit Number: EPR/BL3986ID

Operator: Tarmac Cement and Lime Ltd

Installation: Aberthaw Works

Form number: Air 10 / 31 August 2010

Reporting of non-kiln operational summary of continuous measurements for the month April 2023

Pollutant	Release point	Daily average limit mg/m3	Maximum daily average mg/m3	Average of daily averages mg/m3
Particulate matter	A2	20	6.20	4.52
	A3	20	1.05	0.84

Operator's comments:

Signed: Daniel Bound, Environmental Coordinator (via daniel.bound@tarmac.com)
(authorised to sign as representative of Tarmac Cement and Lime Ltd)

Date: 03/05/2023

Permit Number: EPR/BL3986ID

Operator: Tarmac Cement and Lime Ltd

Installation: Aberthaw Works

Form number: Air 10 / 31 August 2010

Reporting of non-kiln operational summary of continuous measurements for the month May 2023

Pollutant	Release point	Daily average limit mg/m3	Maximum daily average mg/m3	Average of daily averages mg/m3
Particulate matter	A2	20	5.88	5.04
	A3	20	1.39	0.88

Operator's comments:

Signed: Daniel Bound, Environmental Coordinator (via daniel.bound@tarmac.com)
(authorised to sign as representative of Tarmac Cement and Lime Ltd)

Date: 05/06/2023

Permit Number: EPR/BL3986ID

Operator: Tarmac Cement and Lime Ltd

Installation: Aberthaw Works

Form number: Air 10 / 31 August 2010

Reporting of non-kiln operational summary of continuous measurements for the month June 2023

Pollutant	Release point	Daily average limit mg/m3	Maximum daily average mg/m3	Average of daily averages mg/m3
Particulate matter	A2	20	5.83	5.04
	A3	20	2.22	0.96

Operator's comments:

Signed: Daniel Bound, Environmental Coordinator (via daniel.bound@tarmac.com)
(authorised to sign as representative of Tarmac Cement and Lime Ltd)

Date: 03/07/2023