

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01.02.23 – 28.02.23**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.31	22.02.23	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	6.75	22.02.23	BS EN 872
W1	Oil or Grease	None Present	None Visible	22.02.23	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : D Bound
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date : 24.04.23

