

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01.07.23 – 31.07.23**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.9	19.07.23	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	5.5	19.07.23	BS EN 872
W1	Oil or Grease	None Present	None Visible	19.07.23	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : D Bound
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date : 16.10.23

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01.08.23 – 31.08.23

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.07	10.08.23	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	5.05	10.08.23	BS EN 872
W1	Oil or Grease	None Present	None Visible	10.08.23	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : D Bound
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date : 16.10.23

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01.09.23 – 30.09.23**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.02	26.09.23	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	7	26.09.23	BS EN 872
W1	Oil or Grease	None Present	None Visible	26.09.23	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : D Bound
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date : 16.10.23