

Permit Reference Number : BX3376IG

Operator : Continental Teves UK Limited

Installation : Continental Teves UK Limited

Form Number : S1

Reporting of Emissions to Sewer for the period from 01.04.2023 to 30.06.2023

Emission Point	Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
S1	pH	6-11	Max = 9.7 Min= 8.9	Plant & Lab Meters	19.04.2023 26.06.2023	N/A	N/A
S1	Chromium and its compounds	1 mg/l	0.95 mg/l	Atomic Absorption	25.04.2023	N/A	N/A
S1	Zinc and its compounds	2 mg/l	1.90 mg/l	Atomic Absorption	06.06.2023	N/A	N/A
S1	Nickel and its compounds	2 mg/l	0.91 mg/l	Atomic Absorption	21.06.2023	N/A	N/A
S1	Total flow	100 M ³ / 24 Hrs & < 20 M ³ / Hr	1147 m3	Ultrasonic Flow Meter at Outfall	01.04.2023 to 30.06.2023	M/CERTS	4.16%

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated) – *{The basis of any other uncertainty figure needs to be stated. Where no figure is available the Agency will need to agree an appropriate uncertainty value.}*

Signed *J. French*

Date: 10.07.2023