

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BN0020802

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at LLANFIHANGEL-AR-ARTH STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed: **Dated:**

Name (block capitals): **Position:**

(to be completed when signing)



Welsh Off Ref

Form SS.RW2

WWA HQ Ref

RW/0630/1/1

Sheet 1

of 1

LOCAL GOVERNMENT ACT 1972 - WATER ACT 1973
 RIVERS (PREVENTION OF POLLUTION) ACTS 1951-1961
 WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

NOTIFICATION OF VARIATION OF CONSENT
for a discharge of treated sewage effluent

To :

WELSH WATER AUTHORITY

This Notice is issued under the above-mentioned Acts and Order and all other enabling powers as a NOTICE DEEMED TO HAVE BEEN GIVEN BY THE SECRETARY OF STATE FOR WALES, in respect of the existing discharge of treated sewage effluent from the Authority's :

LLANFIHANGEL AR ARTH SEWAGE TREATMENT WORKS

via an existing outlet and subject hitherto to a previous consent as specified below.

THE EXISTING OUTLET is to : the Afon Teifi

at National Grid Reference : SN 4549 4012

and has been shown marked : Discharge Point

on the attached Plan, No. : RW/0630/1/1

THE PREVIOUS CONSENT was : The Consent

Reference No. —

granted on : 12th March 1969

by : South West Wales River Authority

to : Newcastle Emlyn Rural District Council

The Authority submitted this Notification of Variation on : 12th November 1981 to the Secretary of State for Wales in the form of a draft and the Secretary of State has NOT, within the relevant period, given notice of his intention to determine this matter. This discharge is therefore (in substitution for all the conditions hitherto in force) subject only to the following conditions as from : 12th February 1982

CONDITIONS

1. The discharge shall consist only of treated sewage effluent from the above works.
2. The quality and quantity of effluent shall not exceed the following maximum values:

DeterminandValueUnit

Biochemical Oxygen Demand (+ATU) over 5 days at 20°C

22

milligrams per litre

Suspended Solids dried at 105°C

30

milligrams per litre

Rate of discharge

3.9

litres per second

Volume during any period of 24 consecutive hours

338

cubic metres

Volume discharged under 'dry weather conditions' during any period of 24 consecutive hours

56.3

cubic metres

3. Adequate facilities shall be provided for the taking of samples of the effluent at:
outlet from humus tank

The terms of this Notice will not, without the consent in writing of the person to whom this Notice is given, (or his successor), be altered before the expiration of the period ending with the Twelfth day of February 19 84 .

This Notification is issued by the Directorate of Scientific Services, Headquarters, Welsh Water Authority, Cambrian Way, Brecon, Powys.