

**FORM WATER 3: Oil emissions to controlled water – Weekly samples (W3) and annual sample (W4)**

Permit Number: EPR/KP3036AX

Operator: Puma Energy (UK) Limited

Installation Location: Milford Haven Terminal, Milford Haven, SA73 3JD

Q3 2023

Parameter: Oil

Release Point	W3 discharge to St. Botolph's stream		
Parameter	ELV mg/l	3-month average of weekly samples (mg/l)	Maximum weekly result (mg/l)
Oil	5	1.15	3.0

Release Point	W4 discharge to Rickeston water	
Parameter	ELV (mg/l)	Annual sample (mg/l)
Oil	5	-

Signed *SJ Jones*  
Name Sarah Jones  
On behalf of the Operator Puma Energy (UK) Limited  
Date 14/11/2023

