

creu lle gwell
creating a better place

Environment Quality Scientist
Dwr Cymru Cyfyngedig
Pentwyn Road
Nelson
Treharris
CF46 6LY



Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

Our ref: BG0024501

Your ref:

Date: 18th of September 2007

Dear Environment Quality Scientist

Application to discharge treated sewage effluent by DCWW from premises at St. Clears Wastewater Treatment Works
Application no: BG0024501

Water Resources Act 1991 (as amended by the Environment Act 1995) Schedule 10

I enclose our formal consent to discharge in relation to your application. You are now the holder of this Consent and should ensure that the conditions of the Consent are complied with at all times.

If you consider that the conditions of the consent are unreasonable, you have a right of appeal to:

National Assembly for Wales
Environment Protection & Quality Division – Water Branch
Cathays Park
Cardiff CF10 3NQ

Your appeal must be given in writing within three months of the date of issue of the consent and must include a statement of the grounds for the appeal. You should also send a copy of the appeal to us at the address below.

This Consent is an important document.

If you want to revoke (cancel), or vary (change/amend) the Consent in any way, please contact us. Similarly, if you change your contact address while continuing to hold the Consent, please let us know.

This Consent covers water quality considerations only. It does not give any right or permission to discharge where land is not owned by the applicant. In addition, for discharges to watercourse it does not imply the suitability, with regard to volumetric capacity, of the receiving watercourses. It is the responsibility of the applicant to identify and negotiate, with the riparian owners as necessary, any requirement for downstream improvement works. Failure to do so could result in a Common Law action by the riparian owner.

You should be aware that those discharges which outfall directly into 'main river' may require a Land Drainage Consent from the Environment Agency before the outfall may be

Asiantaeth yr Amgylchedd Cymru
Maes Newydd, Llandarwl,
Castell-Nedd Port Talbot, SA10 6JQ
Llinell gwasanaethau cwsmeriaid: 08708 506 506
Epost: enquiries@environment-agency.gov.uk
www.asiantaeth-amgylchedd.cymru.gov.uk

Environment Agency Wales
Maes Newydd, Llandarcy, Neath Port Talbot, SA10 6JQ
Customer services line: 08708 506 506
Email: enquiries@environment-agency.gov.uk
www.environment-agency.wales.gov.uk



constructed. This is in addition to any discharge consent which may be granted. A charge will be levied to cover the processing costs of the Land Drainage Consent application.

Where the proposed outfall is to a watercourse which is the responsibility of an Internal Drainage Board (IDB) or local authority, then Land Drainage Consent is a matter between the applicant and the relevant IDB or local authority.

Any new outfall to a watercourse should be constructed so that it does not protrude or cause interference with flows. Works within 8 metres of a flood protection structure, for example a floodbank, will require a separate 'Works Affecting Watercourses and/or Flood Defences' application to be submitted.

Please ensure that the sample point for this discharge is maintained so that it is accessible to officers of the Environment Agency and that a direct sample of the effluent may be readily and safely taken at all times.

Public Register

Details of the application for consent are placed on our Public Register which is open for inspection by the public.

Annual charges

Under our current scheme of charges, this consented discharge will attract an annual charge from the date the consent is issued. You will be charged from this date whether or not you are actually discharging. Information on our charges is available through our website at www.environment-agency.gov.uk/charges. If you do not have access to the internet, a hard copy is available from me on request.

Change of Consent Holder

If in the future the name of the Consent Holder is due to change, both you and the new holder must inform us in writing before the change. We can then transfer the rights and charges to the new holder and send a certificate to confirm the transfer of consent.

If you have any queries please contact me.

If you have any queries please contact me.

Yours sincerely



Kimberley Ekin-Wood
Regulatory Water Quality

Llinell uniongyrchol/Direct dial
Ffacs uniongyrchol/Direct fax
E-bost uniongyrchol/Direct e-mail

01792 325546
01792 325530
kimberley.ekin-wood@environment-agency.gov.uk

CONSENT NO. BG0024501

creu lle gwell
creating a better place



Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

WATER RESOURCES ACT 1991

SECTION 88 – SCHEDULE 10

(AS AMENDED BY THE ENVIRONMENT ACT 1995)

MODIFICATION OF CONSENT TO DISCHARGE

TO: Environment Quality Scientist
Dŵr Cymru Cyfyngedig
Pentwyn Road
Nelson
Treharris
CF46 6LY

In pursuance of an application by the consent holder for variation of consent, the **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY MODIFIES ITS CONSENT** to the making of a discharge **OF SEWAGE EFFLUENT**, as follows:

Secondary Treated Sewage Effluent incorporating the requirements of the Urban Waste Water Treatment Regulations 1994 (UWWTR)

with respect to Consent No. **BG0024501** issued on the 30th day of June 1983

FROM: ST. CLEARS WASTEWATER TREATMENT WORKS

AT: ST. CLEARS, CARMARTHENSHIRE

TO: RIVER TAF ESTUARY


HEREAFTER SUBJECT TO the conditions set out in the following schedule(s):

Secondary Treated Sewage Effluent
UWWT Regulations 1994

Schedule No. BG0024501 01
Schedule No. BG0024501 01 / U

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency, which affects the effect of variations made to this consent, without the agreement in writing of the Consent Holder, during a period of 4 years from the date this variation is issued.

This variation of consent is issued on the 31st day of March 2005
and takes effect on the 31st day of March 2005

Signed 

Team Leader – Regulatory Water Quality



CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01
DATE ISSUED	31st March, 2005

CONDITIONS OF CONSENT TO DISCHARGE

Secondary Treated Sewage Effluent ("the Discharge")

**FROM: ST. CLEARS WASTEWATER TREATMENT WORKS, ST. CLEARS,
CARMARTHENSHIRE**

NATURE

1. The Discharge shall consist solely of secondary treated sewage effluent.

LOCATION

2. The Discharge shall be made in the manner and at the place specified as:
 - (a) discharging via a 225 millimetre diameter pipe;
 - (b) discharging to the River Taf Estuary;
 - (c) at National Grid Reference SN 28202 14939;
 - (d) shown marked 'Consent Point' on Plan BG0024501 attached as Annex 3.

SAMPLE POINT

3. An appropriately labelled sample point shall be provided and maintained at National Grid Reference Reference SN 28539 15027, as shown marked 'FINAL EFFLUENT & U.W.W.T.D. SAMPLING POINT' on Plan BG0024501, or some other point as agreed in writing with the Agency, so that a representative spot sample of the Discharge may be obtained. The consent holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was being discharged into controlled waters.

VOLUME

4. The volume of the Discharge shall not exceed 1,925 cubic metres per day.
5. The Dry Weather Flow of the Discharge shall not exceed 987 cubic metres per day.

For the purpose of this condition Dry Weather Flow shall mean the average daily flow to the treatment works during seven consecutive days without rain (excluding a period which includes public holidays) following seven days during which the rainfall did not exceed 0.25 millimetres on any one day.

6. The rate of discharge shall not exceed 22.3 litres per second.

CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01

FLOW MEASUREMENT

7. A continuous flow monitoring and recording system, to a specification provided by the Agency, with on-site visual display from which readings can be readily obtained by the Agency, shall be provided and operated to record the daily volume and instantaneous flow of the discharge.
8. As soon as practicable after completion of the flow system installation the Consent Holder shall employ an independent expert to certify that the installation complies with the Agency's specification. The Consent Holder shall satisfy himself as to the professional competence of the expert. A copy of the certifier's report shall be provided to the Agency when it is available.
9. Records of the flow readings shall be maintained by the Consent Holder and shall be provided to the Agency when requested, in a format specified by the Agency.
10. The Consent Holder shall produce and maintain a quality control manual, approved by the independent expert and to the satisfaction of the Agency, specifying procedures for the calibration, operation and maintenance of the flow monitoring system. The flow system shall be calibrated, operated and maintained by the Consent Holder in accordance with the provisions of the manual. The Consent Holder shall keep a record of these procedures available for inspection by the Agency and provide a copy to the Agency on request.
11. The Consent Holder shall record all failures of the continuous flow system and any other breaks in the flow record. The reasons for these failures and breaks shall be recorded and all steps taken to prevent a re-occurrence. The Consent Holder shall ensure that as far as possible the recorder remains fully operational at all times. Any failures shall be remedied as soon as possible.
12. Flows passing forward to full treatment shall be measured at the inlet works rising main outlet, at National Grid Reference SN 28598 15032, or such other point(s) as agreed by the Agency.

COMPOSITION

13. (a) Subject to paragraph (b) below, the Discharge shall not contain more than:
 - (i) 40 milligrammes per litre of biochemical oxygen demand (measured after 5 days at 20°C with nitrification suppressed by the addition of allyl-thiourea);
 - (ii) 60 milligrammes per litre of suspended solids (measured after drying at 105°C).

CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01

- (b) The limit for any of the relevant parameters set out in paragraph (a) above may be exceeded where, in any series of samples of the Discharge taken at regular but randomised intervals in any period of twelve consecutive months as listed in Column 1 of the table at Annex 1 to this consent, no more than the relevant number of samples, as listed in Column 2 of the said table, exceed the applicable limit for that relevant parameter.

WORKS OPERATION

14. The works shall be operated and the effluent shall be treated in a manner which, so far as reasonable practicable, minimises the polluting effects of the discharge made from the works on controlled waters.

This condition does not require -

- (a) any higher standard to be achieved in relation to any characteristic of the discharge which is specifically regulated by conditions 13 and 14, than is required by those conditions;
- (b) any alteration of the works or a change in the type of treatment used.

UNUSUAL WEATHER CONDITIONS

15. (a) No sample of the discharge, taken at a time when unusual weather conditions are adversely affecting the operation of the sewage treatment works, shall be taken into account in deciding whether or not the conditions 13, 14 and 15 of this consent have been complied with.
- (b) For the purpose of this condition "unusual weather conditions" shall include:
- (i) low ambient temperatures as evidenced by effluent temperatures of 5°C or less, or by the freezing of mechanical equipment in the works;
 - (ii) significant snow deposits;
 - (iii) tidal or fluvial flooding;
 - (iv) weather conditions causing unforeseen loss of power supply to the sewage treatment which could not be ameliorated by the reasonable provision and operation of standby generation facilities.

CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01

- (c) On any occasion where unusual weather conditions adversely affect the operation of the sewage treatment works, the Consent Holder shall use its best endeavours to mitigate that adverse effect.
- (d) For a sample of the discharge to be considered for the purposes of (a) above, the Consent Holder shall notify the Agency by telefax or telephone as soon as unusual weather conditions are known to have adversely affected operations and shall confirm the circumstances in writing as soon as possible thereafter (and in any event within 14 days of the occurrence of such conditions). That notification shall include a full description of the unusual weather conditions and their impact on the operation of the works.

RECORDING AND REPORTING

- 16. (a) The Consent Holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- (b) On request the Consent Holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality.
- 17. The Consent Holder shall notify the Agency in writing if any known or planned introduction or material change in respect of discharges from trade premises to the sewerage system occurs, that may increase or introduce into the effluent any "dangerous substance" included on Lists I, II, or Red List (set out in Annex 2 to this notice as updated from time to time and notified to the Consent Holder in writing), and any other substance considered by the consent holder as having or likely to have a significant effect on the receiving waters.

SUBSTANTIAL CHANGE

- 18. A discharge shall not be made from the works if it would cause a significant increase in the polluting effects of the discharge on controlled waters as a result of a new or altered discharge of trade effluent into the works.
- 18.1 A discharge of trade effluent into the works is new if -
 - (a) it is made by the sewerage undertaker and is of a kind not made into the works by the undertaker immediately before the date of effect of this consent; or
 - (b) it is made by a third party and the discharge is authorised on or after that date.

CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01

18.2 A discharge of trade effluent into the works is altered if -

- (a) it is made by the sewerage undertaker and its composition or quantity changes significantly on or after the date of effect of this consent; or
- (b) it is made by a third party and the alteration of the discharge is authorised on or after that date.

18.3 An increase in the polluting effects of the Discharge on controlled waters is not significant for the purposes of this condition if it relates to any characteristic of the Discharge which is specifically regulated by conditions 13 and 14 of this consent but it may be significant if it is caused by a change in some other characteristic of the Discharge.

18.4 For the purposes of this condition "trade effluent" means -

- (a) any discharge by the sewerage undertaker other than
 - (i) domestic sewage from premises connected directly or indirectly to the works; or
 - (ii) surface water run-off;
- (b) any discharge by a third party which is authorised under Chapter III of Part IV of the Water Industry Act 1991 or which is only accepted as a result of a contract with the sewerage undertaker.

UNAUTHORISED DISCHARGES

19. A discharge made from the works shall not contain any poisonous, noxious or polluting matter or solid waste matter which is attributable to any unauthorised discharge into the works.

- (a) A discharge into the works is unauthorised if it is made by a third party and either there is no obligation to receive it or conditions subject to which there is an obligation to receive it are not observed.
- (b) Nothing in this, or any other, condition of this consent prevents anyone from relying on any defence available to them under section 87 of the Water Resources Act 1991.

CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01 / U
DATE ISSUED	31st March, 2005

CONDITIONS OF CONSENT TO DISCHARGE

Secondary Treated Sewage Effluent ("the Discharge")

**FROM: ST. CLEARS WASTEWATER TREATMENT WORKS, ST. CLEARS,
CARMARTHENSHIRE**

URBAN WASTE WATER TREATMENT REGULATIONS

- U0** (a) The Consent Holder shall comply with the Urban Waste Water Treatment (England and Wales) Regulations 1994 ('the Regulations').
- (b) For the purpose of conditions U1 below, interpretations and references to a numbered regulation or Schedule shall have the meaning as in the Regulations, unless otherwise indicated.
- U1** (a) The Discharge derives from an agglomeration with a population equivalent of between 2,000 and 10,000, discharging to estuarial waters.
- (b) The Consent Holder shall inform the Agency in writing of any change, or proposed change, to the population equivalent such as would make a material change to the application of the Regulations and shall, on request, inform the Agency in writing of the actual population equivalent.
- (c) The Discharge shall be subject to Regulation 5(1) and shall satisfy the requirements of Part I of Schedule 3.
- U2** (a) The Consent Holder shall provide apparatus for the purpose of:
- (i) measuring or recording the volume, rate of flow, nature, composition or temperature, and
- (ii) collecting samples of any waste water,
- as is necessary to ensure compliance with paragraph (b) below.
- (b) The Consent Holder shall monitor the Discharge to verify compliance with the requirements of condition U1(c) above in accordance with control procedures as set out in Part II of Schedule 3.
- (c) The consent holder shall provide to the agency any information collected in complying with paragraph (b) above in a manner agreed with the agency.
- U3** Condition U2 above shall apply for the purpose of verifying compliance with the directive from the date as specified in the relevant paragraph of regulation 5 as incorporated into this consent under condition U1(c) above.

CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01 / U

- U4**
- (a) An appropriately labelled sample point shall be provided and maintained at National Grid Reference SN 28599 15031, as shown marked 'URBAN WASTE WATER (U.W.W.T.D.) INLET WORKS SAMPLING POINT' on the attached Plan No. BG0024501, or some other point as agreed in writing with the Agency, so that a representative sample of the Influent may be obtained.
 - (b) An appropriately labelled sample point shall be provided and maintained at National Grid Reference SN 28539 15027, as shown marked 'FINAL EFFLUENT & U.W.W.T.D. SAMPLING POINT' on the attached Plan No. BG0024501, or some other point as agreed in writing with the agency, so that a representative sample of the discharge may be obtained.

CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01

ANNEX 1

TABLE

Column 1

Column 2

Number of samples
taken in any period
of 12 months

Maximum number of samples
permitted to exceed limit
for given determinand

4-7	1
8-16	2
17-28	3
29-40	4
41-53	5
54-67	6
68-81	7
82-95	8
96-110	9
111-125	10
126-140	11
141-155	12
156-171	13
172-187	14
188-203	15
204-219	16
220-235	17
236-251	18
252-268	19
269-284	20
285-300	21
301-317	22
318-334	23
335-350	24
351-365	25

CONSENT NO.	BG0024501
SCHEDULE NO.	BG0024501 01

ANNEX 2

- | | |
|--|------------------------------|
| 1. Mercury and its compounds | 2. Cadmium and its compounds |
| 3. Hexachlorocyclohexane
(lindane and related compounds) | 4. Carbon tetrachloride |
| 5. DDT (the isomers of 1,1,1-trichloro-2,2 bis(p-chlorophenyl) ethane) | |
| 6. Pentachlorophenol (PCP) | 7. Aldrin |
| 8. Dieldrin | 9. Endrin |
| 10. Isodrin | 11. Hexachlorobenzene (HCB) |
| 12. Hexachlorobutadiene (HCBd) | 13. Chloroform |
| 14. Polychlorinated biphenyls | 15. Dichlorvos |
| 16. 1,2-Dichloroethane | 17. Trichlorobenzene |
| 18. Atrazine | 19. Simazine |
| 20. Tributyltin compounds | 21. Triphenyltin compounds |
| 22. Trifluralin | 23. Fenitrothion |
| 24. Azinphos-methyl | 25. Malathion |
| 26. Endosulfan | 27. Lead |
| 28. Chromium | 29. Zinc |
| 30. Copper | 31. Nickel |
| 32. Arsenic | 33. *Iron |
| 34. *pH outside range 5.5 to 9.0 | 35. *Boron |
| 36. Vanadium | 37. PCSD'S |
| 38. Cyfluthrin | 39. Sulcofuron |
| 40. Flucifuron | 41. Permethrin |
| 42. 4-Chloro-3-methyl-phenol | 43. 2-Chlorophenol |
| 44. 2,4-Dichlorophenol | 45. 2,4-D (ester) |
| 46. 2,4-D (non ester) | 47. 1,1,1-Trichloroethane |
| 48. 1,1,2-Trichloroethane | 49. Bentazone |
| 50. Benzene | 51. Biphenyl |
| 52. Chloronitrotoluenes | 53. Demeton |
| 54. Dimethoate | 55. Linuron |
| 56. MCPA | 57. Mecoprop |
| 58. Mevinphos | 59. Napthalene |
| 60. Omethoate | 61. Toluene |
| 62. Triazophos | 63. Xylene |
| 64. Cyanide | 65. Azinphos-ethyl |
| 66. Fenthion | 67. Parathion |
| 68. Parathion-methyl | 69. Trichloroethylene |
| 70. Tetrachloroethylene | 71. Dioxins |
| 72. PAHs | 73. Nonyl phenol |
| 74. Nonyl phenyl ethoxylate | 75. Di-ethylhexyl phthalate |
| 76. Bisphenol-A | 77. Diazinon |
| 78. Chlorfenvinphos | 79. Chlorotoluron |
| 80. Isoproturon | 81. Diuron |
| 82. Propetamphos | 83. Flumethrin |
| 84. Amitraz | 85. High-Cis Cypermethrin |
| 86. Cyromazine | 87. Deltamethrin |
| 88. Cypermethrin | |

This list is applicable as at 1 December 1998 and will be updated as and when changes to the relevant legislative requirements occur.

*Notification to the Agency by the Consent holder is only required in respect of changes to trade effluents likely to cause significant changes to the pH value, and/or iron or boron concentrations, of the crude sewage.

