

Planned or unplanned outage of abatement equipment

Permit Number	EPR/BL7108IM
Name of operator	Tata Steel
Location of Facility	Port Talbot Steel Works
Date & time of when the planned or unplanned outage commence (Please state if planned or unplanned)	22/11/2023 @ 04:08 Planned

(PART A)	
Reference or description of the location of the event	A56 Minister Stein Morfa Coke Ovens Hood
Reason for the outage	18 x ovens pushed off of the hood for planned maintenance work
Immediate action taken to mitigate environment incident (if applicable)	Maintenance planned during battery stop to minimise ovens pushed without a hood.
Has the abatement equipment been reinstated? (If yes state date and time)	Yes 22/11/23 @17:50
If no confirm planned date to reinstate abatement equipment	
Is further correspondence required to notify NRW that the abatement equipment has been reinstated?	No
Reference	A56 MCO 144_221123
(PART B)	
Any more accurate information on the matters notified under Part A (Specifically if the outage of the abatement equipment has increased)	
Date abatement equipment returned to service	22/11/23 @17:50
Name	Aimee Tossell
Post	Environment Officer
Signature	
Date	27/11/2023
Reference	A56 MCO 144_221123