

| SCHEDULE 5 Notification      |                    |
|------------------------------|--------------------|
| <b>Part A</b>                |                    |
| Permit Number:               | BL7108IM           |
| Name of Operator:            | Tata Steel UK Ltd  |
| Location of Facility:        | Port Talbot Works  |
| Time & Date of the Detection | 04/12/2023 10:00am |

| (b) Notification requirements for breach of a permit condition |                                                                                                                                                                                                                 |
|----------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Emission point/reference source                                | A50 Service Boilers 4&5 stack                                                                                                                                                                                   |
| Parameter(s)                                                   | SO <sub>2</sub>                                                                                                                                                                                                 |
| Limit                                                          | Daily fuel-weighted dynamic emission limits<br><br>30/11/23- 173.4 mg/m <sup>3</sup>                                                                                                                            |
| Measured value and uncertainty                                 | Daily average<br><br>30/11/23- 191.9 mg/m <sup>3</sup> (only 6 hours of normal operating conditions)<br><br>95% confidence level has already been subtracted from measured results – permit condition 3.6.7 (a) |
| Date and time of monitoring                                    | Daily means from continuous emission monitoring<br><br>30/11/2023 – 00:00 to 23:59                                                                                                                              |
| Measures taken, or intended to be taken, to stop the emission  | No abatement of SO <sub>2</sub> emissions from boiler stacks.                                                                                                                                                   |
| REF: S5N/23/75A                                                |                                                                                                                                                                                                                 |