

Planned or unplanned outage of abatement equipment

Permit Number	EPR/BL7108IM
Name of operator	Tata Steel
Location of Facility	Port Talbot Steel Works
Date & time of when the planned or unplanned outage commence (Please state if planned or unplanned)	05/12/23 @17:30 – 07/12/23 @10:55

(PART A)	
Reference or description of the location of the event	A56 Minister Stein Morfa Coke Ovens Hood
Reason for the outage	Total of 85 ovens pushed off the hood due to electrical and comms faults – awaiting spares to fix.
Immediate action taken to mitigate environment incident (if applicable)	Sourced and obtain correct spares.
Has the abatement equipment been reinstated? (If yes state date and time)	Yes 07/12/23 @10:55
If no confirm planned date to reinstate abatement equipment	
Is further correspondence required to notify NRW that the abatement equipment has been reinstated?	No
Reference	A56 MCO 147_051223
(PART B) Any more accurate information on the matters notified under Part A (Specifically if the outage of the abatement equipment has increased)	N/A
Date abatement equipment returned to service	07/12/23 @10:55
Name	Aimee Tossell
Post	Environment Officer
Signature	
Date	07/12/2023
Reference	A56 MCO 147_051223