

# Schedule 5 Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

## Part A

Permit Number	<b>EPR/CP3795FY</b>
Name of operator	<b>Sims Group UK Limited</b>
Location of Facility	<b>Northside, South Dock, Alexandra Dock, Newport, NP20 2WE</b>
Time and date of the detection	<b>22/12/2022 – Date of sampling</b>

<b>(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment</b>	
<b>To be notified Immediately</b>	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

<b>(b) Notification requirements for the breach of a permit condition</b>	
<b>To be notified immediately</b>	
Emission point reference/ source	<b>Emission Point reference 11 stated in Schedule 3, Table S3.3 (sample taken from TSP2 – Shredder Sample Point)</b>
Parameter(s)	<b>Copper</b>
Limit	<b>40ug/l</b>
Measured value and uncertainty	<b>51ug/l</b>
Date and time of monitoring	<b>22/12/2022</b>

Measures taken, or intended to be taken, to stop the emission	<b>An investigation has been undertaken. We have been unable to identify the root cause/ attribute an activity to the elevated result. Interceptor maintenance is being arranged.</b>
---	---

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

<b>(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:</b>	
<b>To be notified immediately</b>	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

## Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

<b>Name*</b>	Martin Crossman
<b>Post</b>	Site Manager
<b>Signature</b>	M Crossman
<b>Date</b>	16/01/2023

\* authorised to sign on behalf of the operator