

Permit Number: XP3833UB

Operator: G.D. Environmental Services Limited

Installation: East Bank Road Treatment Facility

Form Number: Sewer1 / 001

Reporting of emissions to sewer for the period from 01/01/2023 to 31/03/2023

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
S1	Flow m ³ /day	None	Month 1	46m ³ over 19 days	Flow meter	Continuous measurement	5.84%
S1	Flow m ³ /day	None	Month 2	20m ³ over 17 days	Flow meter	Continuous measurement	5.84%
S1	Flow m ³ /day	None	Month 3	39m ³ over 23 days	Flow meter	Continuous measurement	5.84%
	Total		Quarter months	36m ³ over 59 days			

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed 

Date: 20/04/2023

(Authorised to sign as representative of G.D. Environmental Services Limited)