



Cyfoeth Naturiol Cymru Natural Resources Wales

Mr Brian Sheppard
Glynclydach Hotel
Longford Road
Dyffryn
Neath
SA10 7AJ

Ein cyf / Our ref: BM0044301 Glynclydach
Hotel 150318

Eich cyf / Your ref:

Dyddiad/Date: 24th May 2019

Dear Mr Sheppard,

**Environment Permitting (England and Wales) Regulations 2010
Failure to Comply with Consent Condition 4 of Discharge Consent BM0044301
Sample taken from Glynclydach Hotel on the 8/1/19 and 24/4/19**

The attached analytical report indicates that samples taken on the 8th January 2019 and 24th April 2019 from Glynclydach Hotel for which you hold the consent, exceeded the permitted limits.

These results, together with all other results taken for the purpose of consent monitoring, will form part of the public register held by Natural Resources Wales and are available for inspection by any member of the public.

Please let me know within **fourteen** days the reason for these failures and the steps that you intend to take or have taken to prevent recurrence. I shall have regard to your response when determining what further action Natural Resources Wales may take to ensure compliance with the consent.

Please ensure that the person responding on behalf of Glynclydach Hotel is authorised or has been authorised to respond on behalf of the company and that this is also stated in the response.

Yours sincerely

Pippa Sabine
Environment Officer

Deialu uniongyrchol/Direct dial 0300 065 3303

Ffacs uniongyrchol/Direct fax 01792 325511

E-bost uniongyrchol/Direct e-mail

pippa.sabine@cyfoethnaturiolcymru.gov.uk / pippa.sabine@naturalresourceswales.gov.uk

Enc. Analytical Report for samples taken on 8/1/19 and 24/4/19

Natural Resources Wales/Cyfoeth Naturiol Cymru

Maes Newydd, Llandarcy, Neath Port Talbot, SA10 6JQ.

Llinell gwasanaethau cwsmeriaid/Customer services line: 0300 065 3000

www.cyfoethnaturiolcymru.gov.uk / www.naturalresourceswales.gov.uk

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg

Correspondence welcomed in Welsh and English

Station	Station number	Time stamp (Sampling)	Parameter type	Parameter method	Measuring method	Sign	Value	Unit
GLYNCLYDACH HOTEL: STW F.E	71596	08/01/2019 14:35	0135 / Sld Sus@105C	Low	Low	---	63	mg/l
GLYNCLYDACH HOTEL: STW F.E	71596	08/01/2019 14:35	0085 / BOD ATU	Low	Low	---	98.2	mg/l
GLYNCLYDACH HOTEL: STW F.E	71596	08/01/2019 14:35	0061 / pH	Low	Low	---	7.25	---
GLYNCLYDACH HOTEL: STW F.E	71596	24/04/2019 12:41	0085 / BOD ATU	Low	Low	>	239	mg/l
GLYNCLYDACH HOTEL: STW F.E	71596	24/04/2019 12:41	0061 / pH	Low	Low	---	6.66	---
GLYNCLYDACH HOTEL: STW F.E	71596	24/04/2019 12:41	0135 / Sld Sus@105C	Low	Low	---	120	mg/l

Natural Resources Wales/Cyfoeth Naturiol Cymru
Maes Newydd, Llandarcy, Neath Port Talbot, SA10 6JQ.
Llinell gwasanaethau cwsmeriaid/Customer services line: 0300 065 3000
www.cyfoethnaturiolcymru.gov.uk / www.naturalresourceswales.gov.uk

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg

Correspondence welcomed in Welsh and English