

SCHEDULE 5 Notification	
Part A	
Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Time & Date of the Detection	04/01/2024 10:00am

(b) Notification requirements for breach of a permit condition	
Emission point/reference source	A50 Service Boilers 4&5 stack
Parameter(s)	SO ₂
Limit	Daily fuel-weighted dynamic emission limits 22/12/23- 246.9 mg/m ³
Measured value and uncertainty	Daily average 22/12/23- 287.7 mg/m ³ (only 4 hours of normal operating conditions) 95% confidence level has already been subtracted from measured results – permit condition 3.6.7 (a)
Date and time of monitoring	Daily means from continuous emission monitoring 22/12/2023 – 00:00 to 23:59
Measures taken, or intended to be taken, to stop the emission	No abatement of SO ₂ emissions from boiler stacks.
REF: S5N/23/83A	