

Appendix 8 – Medium Combustion Plant ('MCP') and combined MCP/Specified Generator Check List

Please provide the information below for each new medium combustion plant or combined MCP/Specified Generator as identified in Annex I of the Medium Combustion Plant Directive (EU/2015/2193).			
Questions	Answers		
1 What is the MCPD identifier ¹ (As shown on site plan)?	Thermal oil heater Wanson EPC1500ES B		
2 What is the rated thermal input (MWth) of the medium combustion plant. Where there is more than one medium combustion plant, please provide the individual and aggregated total thermal input for all plants.		MWth (only one)	
	1.5MWth	MWth (If more than one)	
3 Please indicate the type of medium combustion plant by ticking the appropriate option.	Diesel engine	<input type="checkbox"/>	
	Gas turbine	<input type="checkbox"/>	
	Dual fuel engine	<input type="checkbox"/>	
	Other engines	<input type="checkbox"/>	
	Other medium combustion plant	v	
4 Please state the type of fuels used	Fuel type	Tick relevant options	Share of fuels used (%)
	Solid Biomass	<input type="checkbox"/>	
	Other Solid Fuels	<input type="checkbox"/>	
	Gas Oil (Diesel)	v	0-1
	Liquid fuels other than gas oil	<input type="checkbox"/>	
	Natural Gas	v	99-100
	Gaseous fuels other than natural gas	<input type="checkbox"/>	
5 Please state the start date of the operation of the Medium Combustion Plant. Or where the exact start date is unknown, provide proof that the operation started before 20 th December 2018.	05/03/2020	Start date	
	Or, if start date unknown; provide proof:		
		Document reference	
6 Please state the sector of activity of the Medium Combustion Plant or the facility in which it is applied (NACE code ²)	10.89		
7 Please state the expected number of annual operating hours of the Medium Combustion Plant, and average load in use.	7200	Hours	
	70%	Average load in use	
8 Please confirm that where the option of exemption under article 6(3) or article 6(8) of the medium combustion plant directive is used, the medium combustion plant will not be operated more than the number of hours referred to in those paragraphs.	Yes, I/We confirm that where the option of exemption under article 6(3) or article 6(8) of the medium combustion plant directive is used, the medium combustion plant will not be operated more than the number of hours referred to in those paragraphs		<input type="checkbox"/>