

Part A

Permit Number	EA/EPYP3937SH/V003
Name of Operator	Mekatek Limited
Location of Installation	Amex Park, Johnstown, Carmarthen, SA31 3NF
Location of the emission	W1
Time and date of the emission	November 2023 (composite sample)


Substance(s) emitted	Media <i>eg air, groundwater</i>	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Nitrogen, Total as N	Source emissions to water	72.2 mg/l of Nitrogen, Total as N identified within the monthly composite sample.	November 2023

Measures taken, or intended to be taken, to stop the emission	ALS laboratories have been challenged regarding the accuracy of the result as various correspondence has been received from the accredited laboratory regarding delays and issues with the testing equipment for this det. More internal testing to be carried out on Nitrogen for a period of at least three months, as this det. has not been considered an issue to comply with previously so a cross comparison with the accredited lab is good practice.
---	---

Part B

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	As above.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	As above.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

Name	Peter Ryall
------	-------------

Post	Senior Compliance Officer
Signature	
Date	28/12/2023