


EP Unit Shut Down Notification

Permit Number / Variation Notice Number	BR8212IK / (EA/EPR/BR8212IK/V004)
Name of operator	Knauf Insulation
Location of Installation	Cwmbran
Time and date of the shutdown	25/09/23 (14:00) – 27/09/23 (14:00)

Details of fugitive emission which may cause pollution	
Date and time of the event	25 th September 2023 14:00 to 27 th September 2023 14:00
Reference or description of the location of the event	A2 – By Pass Stack
Description of where any release into the environment took place	To air in the Pontypool /Cwmbran area
Substance(s) potentially released	Particulate
Best estimate of the quantity or rate of release of substance	Varying between 0 to 321 mg/m ³
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	The EP unit is required to be shut down during a 3 day maintenance shutdown period. The number of bushings in operation during this period will be reduced to 3 and as such pull rate reduced.
Description of the failure or accident	The EP unit may be required to be shut down during a 3 day maintenance shutdown period

Details of emission quantities provided	
Emission point reference/ source	A2
Limit	No Limit on emission Point A2
Measured value	320.9 mg/m ³
Date and time of monitoring	15 th March 2021

Name*	Warren Christy
Post	HS&E Manager
Signature	
Date	19/09/2023

* authorised to sign on behalf of Knauf Insulation Limited