

Schedule 5 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	A4 Boiler 16
Time and date of the emission:	16/06/2023

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Carbon Monoxide	Atmosphere	Measured CO concentration; 117 (+/- 4.4) mg/Nm ³ Vs 100 mg/Nm ³ limit (at specified reference conditions)	The testing took place between; 13:30 – 14:30

Description of the failure or accident, and... Measures taken, or intended to be taken, to stop the emission:	Monitoring report received following statutory emissions monitoring, which indicated elevated CO (Carbon Monoxide) in the combined Boiler & Gas Turbine exhaust at the time of the monitoring exercise Subsequent testing took place on the 09/08/2023 which was within compliance at 34.6 mg/Nm³ Further information to follow in Part B
--	---

* Signed:



Date: 15/09/2023

* authorised to sign on behalf of Solutia UK Ltd