

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICE
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP



CG0080001_2006_03_02

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent CG0080001

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
GARNDOLBENMAEN STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Name of Transfer to new Holder(s):

Dated:

Position:

CONSENT VARIATION

RIVERS (CONTROL OF POLLUTION) ACTS 1951-1961
THE WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

I am directed by the Secretary of State for Wales to refer to the discharge consent in respect of the GARNDDU BENNYMAN sewage treatment works dated .17. DECEMBER.. 1980.

The Secretary of State for Wales, having consulted with the Welsh Water Authority, hereby gives notice that in exercise of his powers under Articles 4(8) and 8 of the Water Authorities (Control of Discharges) Order 1978 (SI 1978 No 1210), the conditions imposed on the said consent shall be varied in the following terms:

CONDITIONS

The quality and quantity of effluent shall not exceed the following maximum values:

Biochemical Oxygen Demand (+ ATU) over 5 days at 20°C:.....150..... milligrames per litre.

Suspended Solids dried at 105°C:150..... milligrams per litre.

Ammoniacal ammonia expressed as nitrogen50.....milligrames per litre.

Dry Weather Flow litres per second or59.8... metres cubed per day.

This variation takes effect from the .30. January 1985.

This notice should be retained with the consent dated .17. DECEMBER 1980.

George Roberts
WEP Division
Welsh Office