



Element, Unit C6, Emery Court, The Embankment Business Park, Heaton Mersey, Stockport, SK4 3GL
Your Element Contact: Glenn McMorrow (07966 879 182)
E: glenn.mcmorrow@element.com

Stack Emissions Testing Report Commissioned by
Enovert

Installation Name & Address

Enovert
Tir John Landfill Site
Port Tennant
Swansea
SA1 8LN

EPR Permit: BP3738LS

Stack Reference
Flare

Dates of the Monitoring Campaign
10th August 2023

Job Reference Number
ERE-23296

| |
|--|
| Report Written by |
| Joshua Cunningham Technician MCERTS Level 1 MM 22 1702 - |

| |
|---|
| Report Approved by |
| Darren Price Team Leader MCERTS Level 2 MM 03 176 TE1 TE2 TE3 TE4 |

| |
|--------------------|
| Report Date |
| 8th September 2023 |

| |
|----------------|
| Version |
| Version 1 |

| |
|---|
| Signature of Report Approver |
|  |

CONTENTS

TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

| | |
|---------------------------------|---|
| Monitoring Objectives | 3 |
| Monitoring Results | 4 |
| Monitoring Dates & Times | 5 |
| Process Details | 6 |
| Monitoring & Analytical Methods | 7 |
| Summary of Sampling Deviations | 7 |
| Sampling Location | 8 |
| Plant Photos / Sample Points | 9 |

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

Opinions and interpretations expressed herein are outside the scope of Element's ISO 17025 accreditation.

This test report shall not be reproduced, except in full, without the written approval of Element.

Executive Summary

(Page 1 of 7)

MONITORING OBJECTIVES

Enovert, Tir John Landfill Site

Flare

10th August 2023

Overall Aim of the Monitoring Campaign

Element were commissioned by Enovert to carry out stack emissions testing on the Flare at Tir John Landfill Site.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

Special Requirements

There were no special requirements.

Target Parameters

Total VOCs (as Carbon), Oxides of Nitrogen (as NO₂), Carbon Monoxide

Executive Summary
(Page 2 of 7)

MONITORING RESULTS

Enovert, Tir John Landfill Site
Flare
10th August 2023

where MU = Measurement Uncertainty associated with the Result

| Parameter | Concentration | | | |
|--|--------------------------------|----------------|--------|-------|
| | Units | Result | MU +/- | Limit |
| Total VOCs (as Carbon) | ¹ mg/m ³ | 2.8 | 0.75 | 10 |
| Oxides of Nitrogen (as NO ₂) | ¹ mg/m ³ | 49.5 | 3.1 | 150 |
| Carbon Monoxide | ¹ mg/m ³ | 1.2 | 1.9 | 50 |
| Oxygen | % v/v | Dry 9.9 | 0.32 | |
| Water Vapour | % v/v | 10.5 | 0.47 | |

¹ Reference Conditions (REF) are: 273K, 101.3kPa, dry gas, 3% oxygen.

Executive Summary
(Page 3 of 7)

MONITORING DATE(S) & TIMES

Enovert, Tir John Landfill Site
Flare
10th August 2023

| Parameter | Units | Concentration | | Sampling Date(s) | Sampling Times | Duration mins |
|--|----------------------|---------------|--|------------------|----------------|---------------|
| Total VOCs (as Carbon) | R1 mg/m ³ | 2.8 | | 10/08/2023 | 14:30 - 15:30 | 60 |
| Oxides of Nitrogen (as NO ₂) | R1 mg/m ³ | 49.5 | | 10/08/2023 | 14:30 - 15:30 | 60 |
| Carbon Monoxide | R1 mg/m ³ | 1.2 | | 10/08/2023 | 14:30 - 15:30 | 60 |
| Oxygen | R1 % v/v | 9.9 | | 10/08/2023 | 14:30 - 15:30 | 60 |
| Water Vapour | R1 % v/v | 10.5 | | 10/08/2024 | 14:30 - 15:30 | 60 |

All results are expressed at the respective reference conditions.

Executive Summary
(Page 4 of 7)

PROCESS DETAILS

Enovert, Tir John Landfill Site
Flare
10th August 2023

Standard Operating Conditions

| Parameter | Value |
|--------------------------------------|------------------|
| Process Status | Operating |
| Capacity (of 100%) and Tonnes / Hour | 495 m3/hr |
| Continuous or Batch Process | Batch |
| Feedstock (if applicable) | N/A |
| Abatement System | None |
| Abatement System Running Status | N/A |
| Fuel | Landfill Gas |
| Plume Appearance | No visible plume |

Executive Summary

(Page 5 of 7)

MONITORING & ANALYTICAL METHODS

Enovert, Tir John Landfill Site

Flare

10th August 2023

| Parameter | Monitoring | | | | Analysis | | | | Overall Status | LOD (Average) |
|--|---------------|---------------------|-----------------|-------------|---|----------------------|-----------------|--------------|------------------------|---------------|
| | Standard | Technical Procedure | Sampling Status | Testing Lab | Analytical Procedure | Analytical Technique | Analysis Status | Analysis Lab | | |
| Water Vapour | EN 14790 | CAT-TP-05 | MCERTS | EET | CAT-TP-05 | Gravimetric | MCERTS | EET | MCERTS | 0.10 % v/v |
| Total VOCs (as Carbon) | EN 12619:2013 | CAT-TP-20 | MCERTS | EET | Flame Ionisation Detection by Signal 3010HM | | | MCERTS | 0.32 mg/m ³ | |
| Oxides of Nitrogen (as NO ₂) | EN 14792 | CAT-TP-21 | MCERTS | EET | Chemiluminescence by Horiba PG-250 | | | MCERTS | 0.41 mg/m ³ | |
| Carbon Monoxide | EN 15058 | CAT-TP-21 | MCERTS | EET | NDIR by Horiba PG-250 | | | MCERTS | 0.71 mg/m ³ | |
| Oxygen | EN 14789 | CAT-TP-21 | MCERTS | EET | Dry Zirconia Cell by Horiba PG-250 | | | MCERTS | 0.1 % | |

ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

| | |
|-------------------------------|--------------------------------------|
| Element (Stockport Lab - EET) | ISO 17025 Accreditation Number: 4279 |
|-------------------------------|--------------------------------------|

SUMMARY OF SAMPLING DEVIATIONS

| Parameter | Run | Deviation |
|-----------|-----|--|
| All | All | There are no deviations associated with the sampling employed. |

Executive Summary

(Page 6 of 7)

SUITABILITY OF SAMPLING LOCATION

Duct Characteristics

| Parameter | Units | Value |
|---------------------|----------------|---------------|
| Type | - | Circular |
| Depth | m | 1.80 |
| Width | m | - |
| Area | m ² | 2.55 |
| Port Depth | cm | N/A Mast Used |
| Orientation of Duct | - | Vertical |
| Number of Ports | - | N/A Mast Used |
| Sample Port Size | - | N/A Mast Used |

Location of Sampling Platform

| General Platform Information | Value |
|--------------------------------|-----------|
| Permanent / Temporary Platform | On Ground |
| Inside / Outside | Outside |

Platform Details

| EA Technical Guidance Note M1 / EN 15259 Platform Requirements | Value |
|---|-------|
| Sufficient working area to manipulate probe and operate the measuring instruments | Yes |
| Platform has 2 levels of handrails (approx. 0.5m & 1.0m high) | N/A |
| Platform has vertical base boards (approx. 0.25m high) | N/A |
| Platform has chains / self closing gates at top of ladders | N/A |
| There are no obstructions present which hamper insertion of sampling equipment | Yes |
| Safe Access Available | Yes |
| Easy Access Available | Yes |

Sampling Location / Platform Improvement Recommendations

Due to the nature of the access into the duct, it is not possible to conduct a full velocity profile, however no particulate phase sampling was required and all gaseous species were considered to be mixed sufficiently for the purposes of these tests. There is also no requirement to undertake a homogeneity test as per EN 15259 and as such the location cannot be compared against that or the criteria within TGN M1. The sampling location used in this instance has been approved for use by the Environment Agency.

EN 15259 Homogeneity Test Requirements

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.


Executive Summary
(Page 7 of 7)

PLANT PHOTOS

Photo 1



SAMPLE POINTS



- where**
- = isokinetic point sampled at
 - = isokinetic point not sampled at
 - = combustion gases sample point
 - = non-isokinetic sample point

APPENDICES

APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 1

STACK EMISSIONS MONITORING PERSONNEL

| Position | Name | MCERTS Accreditation | MCERTS Number | Technical Endorsements |
|-------------|-------------------|----------------------|---------------|------------------------|
| Team Leader | Darren Price | MCERTS Level 2 | MM 03 176 | TE1 TE2 TE3 TE4 |
| Technician | Joshua Cunningham | MCERTS Level 1 | MM 22 1704 | - |

LIST OF EQUIPMENT

| Extractive Sampling | | Instrumental Analysers | | Miscellaneous Items | |
|--------------------------|----------------|--------------------------------|----------------|----------------------------------|----------------|
| Equipment Type | Equipment I.D. | Equipment Type | Equipment I.D. | Equipment Type | Equipment I.D. |
| Control Box DGM (1) | - | Horiba PG-250 | CAT 9.26 | Digital Manometer (1) | - |
| Control Box DGM (2) | - | Horiba PG-250 SRM | - | Digital Manometer (2) | - |
| Box Thermocouples (1) | - | Servomex 5200 MP | - | Digital Temperature Meter | CAT 3.294 |
| Box Thermocouples (2) | - | Eco Physics CLD 822Mh | - | Stopwatch | - |
| Umbilical (1) | - | ABB AO2020-URAS26 | - | Barometer | - |
| Umbilical (2) | - | Testo 350 XL | - | Stack Thermocouple (1) | CAT 4.1676 |
| Oven Box (1) | - | Signal 200SM | CAT 4.00168 | Stack Thermocouple (2) | - |
| Oven Box (2) | - | Gasmet DX4000 | - | Stack Thermocouple (3) | - |
| Heated Probe (1) | - | Gasmet Sampling System | - | 1m Heated Line (1) | - |
| Heated Probe (2) | - | Signal 3010HM | CAT 8.50 | 1m Heated Line (2) | - |
| Heated Probe (3) | - | M&C PSS | CAT 12.168 | 1m Heated Line (3) | - |
| S-Pitot (1) | - | Mass Flow Controller (1) | - | 5m Heated Line (1) | - |
| S-Pitot (2) | - | Mass Flow Controller (2) | - | 15m Heated Line (1) | - |
| L-Pitot | - | Mass View (1) | CAT 25.106 | 20m Heated Line (1) | CAT 20.1023 |
| Site Balance | CAT 17.82 | Mass View (2) | CAT 25.107 | 20m Heated Line (2) | - |
| 500g / 1Kg Check Weights | CAT 17.82 | Squirrel 2020 | CAT DL#04 | Dual Channel Heater Controller | - |
| Last Impinger Arm | - | Easylogger EN-EL-12 Bit | - | Single Channel Heater Controller | CAT 20.1023 |
| Callipers | - | Bioaerosols Temperature Logger | - | Laboratory Balance | - |
| Tubes Kit Thermocouple | - | Electronic Refrigerator | - | Tape Measure | CAT 16.144 |

METHODS & TECHNICAL PROCEDURES USED

| Parameter | Standard | Technical Procedure |
|--|---------------|---------------------|
| Water Vapour | EN 14790 | CAT-TP-05 |
| Total VOCs (as Carbon) | EN 12619:2013 | CAT-TP-20 |
| Oxides of Nitrogen (as NO ₂) | EN 14792 | CAT-TP-21 |
| Carbon Monoxide | EN 15058 | CAT-TP-21 |
| Oxygen | EN 14789 | CAT-TP-21 |

WATER VAPOUR: RESULTS SUMMARY

Enovert, Tir John Landfill Site
Flare

Sample Runs

| Parameter | Units | Run 1 | Mean |
|---------------|--------|-------|------|
| Concentration | % v/v | 10.5 | 10.5 |
| Uncertainty | ±% v/v | 0.47 | 0.47 |

General Sampling Information

| Parameter | Value |
|---------------------|-----------|
| Standard | EN 14790 |
| Technical Procedure | CAT-TP-05 |

WATER VAPOUR: SAMPLING DETAILS

Sample Runs

| Parameter | Units | Run 1 |
|----------------------------|----------------|---------------|
| Sampling Times | - | 14:30 - 15:30 |
| Sampling Dates | - | 10/08/2024 |
| Sampling Device | - | MFC / MV |
| Duration | mins | 60 |
| Volume Sampled (STP, Dry) | m ³ | 0.3131 |
| Volume Sampled (STP, Wet) | m ³ | 0.3497 |
| Sample Flow Rate | l/min | 5.05 |
| Liquid Trap Start Mass | g | 2501.4 |
| Liquid Trap End Mass | g | 2521.7 |
| Silica Trap Start Mass | g | 931.4 |
| Silica Trap End Mass | g | 940.5 |
| Total Mass Of Water Vapour | g | 29.4 |
| Calculated Water Vapour | % v/v | 10.48 |

Where: MFC stands for Mass Flow Controller, MV stands for Mass View Flowmeter

WATER VAPOUR: QUALITY ASSURANCE

Sample Runs

| Leak Test Results | Units | Run 1 |
|-------------------------|-------|-------|
| Mean Sampling Rate | l/min | 5.0 |
| Pre-Sampling Leak Rate | l/min | 0.08 |
| Post-Sampling Leak Rate | l/min | 0.08 |
| Allowable Leak Rate | l/min | 0.10 |
| Leak Test Acceptable | - | Yes |

| Water Droplets | Units | Run 1 |
|----------------------------|-------|-------|
| Are Water Droplets Present | - | No |

| Measurement Uncertainty | Units | Run 1 |
|------------------------------|-------|-------|
| Measurement Uncertainty (MU) | % | 4.5 |
| Allowable MU | % | 20.0 |
| MU Acceptable | % | Yes |

| Silica Gel | Units | Run 1 |
|---------------------|-------|-------|
| Less than 50% Faded | % | Yes |

| Test Conditions | Units | Run 1 |
|-------------------------------|-------|-------|
| Ambient Temperature Recorded? | - | No |

Method Deviations

| Nature of Deviation | Run Number |
|--|------------|
| (x = deviation applies to the associated run) | 1 |
| There are no deviations associated with the sampling employed. | x |

WATER VAPOUR: MEASUREMENT UNCERTAINTY CALCULATIONS

| Measured Quantities | Value | | Standard uncertainty | | |
|---------------------------|----------------|--------|----------------------|----------------|--------|
| | Symbol | Run 1 | Symbol | Units | Run 1 |
| Sampled Volume (STP) | V _m | 0.3131 | uV _m | m ³ | 0.0063 |
| Repeatability of Weighing | R _w | 29.40 | uR _w | g | 0.12 |
| Reading of Balance | R _b | 29.40 | uR _b | g | 0.15 |
| Leak | L | 1.58 | | % | - |

| Measured Quantities | Uncertainty as a Percentage | | Requirement of Standard |
|---------------------------|-----------------------------|-------|-------------------------|
| | Units | Run 1 | |
| Sampled Volume (STP) | % | 2.00 | ≤2% |
| Repeatability of Weighing | % | 0.41 | No Requirement |
| Reading of Balance | % | 0.50 | No Requirement |
| Leak | % | 1.58 | ≤2% |

| Measured Quantities | Uncertainty in Measurement Units | | | Sensitivity Coefficient |
|---------------------------|----------------------------------|----------------|--------|-------------------------|
| | Symbol | Units | Run 1 | |
| Sampled Volume (STP) | V _m | m ³ | 0.3131 | 33.46 |
| Repeatability of Weighing | R _w | g | 29.40 | 0.36 |
| Reading of Balance | R _b | g | 29.40 | 0.36 |
| Leak | L | % v/v | 0.10 | 1.00 |

| Measured Quantities | Uncertainty in Result | |
|---------------------------|-----------------------|-------|
| | Units | Run 1 |
| Sampled Volume (STP) | % v/v | 0.210 |
| Repeatability of Weighing | % v/v | 0.043 |
| Reading of Balance | % v/v | 0.052 |
| Leak | % v/v | 0.096 |

| Parameter | Units | Run 1 |
|---|-------|-------|
| Combined uncertainty | % v/v | 0.24 |
| Expanded uncertainty (95% confidence) | % v/v | 0.47 |
| Expanded uncertainty (95% confidence), estimated with Method Deviations | % v/v | 0.47 |
| Uncertainty if Water Droplets are present | % v/v | N/A |
| Reported Uncertainty | % v/v | 0.47 |
| Expanded uncertainty (95% confidence) | % | 4.5 |
| Expanded uncertainty (95% confidence), estimated with Method Deviations | % | 4.5 |
| Uncertainty if Water Droplets are present | % | N/A |
| Reported Uncertainty | % | 4.5 |

APPENDIX 2

TOTAL VOCs (as CARBON): RESULTS SUMMARY

Enovert, Tir John Landfill Site
Flare

Sample Runs

| Parameter | Units | Run 1 | Mean |
|---------------|--------------------|-------|------|
| Concentration | mg/m ³ | 2.8 | 2.8 |
| Uncertainty | ±mg/m ³ | 0.75 | 0.75 |

General Sampling Information


| Parameter | Value | |
|----------------------------------|------------------------------------|---------------------------------------|
| Standard | EN 12619:2013 | |
| Technical Procedure | CAT-TP-20 | |
| Probe Material | Stainless Steel | |
| Filtration Type / Size | 0.1µm Glass Fibre | |
| Heated Head Filter Used | Yes | |
| Heated Line Temperature | 180°C | |
| Span Gas Type | Propane In Synthetic Air (5 Grade) | |
| Span Gas Reference Number | 12.0470 | |
| Span Gas Expiry Date | 21/09/2024 | |
| Span Gas Start Pressure (bar) | 50 | |
| Gas Cylinder Concentration (ppm) | 8.5 | |
| Span Gas Set Point (ppm) | 8.50 | |
| Span Gas Uncertainty (%) | 2 | |
| Zero Gas Type | Synthetic Air (5 Grade) | |
| Number of Sampling Lines Used | 1/1 | FORMAT: Number Used / Number Required |
| Number of Sampling Points Used | 1/1 | FORMAT: Number Used / Number Required |
| Sample Point I.D.'s | A1 | |

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas, 3% oxygen.

TOTAL VOCs (as CARBON): DATA TREND

Graphical Trend of Data



TOTAL VOCs (as CARBON): SAMPLING DETAILS & QUALITY ASSURANCE

Sampling Details

| Parameter | Units | Run 1 |
|------------------|-------|---------------|
| Sampling Times | - | 14:30 - 15:30 |
| Sampling Dates | - | 10/08/2023 |
| Instrument Range | ppm | 100 |
| Span Gas Value | ppm | 8.5 |

Quality Assurance

| Zero Drift | | Units | Run 1 |
|-------------------------------|--------------------------------|-------|---------|
| CAL 1 | Zero Down Sampling Line (Pre) | ppm | 0.00 |
| | Zero Down Sampling Line (Post) | ppm | 0.30 |
| | Zero Drift | ppm | 0.30 |
| | Zero Drift | % | 3.53 |
| | Drift Correction Applied | 2-5% | Yes |
| | Allowable Zero Drift | ± ppm | 0.43 |
| | Zero Drift Acceptable | - | #REF! |
| | Span Drift | | Units |
| CAL 1 | Span Down Sampling Line (Pre) | ppm | 8.50 |
| | Span Down Sampling Line (Post) | ppm | 8.20 |
| | Span Drift | ppm | -0.30 |
| | Span Drift | % | -3.53 |
| | Drift Correction Applied | 2-5% | Yes |
| | Allowable Span Drift | ± ppm | 0.43 |
| | Span Drift Acceptable | - | Yes |
| | Test Conditions | | Units |
| Run Ambient Temperature Range | | °C | 22 - 26 |

Method Deviations

| Nature of Deviation | Run Number |
|--|------------|
| (x = deviation applies to the associated run) | 1 |
| There are no deviations associated with the sampling employed. | x |

TOTAL VOCs (as CARBON): MEASUREMENT UNCERTAINTY CALCULATIONS

| Performance characteristics | RUN 1 | Units |
|-----------------------------|-------|------------------------------|
| Limit value | 10.0 | mg/m ³ (REF) |
| Allowable MU | 15.0 | % |
| Measured concentration | 1.71 | mg/m ³ (STP, dry) |
| Range Used | 100.0 | ppm |
| Range Used [A] | 160.6 | mg/m ³ |
| Cal gas conc. | 8.5 | ppm |
| Conversion | 1.61 | ppm to mg/m ³ |
| MCERTS Range [B] | 15.0 | mg/m ³ |
| Lower of [A] or [B] | 15.0 | mg/m ³ |
| Cal gas conc. | 13.7 | mg/m ³ |

| Performance characteristics | RUN 1 | Units |
|------------------------------------|-------|------------------|
| Response time | 15 | seconds |
| Number of readings in measurement | 60 | - |
| Repeatability at zero | 0.15 | % full scale |
| Repeatability at span level | 0.80 | % full scale |
| Deviation from linearity | 0.10 | % of value |
| Zero drift | 0.00 | % full scale |
| Span drift | 0.00 | % full scale |
| Volume or pressure flow dependence | 2.00 | % of full scale |
| Atmospheric pressure dependence | 0.80 | % of value/kPa |
| Ambient temperature dependence | 1.00 | % full scale/10K |
| Combined interference | 1.20 | % range |
| Dependence on voltage | 0.10 | % full scale/10V |
| Losses in the line (leak) | 1.18 | % of value |
| Uncertainty of calibration gas | 2.00 | % of value |

| Performance characteristic | RUN 1 | Units |
|---|-----------------|-------------------|
| Standard deviation of repeatability at zero | use rep at span | mg/m ³ |
| Standard deviation of repeatability at span level | 0.10 | mg/m ³ |
| Lack of fit | 0.01 | mg/m ³ |
| Drift | 0.00 | mg/m ³ |
| Volume or pressure flow dependence | 0.00 | mg/m ³ |
| Atmospheric pressure dependence | 0.03 | mg/m ³ |
| Ambient temperature dependence | 0.14 | mg/m ³ |
| Combined interference (from MCERTS Certificate) | 0.10 | mg/m ³ |
| Dependence on voltage | 0.01 | mg/m ³ |
| Losses in the line (leak) | 0.01 | mg/m ³ |
| Uncertainty of calibration gas | 0.02 | mg/m ³ |

| Measurement uncertainty | Result | RUN 1 | Units |
|---|----------|-------|-------------------------|
| Combined uncertainty | | 1.71 | mg/m ³ |
| Expanded uncertainty | k = 1.96 | 0.23 | mg/m ³ |
| Expanded uncertainty | | 0.46 | mg/m ³ |
| Uncertainty corrected to std conds. (O ₂) | | 0.75 | mg/m ³ (REF) |

| | RUN 1 | Units |
|--|------------|------------|
| Expanded uncertainty (no O ₂) - at 95% Confidence | 26.88 | % of Value |
| Expanded uncertainty (no O ₂) - at 95% Confidence | 4.60 | % at ELV |
| Overall Allowable uncertainty (no O ₂) - at 95% Confidence | 15.0 | % at ELV |
| Result of Compliance with Uncertainty Requirement | N/A | - |

| | RUN 1 | Units |
|--|------------------|------------|
| Expanded uncertainty (with O ₂) - at 95% Confidence | 27.08 | % of Value |
| Expanded uncertainty (with O ₂) - at 95% Confidence | 8.14 | % at ELV |
| Overall Allowable uncertainty (with O ₂) - at 95% Confidence | 15.3 | % at ELV |
| Result of Compliance with Uncertainty Requirement | COMPLIANT | - |

Requirement for SRM is that Uncertainty should be <15% of the value at the ELV, on a dry gas basis, or if O₂ correction is applied less than 15% + the uncertainty associated with the O₂ correction (using sqrt of sum squares to add uncertainty components).

APPENDIX 2

OXIDES OF NITROGEN (as NO₂): RESULTS SUMMARY

Enovert, Tir John Landfill Site
Flare

Sample Runs

| Parameter | Units | Run 1 | Mean |
|---------------|--------------------|-------|------|
| Concentration | mg/m ³ | 49.5 | 49.5 |
| Uncertainty | ±mg/m ³ | 3.1 | 3.1 |

General Sampling Information


| Parameter | Value | |
|---------------------------------------|--------------------|---------------------------------------|
| Standard | EN 14792 | |
| Technical Procedure | CAT-TP-21 | |
| Probe Material | Stainless Steel | |
| Filtration Type / Size | 0.1µm Glass Fibre | |
| Heated Head Filter Used | Yes | |
| Heated Line Temperature | 180°C | |
| Date & Result of Last Converter Check | 13/10/2022 - 95.5% | |
| Span Gas Type | Nitrogen Monoxide | |
| Span Gas Reference Number | 12.0493 | |
| Span Gas Expiry Date | 11/01/2025 | |
| Span Gas Start Pressure (bar) | 180 | |
| Gas Cylinder Concentration (ppm) | 89.6 | |
| Span Gas Uncertainty (%) | 2 | |
| Zero Gas Type | Nitrogen (5 Grade) | |
| Number of Sampling Lines Used | 1/1 | FORMAT: Number Used / Number Required |
| Number of Sampling Points Used | 1/1 | FORMAT: Number Used / Number Required |
| Sample Point I.D.'s | A1 | |

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas, 3% oxygen.

OXIDES OF NITROGEN (as NO₂): DATA TREND

Graphical Trend of Data



APPENDIX 2

OXIDES OF NITROGEN (as NO₂): SAMPLING DETAILS & QUALITY ASSURANCE

Sampling Details

| Parameter | Units | Run 1 |
|------------------|-------|---------------|
| Sampling Times | - | 14:30 - 15:30 |
| Sampling Dates | - | 10/08/2023 |
| Instrument Range | ppm | 250 |
| Span Gas Value | ppm | 89.6 |

Quality Assurance

| Conditioning Unit Temperature | Units | Run 1 | |
|-------------------------------|--------------------------|---------|-------|
| Average Temperature | °C | 3.7 | |
| Allowable Temperature | < °C | 4.0 | |
| Temperature Acceptable | - | Yes | |
| Zero Drift | Units | Run 1 | |
| CAL 1 | Zero at Analyser (Pre) | ppm | 0.00 |
| | Zero at Analyser (Post) | ppm | -0.30 |
| | Zero Drift | ppm | -0.30 |
| | Zero Drift | % | 0.33 |
| | Drift Correction Applied | 2-5% | No |
| | Allowable Zero Drift | ± % | 5.00 |
| | Zero Drift Acceptable | - | Yes |
| Span Drift | Units | Run 1 | |
| CAL 1 | Span at Analyser (Pre) | ppm | 89.60 |
| | Span at Analyser (Post) | ppm | 85.50 |
| | Span Drift | ppm | -4.10 |
| | Zero Adj. Span Drift | % | 4.24 |
| | Drift Correction Applied | 2-5% | Yes |
| | Allowable Span Drift | ± % | 5.00 |
| | Span Drift Acceptable | - | Yes |
| Test Conditions | Units | Run 1 | |
| Run Ambient Temperature Range | °C | 22 - 26 | |

Method Deviations

| Nature of Deviation | Run Number |
|--|------------|
| (x = deviation applies to the associated run) | 1 |
| There are no deviations associated with the sampling employed. | x |

OXIDES OF NITROGEN (as NO₂): MEASUREMENT UNCERTAINTY CALCULATIONS

| Performance characteristics | RUN 1 | Units |
|-----------------------------|-------|------------------------------|
| Limit value | 150.0 | mg/m ³ (REF) |
| Allowable MU | 10.0 | % |
| Measured concentration | 30.47 | mg/m ³ (STP, dry) |
| Ratio NO / NO ₂ | 5 | % |
| Range Used | 250.0 | ppm |
| Range Used [A] | 513.1 | mg/m ³ |
| Cal gas conc. | 89.6 | ppm |
| Conversion | 2.05 | ppm to mg/m ³ |
| MCERTS Range [B] | 125.0 | mg/m ³ |
| Lower of [A] or [B] | 125.0 | mg/m ³ |
| Cal gas conc. | 183.9 | mg/m ³ |

| Performance characteristics | RUN 1 | Units |
|---|-------|------------------|
| Response time | 60 | seconds |
| Number of readings in measurement | 60 | - |
| Repeatability at zero | 0.40 | % full scale |
| Repeatability at span level | 0.40 | % full scale |
| Deviation from linearity | 0.36 | % of value |
| Zero drift | -0.33 | % full scale |
| Span drift | 0.00 | % full scale |
| Volume or pressure flow dependence | 0.40 | % of full scale |
| Atmospheric pressure dependence | 0.30 | % of value/kPa |
| Ambient temperature dependence | 0.18 | % full scale/10K |
| Combined interference | 0.60 | % range |
| Dependence on voltage | 0.40 | % full scale/10V |
| Converter efficiency | 95.5 | % |
| Losses in the line (leak) | 1.23 | % of value |
| Uncertainty of calibration gas blending | 1.40 | % of value |
| Uncertainty of calibration gas | 2.00 | % of value |

| Performance characteristic | RUN 1 | Units |
|---|-----------------|-------------------|
| Standard deviation of repeatability at zero | use rep at span | mg/m ³ |
| Standard deviation of repeatability at span level | 0.05 | mg/m ³ |
| Lack of fit | 0.26 | mg/m ³ |
| Drift | 0.00 | mg/m ³ |
| Volume or pressure flow dependence | 0.00 | mg/m ³ |
| Atmospheric pressure dependence | 0.11 | mg/m ³ |
| Ambient temperature dependence | 0.03 | mg/m ³ |
| Combined interference (from MCERTS Certificate) | 0.43 | mg/m ³ |
| Dependence on voltage | 0.05 | mg/m ³ |
| Converter efficiency | 0.04 | mg/m ³ |
| Losses in the line (leak) | 0.22 | mg/m ³ |
| Uncertainty of calibration gas blending | 0.25 | mg/m ³ |
| Uncertainty of calibration gas | 0.35 | mg/m ³ |

| Measurement uncertainty | Result | RUN 1 | Units |
|---|----------|-------|-------------------------|
| Combined uncertainty | | 30.47 | mg/m ³ |
| Expanded uncertainty | | 0.83 | mg/m ³ |
| Expanded uncertainty | k = 1.96 | 1.63 | mg/m ³ |
| Uncertainty corrected to std conds. (O ₂) | | 2.65 | mg/m ³ (REF) |

| | RUN 1 | Units |
|--|------------|------------|
| Expanded uncertainty (no O ₂) - at 95% Confidence | 5.35 | % of Value |
| Expanded uncertainty (no O ₂) - at 95% Confidence | 1.09 | % at ELV |
| Overall Allowable uncertainty (no O ₂) - at 95% Confidence | 10.0 | % at ELV |
| Result of Compliance with Uncertainty Requirement | N/A | - |

| | RUN 1 | Units |
|--|------------------|------------|
| Expanded uncertainty (with O ₂) - at 95% Confidence | 6.26 | % of Value |
| Expanded uncertainty (with O ₂) - at 95% Confidence | 3.70 | % at ELV |
| Overall Allowable uncertainty (with O ₂) - at 95% Confidence | 10.5 | % at ELV |
| Result of Compliance with Uncertainty Requirement | COMPLIANT | - |

Requirement for SRM is that Uncertainty should be <10% of the value at the ELV, on a dry gas basis, or if O₂ correction is applied less than 10% + the uncertainty associated with the O₂ correction (using sqrt of sum squares to add uncertainty components).

APPENDIX 2

CARBON MONOXIDE: RESULTS SUMMARY

Enovert, Tir John Landfill Site
Flare

Sample Runs

| Parameter | Units | Run 1 | Mean |
|---------------|--------------------|-------|------|
| Concentration | mg/m ³ | 1.2 | 1.2 |
| Uncertainty | ±mg/m ³ | 1.9 | 1.9 |

General Sampling Information

| Parameter | Value | |
|----------------------------------|--------------------|---------------------------------------|
| Standard | EN 15058 | |
| Technical Procedure | CAT-TP-21 | |
| Probe Material | Stainless Steel | |
| Filtration Type / Size | 0.1µm Glass Fibre | |
| Heated Head Filter Used | Yes | |
| Heated Line Temperature | 180°C | |
| Span Gas Type | Carbon Monoxide | |
| Span Gas Reference Number | 12.0498 | |
| Span Gas Expiry Date | 11/01/2025 | |
| Span Gas Start Pressure (bar) | 180 | |
| Gas Cylinder Concentration (ppm) | 149.1 | |
| Span Gas Uncertainty (%) | 2 | |
| Zero Gas Type | Nitrogen (5 Grade) | |
| Number of Sampling Lines Used | 1/1 | FORMAT: Number Used / Number Required |
| Number of Sampling Points Used | 1/1 | FORMAT: Number Used / Number Required |
| Sample Point I.D.'s | A1 | |


Reference Conditions

Reference Conditions are: 273K, 101.3kPa, dry gas, 3% oxygen.

APPENDIX 2

CARBON MONOXIDE: DATA TREND

Graphical Trend of Data



APPENDIX 2

CARBON MONOXIDE: SAMPLING DETAILS & QUALITY ASSURANCE

Sampling Details

| Parameter | Units | Run 1 |
|------------------|-------|---------------|
| Sampling Times | - | 14:30 - 15:30 |
| Sampling Dates | - | 10/08/2023 |
| Instrument Range | ppm | 2000 |
| Span Gas Value | ppm | 149.1 |

Quality Assurance

| Conditioning Unit Temperature | Units | Run 1 | |
|-------------------------------|--------------------------|---------|--------|
| Average Temperature | °C | 3.7 | |
| Allowable Temperature | < °C | 4.0 | |
| Temperature Acceptable | - | Yes | |
| Zero Drift | Units | Run 1 | |
| CAL 1 | Zero at Analyser (Pre) | ppm | 1.00 |
| | Zero at Analyser (Post) | ppm | -1.50 |
| | Zero Drift | ppm | -2.50 |
| | Zero Drift | % | 1.65 |
| | Drift Correction Applied | 2-5% | No |
| | Allowable Zero Drift | ± % | 5.00 |
| | Zero Drift Acceptable | - | Yes |
| Span Drift | Units | Run 1 | |
| CAL 1 | Span at Analyser (Pre) | ppm | 151.80 |
| | Span at Analyser (Post) | ppm | 148.00 |
| | Span Drift | ppm | -3.80 |
| | Zero Adj. Span Drift | % | 0.87 |
| | Drift Correction Applied | 2-5% | No |
| | Allowable Span Drift | ± % | 5.00 |
| | Span Drift Acceptable | - | Yes |
| Test Conditions | Units | Run 1 | |
| Run Ambient Temperature Range | °C | 22 - 26 | |

Method Deviations

| Nature of Deviation | Run Number |
|--|------------|
| (x = deviation applies to the associated run) | 1 |
| There are no deviations associated with the sampling employed. | x |

CARBON MONOXIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

| Performance characteristics | RUN 1 | Units |
|-----------------------------|--------|------------------------------|
| Limit value | 50.0 | mg/m ³ (REF) |
| Allowable MU | 6.0 | % |
| Measured concentration | 0.71 | mg/m ³ (STP, dry) |
| Range Used | 2000.0 | ppm |
| Range Used [A] | 2498.4 | mg/m ³ |
| Cal gas conc. | 149.1 | ppm |
| Conversion | 1.25 | ppm to mg/m ³ |
| MCERTS Range [B] | 95.0 | mg/m ³ |
| Lower of [A] or [B] | 95.0 | mg/m ³ |
| Cal gas conc. | 186.3 | mg/m ³ |

| Performance characteristics | RUN 1 | Units |
|---|-------|------------------|
| Response time | 60 | seconds |
| Number of readings in measurement | 60 | - |
| Repeatability at zero | 0.40 | % full scale |
| Repeatability at span level | 0.40 | % full scale |
| Deviation from linearity | 0.36 | % of value |
| Zero drift | -1.65 | % full scale |
| Span drift | -0.87 | % full scale |
| Volume or pressure flow dependence | 0.40 | % of full scale |
| Atmospheric pressure dependence | 0.30 | % of value/kPa |
| Ambient temperature dependence | 0.05 | % full scale/10K |
| Combined interference | 0.73 | % range |
| Dependence on voltage | 0.40 | % full scale/10V |
| Losses in the line (leak) | 0.07 | % of value |
| Uncertainty of calibration gas blending | 1.40 | % of value |
| Uncertainty of calibration gas | 2.00 | % of value |

| Performance characteristic | RUN 1 | Units |
|---|-----------------|-------------------|
| Standard deviation of repeatability at zero | use rep at span | mg/m ³ |
| Standard deviation of repeatability at span level | 0.05 | mg/m ³ |
| Lack of fit | 0.20 | mg/m ³ |
| Drift | 0.00 | mg/m ³ |
| Volume or pressure flow dependence | 0.00 | mg/m ³ |
| Atmospheric pressure dependence | 0.08 | mg/m ³ |
| Ambient temperature dependence | 0.01 | mg/m ³ |
| Combined interference (from MCERTS Certificate) | 0.40 | mg/m ³ |
| Dependence on voltage | 0.05 | mg/m ³ |
| Losses in the line (leak) | 0.00 | mg/m ³ |
| Uncertainty of calibration gas blending | 0.01 | mg/m ³ |
| Uncertainty of calibration gas | 0.01 | mg/m ³ |

| Measurement uncertainty | Result | RUN 1 | Units |
|---|----------|-------|-------------------------|
| Measurement uncertainty | | 0.71 | mg/m ³ |
| Combined uncertainty | | 0.61 | mg/m ³ |
| Expanded uncertainty | k = 1.96 | 1.19 | mg/m ³ |
| Uncertainty corrected to std conds. (O ₂) | | 1.93 | mg/m ³ (REF) |

| | RUN 1 | Units |
|--|------------|------------|
| Expanded uncertainty (no O ₂) - at 95% Confidence | 166.71 | % of Value |
| Expanded uncertainty (no O ₂) - at 95% Confidence | 2.37 | % at ELV |
| Overall Allowable uncertainty (no O ₂) - at 95% Confidence | 6.0 | % at ELV |
| Result of Compliance with Uncertainty Requirement | N/A | - |

| | RUN 1 | Units |
|--|------------------|------------|
| Expanded uncertainty (with O ₂) - at 95% Confidence | 166.74 | % of Value |
| Expanded uncertainty (with O ₂) - at 95% Confidence | 5.04 | % at ELV |
| Overall Allowable uncertainty (with O ₂) - at 95% Confidence | 6.8 | % at ELV |
| Result of Compliance with Uncertainty Requirement | COMPLIANT | - |

Requirement for SRM is that Uncertainty should be <6% of the value at the ELV, on a dry gas basis, or if O₂ correction is applied less than 6% + the uncertainty associated with the O₂ correction (using sqrt of sum squares to add uncertainty components).

APPENDIX 2

OXYGEN: RESULTS SUMMARY

Enovert, Tir John Landfill Site
Flare

Sample Runs

| Parameter | Units | Run 1 | Mean |
|---------------|--------|-------|------|
| Concentration | % v/v | 9.9 | 9.9 |
| Uncertainty | ±% v/v | 0.32 | 0.32 |


General Sampling Information

| Parameter | Value | |
|------------------------------------|-------------------------|---------------------------------------|
| Standard | EN 14789 | |
| Technical Procedure | CAT-TP-21 | |
| Probe Material | Stainless Steel | |
| Filtration Type / Size | 0.1µm Glass Fibre | |
| Heated Head Filter Used | Yes | |
| Heated Line Temperature | 180°C | |
| Span Gas Type | Synthetic Air (5 Grade) | |
| Span Gas Reference Number | 12.047 | |
| Span Gas Expiry Date | 21/09/2024 | |
| Span Gas Start Pressure (bar) | 50 | |
| Gas Cylinder Concentration (% v/v) | 7.8 | |
| Span Gas Uncertainty (%) | 2 | |
| Zero Gas Type | Nitrogen (5 Grade) | |
| Number of Sampling Lines Used | 1/1 | FORMAT: Number Used / Number Required |
| Number of Sampling Points Used | 1/1 | FORMAT: Number Used / Number Required |
| Sample Point I.D.'s | A1 | |

APPENDIX 2

OXYGEN: DATA TREND

Graphical Trend of Data



APPENDIX 2

OXYGEN: SAMPLING DETAILS & QUALITY ASSURANCE

Sampling Details

| Parameter | Units | Run 1 |
|------------------|-------|---------------|
| Sampling Times | - | 14:30 - 15:30 |
| Sampling Dates | - | 10/08/2023 |
| Instrument Range | % v/v | 25.0 |
| Span Gas Value | % v/v | 7.8 |

Quality Assurance

| Conditioning Unit Temperature | Units | Run 1 | |
|-------------------------------|--------------------------|---------|-------|
| Average Temperature | °C | 3.7 | |
| Allowable Temperature | < °C | 4.0 | |
| Temperature Acceptable | - | Yes | |
| Zero Drift | Units | Run 1 | |
| CAL 1 | Zero at Analyser (Pre) | % v/v | 0.05 |
| | Zero at Analyser (Post) | % v/v | 0.08 |
| | Zero Drift | % v/v | 0.03 |
| | Zero Drift | % | 0.38 |
| | Drift Correction Applied | 2-5% | No |
| | Allowable Zero Drift | ± % | 5.00 |
| | Zero Drift Acceptable | - | Yes |
| Span Drift | Units | Run 1 | |
| CAL 1 | Span at Analyser (Pre) | % v/v | 7.98 |
| | Span at Analyser (Post) | % v/v | 7.96 |
| | Span Drift | % v/v | -0.02 |
| | Zero Adj. Span Drift | % | 0.64 |
| | Drift Correction Applied | 2-5% | No |
| | Allowable Span Drift | ± % | 5.00 |
| | Span Drift Acceptable | - | Yes |
| Test Conditions | Units | Run 1 | |
| Run Ambient Temperature Range | °C | 22 - 26 | |

Method Deviations

| Nature of Deviation | Run Number |
|--|------------|
| (x = deviation applies to the associated run) | 1 |
| There are no deviations associated with the sampling employed. | x |

OXYGEN: MEASUREMENT UNCERTAINTY CALCULATIONS

| Performance characteristics | RUN 1 | Units |
|-----------------------------|-------|-------|
| Limit value | N/A | %vol |
| Allowable MU | 6.0 | % |
| Measured concentration | 9.92 | %vol |
| Range Used | 25.0 | %vol |
| Cal gas conc. | 7.8 | %vol |

| Performance characteristics | RUN 1 | Units |
|------------------------------------|-------|------------------|
| Response time | 60 | seconds |
| Number of readings in measurement | 60 | - |
| Repeatability at zero | 0.04 | % full scale |
| Repeatability at span level | 0.04 | % full scale |
| Deviation from linearity | 0.10 | % of value |
| Zero drift | 0.38 | % full scale |
| Span drift | -0.64 | % full scale |
| Volume or pressure flow dependence | 0.20 | % of full scale |
| Atmospheric pressure dependence | 0.30 | % of value/kPa |
| Ambient temperature dependence | -0.07 | % full scale/10K |
| Combined interference | 0.56 | % range |
| Dependence on voltage | 0.02 | % full scale/10V |
| Losses in the line (leak) | 0.00 | % of value |
| Uncertainty of calibration gas | 2.00 | % of value |

| Performance characteristic | RUN 1 | Units |
|---|-----------------|-------|
| Standard deviation of repeatability at zero | use rep at span | %vol |
| Standard deviation of repeatability at span level | 0.01 | %vol |
| Lack of fit | 0.01 | %vol |
| Drift | 0.00 | %vol |
| Volume or pressure flow dependence | 0.00 | %vol |
| Atmospheric pressure dependence | 0.02 | %vol |
| Ambient temperature dependence | -0.01 | %vol |
| Combined interference (from MCERTS Certificate) | 0.08 | %vol |
| Dependence on voltage | 0.00 | %vol |
| Losses in the line (leak) | 0.00 | %vol |
| Uncertainty of calibration gas | 0.11 | %vol |

| Measurement uncertainty | Result | RUN 1 | Units |
|-------------------------|----------|-------|-------|
| Combined uncertainty | | 9.92 | %vol |
| Expanded uncertainty | k = 1.96 | 0.32 | %vol |

| | RUN 1 | Units |
|---|------------------|------------|
| Expanded uncertainty (no O ₂) - at 95% Confidence | 3.25 | % of Value |
| Result of Compliance with Uncertainty Requirement | COMPLIANT | - |

Requirement for SRM is that Uncertainty should be 0.3% vol absolute or 6% relative whichever is the lower, on a dry gas basis. Source, EN 14789.

VERSION HISTORY

| Version Number | Record of changes made within this version of the document |
|----------------|--|
| V1 | The original document issued to the client |