

Permit Number: EPR/EP3830GH

Operator: Liberty Steel UK Ltd

Facility: Liberty Steel Newport

Form Number: Water1 / 15/08/2016

**Reporting of emissions to water (other than to sewer) and land for the period from 01/07/2023 to 30/09/2023**

Emission Point	Emission			Reference Period	Result <sup>[1]</sup>	Test Method <sup>[2]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
	Substance / Parameter	Limit Value	Result <sup>[1]</sup>					
W1	Total suspended solids	20 mg/l	Spot Sample	26	BS EN 872:1996 or other ISO, BS or SCA blue book method as approved by Natural Resources Wales	11.09.2023 09.00	12.19	
W1	Total Hydrocarbons	5 mg/l	Spot Sample	0.077	SCA blue book 77 ISBN 0117517283 2002 or other ISO, BS or SCA blue book method as approved by Natural Resources Wales	21.08.2023 12.00	0.072	
W1	pH	6-10	Spot Sample	8.4	BS 6068-2.50:1995 (ISO 10523:1994)	07.07.2023 12.00	8.63	
W1	Lead	0.1 mg/l	Spot Sample	0.006	BS 6068-2.60:1998, BS EN ISO 11885 1998	07.07.2023 12.00	0.006	
W1	Arsenic	0.1 mg/l	Spot Sample	0.003	BS 6068-2.60:1998, BS EN ISO 11885 1998	07.07.2023 12.00	0.003	
W1	Cadmium	0.006 mg/l	Spot Sample	0.0006	BS 6068-2.60:1998, BS EN ISO 11885 1998	07.07.2023 12.00	0.0006	

Emission Point	Emission			Reference Period	Result <sup>[1]</sup>	Test Method <sup>[2]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
	Substance / Parameter	Limit Value						
W1	Chromium	0.2 mg/l	Spot Sample	0.007	BS 6068-2.60:1998, BS EN ISO 11885 1998	07.07.2023 12.00	0.015	
W1	Nickel	0.1 mg/l	Spot Sample	0.006	BS 6068-2.60:1998, BS EN ISO 11885 1998	07.07.2023 12.00	0.004	
W1	Copper	0.1 mg/l	Spot Sample	0.21	BS 6068-2.60:1998, BS EN ISO 11885 1998	21.08.2023 12.00	0.050	
W1	Mercury	-	Spot Sample	0.00002	BS 6068-2.60:1998, BS EN ISO 11885 1998	21.08.2023 12.00	0.00001	
W1	Iron	5 mg/l	Spot Sample	0.23	BS 6068-2.74:2002, BS EN ISO 13506:2002	07.07.2023 12.00	0.19	
W1	Zinc	0.5 mg/l	Spot Sample	0.050	BS 6068-2.60:1998, BS EN ISO 11885 1998	21.08.2023 12.00	0.026	

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[5] Metal include elements and compounds of Pb, As, Cd, Cr, Ni, Cu, Hg and Zn expressed as the metal and shall be individually reported

Signed .....

Date: 30<sup>th</sup> October 2023