

29. I was sent this form
as a result of several
telephone calls to Natural
Resources Wales.

Understood I could not have
free registration as borehole
is approx 8ft. from septic
tank. I enclose copy
of recent water test.
Water jokers have been
checked and replaced over

last 13 years.
This property is sold
now and expect to
complete in early October.

CM Thompson.

01570 423134.

To: D.M. Evans



MINTON, TREHARNE
& DAVIES GROUP

Carmarthenshire County Council, Environmental Health,
Public Health Section, Carmarthenshire County Council, Town Hall,
Iscennen Road, Ammanford, SA18 3BE.

CERTIFICATE OF WATER ANALYSIS

A sample was received on 5th June 2019 and the following information was provided:

Date sample taken: 5th June 2019 at 1100

Reference number: Pantymaen

Description etc: Well Water

Place of Sampling: Pantymaen, Callan

The sample was analysed/reported as received and the results are as follows:-

Determinand	Method	Result	Units	Limits
* ¹ Turbidity	HJE/W008	< 0.1	NTU(FTU)	4
+ ² pH @ 20°C	HJE/W006	7.5	pH Units	6.5 - 9.5
+ ³ Conductivity	HJE/W007	217	µS/cm@20°C	2500

The analysis was completed on 11th June 2019

Limits: The Private Water Supplies (Wales) Regulations 2017

-----[]-----

My opinion and observations are:-

This sample of water was clear and colourless in appearance.

This sample of water had a pH value within the currently permitted range for potable water.

This sample of water satisfied the chemical requirements of the Private Water Supplies (Wales) Regulations 2017 in respect of the tests carried out.

I further certify that the sample had undergone no change which would affect my results, opinion or observations.

Certified by me this 12th June 2019

Signature:

Name: Karen Mayne CSci, C.Chem, MRSC
Laboratory Manager (HJE)



1946

Tel: +44 (0) 29 2054 0000
Fax: +44 (0) 29 2054 0111
mtlab@minton.co.uk
hjevans@minton.co.uk

Minton, Treharne & Davies LTD.
Forest Farm Industrial Estate,
Coryton, Cardiff, CF14 7HW, UK

WWW.MINTON.GLOBAL

Registered in England No: 495262.
VAT Reg GB 135 0805 69

Registered Address: Merton House,
Croesadam Close, Parkwyn, Cardiff,
CF23 8HE, UK