

Notice of request for more information

Environmental Permitting (England and Wales)
Regulations 2016

Notice requiring further information

To: Company Secretary and/or Director
Radnor Hills
Heartsease
Knighton
Powys
LD7 1LU

Application number: PAN-023318 (EPR/AB3697CN/V003)

Natural Resources Wales, in exercise of its powers under paragraph 4 of Part 1 of Schedule 5 of the above Regulations, requires you to provide the information detailed in the attached schedule. The information is required in order to determine your application for a permit, dated 22/12/2023. The information requested should be sent to the following address by 06/03/2024.

Information should be sent to:

Permitting Service
Natural Resources Wales
Cambria House
29 Newport Road
Cardiff
CF24 0TP

Name	Date
William Wallace	21/02/2024

Authorised on behalf of Natural Resources Wales

Ffôn/Tel 0300 065 4448
Ebost/Email william.wallace@cyfoethnaturiolcymru.gov.uk
william.wallace@naturalresourceswales.gov.uk

Gwasanaeth Trwyddedu, Cyfoeth Naturiol Cymru, Tŷ Cambria, 29 Heol Casnewydd, Caerdydd. CF24 0TP
Permitting Service, Natural Resources Wales, Cambria House, 29 Newport Road, Cardiff. CF24 0TP

Gwefan/Website www.cyfoethnaturiolcymru.gov.uk
www.naturalresourceswales.gov.uk

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg
Correspondence welcomed in Welsh and English

Schedule

1. Emission limits and fuel from existing boiler A1-A4

In your air quality assessment, you have stated that all boilers (A1-A6) are liquefied petroleum gas powered. However, supporting documents from the original permit application in 2017 ([RH Environment supporting document](#)) on our public register [here](#)) and the issued permit in 2017 state that four of the boilers (A1-A4) were either natural gas powered or Calor gas after their conversion from diesel. The air quality impact assessment submitted for this application states that these boilers are running on liquefied petroleum gas (LPG) and are classified as “gaseous fuels other than natural gas” under medium combustion plant directive (MCPD).

Can you:

- I. Confirm if the boilers have always run on liquefied petroleum gas (LPG) (since their conversion from diesel) or if the boiler had changed from natural gas to LPG. If there had been a change from natural gas to LPG, state the date that the boilers changed fuel.
- II. Confirm what fuel was used when the emissions data (presented and used for the modelling) was taken. This is due to the air quality assessment stating that the emissions from boilers A2-A4 based on emission monitoring in 2017.
- III. If the boilers had been converted since the emission data was taken please resubmit the air quality modelling at the appropriate emission levels or confirm, with evidence, that the boilers can still achieve the emissions levels in the air quality modelling.
- IV. If the boilers had run on LPG when emission data was taken confirm, with evidence, that the boilers can still achieve the emissions levels used for the air quality modelling.

End of schedule

Ffôn/Tel 0300 065 4448
Ebost/Email william.wallace@cyfoethnaturiolcymru.gov.uk
william.wallace@naturalresourceswales.gov.uk

Gwasanaeth Trwyddedu, Cyfoeth Naturiol Cymru, Tŷ Cambria, 29 Heol Casnewydd, Caerdydd. CF24 0TP
Permitting Service, Natural Resources Wales, Cambria House, 29 Newport Road, Cardiff. CF24 0TP

Gwefan/Website www.cyfoethnaturiolcymru.gov.uk
www.naturalresourceswales.gov.uk

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg
Correspondence welcomed in Welsh and English