

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BH0056201

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at TAVERNSPITE STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed: Dated:

Name (block capitals): Position:

(to be completed when signing on behalf of corporate bodies)





*Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru*

*National Rivers Authority
Welsh Region*

WATER RESOURCES ACT 1991

Consent No. BH0056201

Under Section 88 and Schedule 10 of the Water Resources Act 1991 and all other enabling powers the National Rivers Authority hereby serves this Notice

R E V I E W O F C O N S E N T

Page 1 of 3

On: Dŵr Cymru Cyfyngedig

Of: Plas Y Ffynnon, Cambrian Way, Brecon, Powys, LD3 7HP

In respect of the previous Consent No. BH0056201 issued on : 1st March 1983

For: A Discharge of Biologically Treated Sewage Effluent

From: Tavernspite STW., Whitland, Dyfed

CONDITIONS OF CONSENT

1. The discharge shall consist only of biologically treated sewage effluent.
2. The discharge shall be made in the manner and at the place specified as follows:-

Discharging via : 150mm diameter pipe
Discharging to : Afon Cwm-Waun-Gron
At OS Grid Ref. : SN 1822 1335
As shown marked : Consent Point 'B' on the attached drawing/plan no. BH0056201
3. Adequate facilities, approved in writing by the Authority, shall be provided to enable representative samples of the discharge to be safely and conveniently obtained at any time at the sampling chamber as shown marked 'Point A' on the attached drawing/plan no. BH0056201/1
4. The volume of effluent discharged under dry weather flow conditions shall not exceed 80 cubic metres per day.
5. The maximum rate of flow of effluent discharged shall not exceed 1.8 litres per second.

continued.....

Aelod Rhanbarthol o'r Bwrdd
Yr Athro Ron Edwards

Rheolwr Rhanbarth Cyllfredinol
Dr John Stoner

Llys Afon
Hawthorn Rise
Hwlfordd
Dyfed SA61 2BQ
Ffôn: Hwlfordd (0437) 760081
Ffacs: (0437) 760881

Regional Board Member
Professor Ron Edwards

Regional General Manager
Dr John Stoner

Llys Afon
Hawthorn Rise
Haverfordwest
Dyfed SA61 2BQ
Tel: Haverfordwest (0437) 760081
Fax: (0437) 760881

WATER RESOURCES ACT 1991
Continuation Sheet

Consent No. BH0056201

page 2 of 3

6. The maximum volume of effluent discharged shall not exceed 160 cubic metres per day.
7. Calibrated apparatus, approved in writing by the Authority, shall be provided and maintained in full working order, to permit the instantaneous rate of flow of effluent discharged to be measured accurately at any time.
8. The quality of the effluent discharged at all flow rates up to the maximum specified in condition 5 shall neither be inferior to the following lower tier numerical limits, except as provided for in the Annex 1, nor to the upper tier limits.
- 8a. The lower tier 5 day Biochemical Oxygen Demand (BOD ATU), determined at 20 degrees Celsius after the suppression of nitrification using allyl thiourea, shall not exceed 15 milligrammes of Oxygen per litre of sample. The upper tier BOD(ATU) shall not exceed 30 milligrammes of Oxygen per litre of sample.
- 8b. The lower tier Suspended Solids concentration (dried at 105 degrees Celsius) shall not exceed 20 milligrammes per litre. The upper tier Suspended Solids concentration shall not exceed 50 milligrammes per litre.
- 8c. The lower tier Ammoniacal Nitrogen concentration, expressed as Nitrogen, shall not exceed 5 milligrammes per litre. The upper tier Ammoniacal Nitrogen concentration shall not exceed 10 milligrammes per litre.
9. The effluent shall not contain any solid matter having a particle size greater than 6mm in any two dimensions.
10. The Authority shall be informed in writing as soon as reasonably practicable of any information received by Dŵr Cymru to the effect that there has been or is likely to be discharged into the sewerage system connected to the works, a significant increase in the quantity of any of the substances listed in the attached Annex 2.

continued.....

WATER RESOURCES ACT 1991
Continuation Sheet

Consent No. BH0056201

page 3 of 3

11. For the purposes of this consent dry weather flow shall mean the average daily flow to the treatment works during seven consecutive days without rain (excluding a period which includes public holidays) following seven days during which the rainfall did not exceed 0.25 mm on one day.

This Consent is given on: 1 DECEMBER 1992 on behalf of the Authority
by: Shweta Area Environmental Quality Manager

During the period ending with the 30 NOVEMBER 1994 the terms of this Consent will not be altered without the written agreement of the person making the discharge.

CONSENT NO.	BH0056201
SCHEDULE NO.	BH005620101

ANNEX

- | | |
|--|------------------------------|
| 1. Mercury and its compounds | 2. Cadmium and its compounds |
| 3. Hexachlorocyclohexane
(lindane and related compounds) | 4. Carbon tetrachloride |
| 5. DDT (the isomers of 1,1,1-trichloro-2,2 bis{p-chlorophenyl} ethane) | |
| 6. Pentachlorophenol (PCP) | 7. Aldrin |
| 8. Dieldrin | 9. Endrin |
| 10. Isodrin | 11. Hexachlorobenzene (HCB) |
| 12. Hexachlorobutadiene (HCBd) | 13. Chloroform |
| 14. Polychlorinated biphenyls | 15. Dichlorvos |
| 16. 1,2-Dichloroethane | 17. Trichlorobenzene |
| 18. Atrazine | 19. Simazine |
| 20. Tributyltin compounds | 21. Triphenyltin compounds |
| 22. Trifluralin | 23. Fenitrothion |
| 24. Azinphos-methyl | 25. Malathion |
| 26. Endosulfan | 27. Lead |
| 28. Chromium | 29. Zinc |
| 30. Copper | 31. Nickel |
| 32. Arsenic | 33. *Iron |
| 34. *pH outside range 5.5 to 9.0 | 35. *Boron |
| 36. Vanadium | 37. PCSD'S |
| 38. Cyfluthrin | 39. Sulcofuron |
| 40. Flucifuron | 41. Permethrin |
| 42. 4-Chloro-3-methyl-phenol | 43. 2-Chlorophenol |
| 44. 2,4-Dichlorophenol | 45. 2,4-D (ester) |
| 46. 2,4-D (non ester) | 47. 1,1,1-Trichloroethane |
| 48. 1,1,2-Trichloroethane | 49. Bentazone |
| 50. Benzene | 51. Biphenyl |
| 52. Chloronitrotoluenes | 53. Demeton |
| 54. Dimethoate | 55. Linuron |
| 56. MCPA | 57. Mecoprop |
| 58. Mevinphos | 59. Napthalene |
| 60. Omethoate | 61. Toluene |
| 62. Triazophos | 63. Xylene |
| 64. Cyanide | 65. Azinphos-ethyl |
| 66. Fenthion | 67. Parathion |
| 68. Parathion-methyl | 69. Trichloroethylene |
| 70. Tetrachloroethylene | 71. Dioxins |
| 72. PAHs | 73. Nonyl phenol |
| 74. Nonyl phenyl ethoxylate | 75. Di-ethylhexyl phthalate |
| 76. Bisphenol-A | 77. Diazinon |
| 78. Chlorfenvinphos | 79. Chlorotoluron |
| 80. Isoproturon | 81. Diuron |
| 82. Propetamphos | 83. Flumethrin |
| 84. Amitraz | 85. High-Cis Cypermethrin |
| 86. Cyromazine | 87. Deltamethrin |
| 88. Cypermethrin | |

This list is applicable as at 1 December 1998 and will be updated as and when changes to the relevant legislative requirements occur.

*Notification to the Agency by the Consent holder is only required in respect of changes to trade effluents likely to cause significant changes to the pH value, and/or iron or boron concentrations, of the crude sewage.

ANNEX 1.

Where the number of samples taken in any period of twelve consecutive months falls within any of the ranges within Column 1 of the table below, the number of samples which are inferior to the numerical quality limit in force at the time for any determinand shall not exceed the appropriate permitted number as listed in Column 2. A sample shall only be considered as having failed in relation to the particular determinand(s) for which the specified quality limit is exceeded. A sample shall be considered to be satisfactory in relation to other determinands the concentration of which are equal to or lower than the specified limit. This annex shall not apply to the upper tier limits.

TABLE

<u>Column 1</u>	<u>Column 2</u>
Number of samples taken in any period of 12 months	Maximum number of samples permitted to exceed limit for given determinand
4-7	1
8-16	2
17-28	3
29-40	4
41-53	5
54-67	6
68-81	7
82-95	8
96-110	9
111-125	10
126-140	11
141-155	12
156-171	13
172-187	14
188-203	15
204-219	16
220-235	17
236-251	18
252-268	19
269-284	20
285-300	21
301-317	22
318-334	23
335-350	24
351-365	25

ANNEX 2.

<u>SUBSTANCE</u>	
Mercury	Fenthion
Cadmium	Parathion
g-Hexachlorocyclohexane	Parathion-methyl
DDT	Tetrachloroethylene
Pentachlorophenol	Trichloroethane
Hexachlorobenzene	Dioxins
Hexachlorobutadiene	Isodrin
Aldrin	
Dieldrin	
Endrin	
Polychlorinated Biphenyls	
Dichlorvos	
1,2 Dichloroethane	
Trichlorobenzene	
Atrazine	
Simazine	
Tributyltin compounds	
Triphenyltin compounds	
Trifluralin	
Fenitrothion	
Azinphos-methyl	
Malathion	
Endosulphan	
Carbon tetrachloride	
Chloroform	
Trichloroethylene	
Perchloroethylene	
Lead	
Chromium	
Zinc	
Copper	
Nickel	
Arsenic	
Iron	
pH	
Boron	
Vanadium	
PCSDs	
Cyfluthrin	
Sulcofuron	
Flucofuron	
Permethrin	
Cyanide	
Azinphos-ethyl	

DISCHARGE POINT

O.S. GRID REF.

SN 1822 1335

TAVERNSPITE STW

O.S. GRID REF.

SN 1830 1300



WALLACE EVANS

Scale

1:2500

Date

APRIL 9

Drawn

EMC

Checked

Drg No.

2F527/AA9/001