



ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales

CONSENT NO.	CG0133701
-------------	-----------

**WATER RESOURCES ACT 1991
SECTION 88 - SCHEDULE 10
(AS AMENDED BY THE ENVIRONMENT ACT 1995)
NOTICE OF MODIFICATION OF CONSENT TO DISCHARGE**

**TO: Dŵr Cymru Cyf
Pentwyn Road
Nelson
Treharris
Mid Glamorgan
CH46 6LY**

WHEREAS the **ENVIRONMENT AGENCY** in pursuance of its powers under Schedule 10 to the Water Resources Act 1991 granted on 12th day of February 1987 CG0133701 permitting the discharge of **TREATED SEWAGE EFFLUENT**

FROM: TREGARTH STW

AT: SH 60810 68710

TO: Ogwen

NOTICE IS HEREBY given by the **ENVIRONMENT AGENCY** that, following the publication of the PR04 agreed programme for sewerage undertakers in England and Wales, and in pursuance of its powers under the paragraph 7(2) of Schedule 10 to the Water Resources Act 1991, the said Consent is **MODIFIED** as follows:

A. Substitution of condition 6(b) attached to CG0133701 by the following new condition:

6(b). Treated Sewage Effluent:

The limits set out below may be exceeded where, in any series of samples taken in the period of 12 months ending on the date of the discharge, as listed in column 1 of Annex 1 attached to this consent no more than the relevant number of samples, as listed in Column 2 of the said Annex, exceeds the applicable limit for that determinant at the time when a sample is taken.

(i) The biological oxygen demand (ATU) in 5 days at 20°C shall not exceed 25 milligrams per litre

Notwithstanding the above paragraph, no sample of the treated sewage effluent shall not contain more than:-

(iv) 60 milligrams per litre of biochemical oxygen demand (ATU) in 5 days at 20°C

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 to the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of modifications made by this notice, without the agreement in writing of the Consent Holder, during a period of 4 years from the date this notice is served.

Environment Agency Wales

Chester Road, Buckley, Flintshire, CH7 3AJ Tel: 08708 506 506 Fax: 01244 550144

Consent Number: CG0133701





ASiantaeth Yr
Amgylchedd Cymru
ENVIRONMENT
AGENCY WALES

This modification is served on 31st March 2005
This modification takes effect on 31st day of December 2005

Signed *Iwan Williams*
Iwan Williams
Regulatory Team Leader (Water Quality)

NOTE. All other conditions of this consent remain unaltered and in force. This notice of modification should be read in conjunction with, CG0133701

CONSENT AMENDMENTS

CONSENT NO	SCHEDULE NO	DATE MODIFICATION ISSUED
CG0133701		31 st March 2005
CONDITIONS : UNCHANGED		
1, 2, 3, 4, 5, 6(a), 7		
CONDITIONS: MODIFIED		DATE ON WHICH NEW OR REVISED CONDITIONS COME INTO FORCE
6(b)		31 st day of December 2005

